



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

JUDICIAL PURCHASING OFFICE  
670 NEW LONDON AVENUE  
CRANSTON, RHODE ISLAND 02920  
TEL: 401-275-6527 FAX:401-275-6530

**B2016007 ADDENDUM #1**

**Date of Addendum: 8/15/16**

**NOTICE TO ALL POTENTIAL RESPONDENTS**

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. The original RFP documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP.

Respondent shall take this Addendum into consideration when preparing and submitting its Proposal.

**The following is a summary of additional scope for the above mentioned project:**

***Non-Electric Zone Valves:***

1. A non-electric zone control valve shall be added in each of three locations on the 4th and 5th floors of the building. In each location, the control valve shall be located on the return side of the zone inside of the existing baseboard cover, downstream of the last finned element. The three locations are as follows:
  - a. 4th floor baseboard zone serving rooms 465, 467 (Women), 468 (Women), and 479. Return side located in Room 479.
  - b. 5th floor baseboard zone serving rooms 519, 520 (Women), 521 (Women) and 522: Return side located in Room 522.
  - c. 5th floor baseboard zone serving rooms 563, 563 (Women), 566 (Women), and 577. Return side located in Room 577.
2. Valve shall be Taco Heat-Gard 5400 series thermostatic non-electric valve, or approved equal, sized by control subcontractor.

***Cabinet Unit Heaters CUH-4-2 & CUH-5-2:***

1. Cabinet unit heaters shall be Trane Model FFDB06 with the same performance characteristics as as shown on schedule on drawing M-3. The CUH's shall have bottom return inlet louver and front duct collar supply to be reconnected to existing supply ductwork. Existing ductwork associated with cabinet unit heaters shall be cleaned and tested for excessive leaks.

**END OF ADDENDUM**