

CITY OF NEWPORT, RHODE ISLAND  
PURCHASING DIVISION  
NOTICE TO BIDDERS

ADDENDUM NO. 1  
BID #13-073

This Addendum No.1 addresses issues resulting from the mandatory pre-bid meeting conducted on April 9, 2013.

**Clarifications**

The scope of work for Option 2 shall also include the following items:

These items pertain to the doorway from the western tower to the exterior parking lot at the ground level.

- Remove the metal door frame
- Remove and replace the lintel above this doorway
  - New lintel shall be hot dip galvanized steel
- Clean and finish the brick and block in the areas where the steel frame has been removed, match adjacent areas in color and finish.