

# Rhode Island Airport Corporation


September 27, 2016

**ADDENDUM NO. 001  
INVITATION FOR BID NO. 26598  
PAINTING OF AIRPORT TERMINAL BUILDING  
WESTERLY STATE AIRPORT, WESTERLY, RI**

Prospective Bidders and all concerned are hereby notified of the following changes in the Invitation for Bid document for the Painting of the Airport Terminal at Westerly Airport, IFB No. 26598. These changes shall be incorporated in and shall become an integral part of the contract documents.

1. Will a bid bond be required?  
**No.**
2. How Many Coats of paint will be required?  
**The bid specifies a minimum of one coat of paint. However, the contractor will need to apply however many coats are required by the manufacturer to obtain and maintain the required 5-year minimum warranty.**
3. Can the building be sprayed or must it be brush painted?  
**Due to the concern of overspray and the close proximity of aircraft, the building will need to be brush painted.**
4. Does the job include the wood support beams under the front and rear entrance canopy?  
**No.**
5. Will the airport be removing the canopy on the front and rear of the building to provide easy access to area above?  
**The canopies will not be removed and must remain intact throughout the project.**
6. Replace Item 9 under Scope of Work with the following:  
**Clean all gutters and downspouts. Apply appropriate finish of compatible color to fascia board and visible flashing.**
7. It appears that there is a substantial amount of siding and trim repair. Can you identify areas or liner footage of trim and siding repair? It is your intention to replace all cracked and split out 45's on the siding?  
**RIAC is relying on the expertise of bidding contractors to determine the necessary repairs to ensure the maximum life expectancy of the existing exterior. The successful bidder will repair or replace any apparent signs of rot.**

8. What is the prevailing wage? **The RI Department of Labor and Training website <http://www.dlt.ri.gov/pw/>, indicates the necessary processes for prevailing wage projects as well as the current wage determinations.**
9. Is there any special requirement to work on site?  
**All work should be coordinated and approved by the RIAC and the airport manager, prior to commencing work.**



---

Carla M. Ottaviano  
Financial Analyst and Administrator

**###END OF ADDENDUM###**