

ADDENDUM NO. 2

Bidding and Contract Documents

For

Relocate Airfield Lighting Vault
Quonset State Airport
North Kingstown, Rhode Island

RHODE ISLAND AIRPORT CORPORATION

April 4, 2013

PREPARED BY:
Parsons Brinckerhoff
10 Dorrance Street, Suite 700
Providence, Rhode Island 02903

NOTICE TO PROSPECTIVE BIDDERS

ADDENDUM NO. 2

Prospective Bidders and all concerned are hereby notified of the following changes in the Contract Documents for RELOCATE AIRFIELD LIGHTING VAULT at the QUONSET STATE AIRPORT. These changes shall be incorporated in and shall become an integral part of the contract documents. The number (No. 2) and date (4/04/13) of this addendum must be entered into the space provided on Page P-4 of the Proposal Form. These changes will be incorporated into the Conformed Contract Documents to be issued to the successful bidder.

BIDDER QUESTIONS

Q1. There is a lot of info in the addendum for the bid that is due in 3 – 4 days. Is there any way the date could get pushed out a few days??

A1. Unfortunately, we are not able to make any changes to the bid opening date due at this time.

Q2. How many S-1 Cutouts will be installed in each of the three (3) new enclosures? Also, is a 24" x 24" x 8"D Stainless Steel Enclosure acceptable for the S1 Cutouts?

A2. Each enclosure contains two (2) cutouts. A 24' x 24" x 8"D stainless steel enclosure is sufficient to house each pair of cutouts and is acceptable.

Note that Addendum No. 2 consists of 2 pages of text.

The period for questions has been completed and this is the final Addendum.

Fully conformed contract documents incorporating the items included in this Addendum will be provided to the successful Contractor upon the award of contract.

APPROVED BY: Date: 4/4/13



RIAC Signature

END OF ADDENDUM No. 2