

ADDENDUM NO. 3

Bidding and Contract Documents

For

Relocate Airfield Lighting Vault
Quonset State Airport
North Kingstown, Rhode Island

RHODE ISLAND AIRPORT CORPORATION

April 5, 2013

PREPARED BY:
Parsons Brinckerhoff
10 Dorrance Street, Suite 700
Providence, Rhode Island 02903

NOTICE TO PROSPECTIVE BIDDERS

ADDENDUM NO. 3

Prospective Bidders and all concerned are hereby notified of the following changes in the Contract Documents for RELOCATE AIRFIELD LIGHTING VAULT at the QUONSET STATE AIRPORT. These changes shall be incorporated in and shall become an integral part of the contract documents. The number (No. 3) and date (4/05/13) of this addendum must be entered into the space provided on Page P-4 of the Proposal Form. These changes will be incorporated into the Conformed Contract Documents to be issued to the successful bidder.

**CLARIFICATION
BIDDERS QUESTIONS**

Addendum No. 1:

Q6. Is FAA supplying FAA panel, 5kv switches, and 45 kva transformer if not we will need more info on these items.

The following answer below **REPLACES** and **SUPERCEDES** the answer from **ADDENDUM NO. 1**:

A6. FAA panel, 5kV switches and 45kVA transformer shall be furnished and installed by the Contractor as part of this Project. Specification for FAA panel is covered by Section 16470. Specification for 45kVA transformer is covered by Section 16460. Specification for 5kV switches is covered by Section 16471, which is added in this Addendum (No. 1).

Note that Addendum No. 3 consists of 2 pages of text.

The period for questions has been completed and this is the final Addendum.

Fully conformed contract documents incorporating the items included in this Addendum will be provided to the successful Contractor upon the award of contract.

APPROVED BY: Date: 4/5/13


RIAC Signature

END OF ADDENDUM No. 3