

Bid# 15082534

Addendum 2 – Ventilation Exhaust Degreasing

Rhode Island College

8/25/15

Addition to Scope of Work:

The exhaust system filter system cleaning is as follows:

Maintenance to Grease Guard Roof Protection System at the Donovan Dining Grill.

A- Provide 6yrs Rotation of Filter Media for GG-XD72

B- Annual Replacement of the Top Two Filter Layers for GG-XD72