

Bid# 15082534

Addendum 3 – Ventilation Exhaust Degreasing

Rhode Island College

9/1/15

Q: In regards to the additional scope of work on the ventilation exhaust degreasing (addendum 2). Could you clarify what you mean by 6×yr rotation of filters? Does this mean we clean your filters you have and rotate them every time we do the Donovan dining grill? Also can you clarify what the Annual replacement of the top two filter layers for the GG-XD72 mean?

A: The exhaust unit for our grill line has a pan and filter system which prevents any grease from going on to the room. The system uses a filter media and filters. The filter media needs to be rotated each time the hood is cleaned. The top two filters need to be changed yearly.