

Rhode Island College  
Cafeteria & Kitchen Equipment, Commercial

**Addendum 1**

8/11/15

Q: On the Pitco fryer, the foot note at the bottom of the specification sheet indicates “AGENCY RESPONSIBLE FOR ALL UTILITY CONNECTIONS”. This unit is normally delivered as ‘deliver, set in place and make ready for final connections by trades. (Any on site person certified in gas/plumbing can make the connections.)

A: **Yes. Rhode Island College will be responsible for all utility connections.**

Q: The electro freeze unit bid description is missing verbiage on the required start up/calibration and training.

A: Rhode Island College requires that start up/calibration and training is required by the successful awarded vendor.

**Additional Information – Line Item #2 – Electro Freezer**

The model’s electrical specifications are to be 208-230/60/3/ Air