


**THE  
UNIVERSITY  
OF RHODE ISLAND**

**DIVISION OF  
ADMINISTRATION  
AND FINANCE**



**PURCHASING DEPARTMENT**  
10 Tootell Road, Suite 3, Kingston, RI 02881 USA    p: 401.874.2171    f: 401.874.2306    uri.edu/purchasing

DATE: 4/25/16

**ADDENDUM #1**

BID NO.: 100240  
OPENING: 5/4/16 @ 3:00pm  
COMMODITY: Pharmacy Equipment

Based on the decision to adjust the final installation site (install to be done by others) in an alternate location within the same room #060 at the Pharmacy Building, a slight increase in capacity of the system will need to be made. Please increase the minimum HP of the compressor from 30 to 40HP with a maximum pressure of 125 PSIG. The Air Dryer is to be no less than 106 SCFM at -40 F dew point. The alternate location for placement of the Air Compressor System in Room #060 is no longer on the existing concrete pad.

The Pre-Bid Conference is still scheduled for 4/26/16 @ 10:00AM, meeting at the URI Pharmacy Building -1<sup>st</sup> floor lobby at 7 Greenhouse Road, Kingston RI 02881.

If you have already submitted a bid and need to make changes, based on the information within the Addendum, please submit a new bid response and indicate that this submission supersedes the prior.

Debra Lee  
URI Assistant Purchasing Agent  
Rev. 9-1-15