

**THE  
UNIVERSITY  
OF RHODE ISLAND**

**DIVISION OF  
ADMINISTRATION  
AND FINANCE**

THINK BIG  WE DO™

PURCHASING DEPARTMENT  
10 Tootell Road, Suite 3, Kingston, RI 02881 USA

p: 401.874.2171

f: 401.874.2306

uri.edu/purchasing



DATE: 11/7/18

**ADDENDUM #1**

BID NO.: 100644  
OPENING: 11/20/18 @ 2:00PM  
COMMODITY: Fire Protection Systems Inspections Testing & Service

The mandatory pre-bid was held on 11/2/18 and the sign in sheet is attached.

Device counts for the fire alarm system are also attached. Please note this list is from 2013 and a few modifications have taken place since this list was populated.

The following vendor questions were received for the question period ending on 11/7/18 at 12:00pm. No additional questions will be answered.

Q1) Will we be provided with device counts for the fire alarm system?


A1) Yes, please see attached

Q2) What do we do if we can't create a CD-R media disk can I submit a Thumb drive?

A2) Bid proposal must include a public copy submit on a read-only CD-R per the specifications. Proposals that do not include a copy for public inspection will be deemed nonresponsive.

Q3) On the bid docs pricing sheets you have quantity and then unit and extended priced listed do you want us to multiply the unit price by the quantity to get the extended price?

A3) Yes.



Ryan Pincince  
Assistant University Purchasing Agent  
Purchasing Department  
The University of Rhode Island



"MANDATORY" PRE-BID CONFERENCE SIGN-IN SHEET

Mandatory pre-bid onference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

BID NUMBER:	100664	PURCHASING REPRESENTATIVE:	Ryan Pincince
BID TITLE:	Fire Protection Systems Inspection Testing & Service		
LOCATION:	URI Providence Campus, 80 Washington Street, Main Lobby, Providence, RI 02903		
PRE BID DATE AND TIME:	11/2/2018 @ 9:30AM	PRE BID END TIME:	9:55 AM

Company Name:	Representative:	Email Address:	Phone Number
URI	Ryan Pincince	ryan.pincince@uri.edu	(401)874-5463
AFPA	CHRIS CULPAN	CCULPAN@AFPA.com	401-331-7003
Encore	Kristen Nolan Angela Gallucci	knolan@encorefireprotection.com victoria.tarochello@jci.com	617-201-9162
Johnson Controls	Victoria LaRocca	<del>vlarocca@jci.com</del>	401-200-2161
Red Hawk Fire	Susan Lindholm	Susan.Lindholm@RedHawkFire.com	914.552.8402
U.B.I.	Ed Coppola	ecoppola@uri.edu	401-277-5179
Electronic Alarm	H. Guzeika	henryte@electronicalarm.com	401.737.2221

-----  
-----  
SHEPARD'S BUILDING

GENERAL INFORMATION

Page 1

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

4100 Fire Alarm System

GENERAL

Simplex Time Recorder Co.

INFO

Node Number: 1

System Type: 4100+

Job Filename : 9520019D

Job Title : SHEPARD'S BUILDING

Order Number : 1435579

Customer :

Customer Contact :

Contractor : AUDET E W & SONS, INC.

Salesperson : MARK LORD

Branch Number : 149

Branch Location : PROVIDENCE, RI

Programmed by : BRYAN LYNCH

Agency Approval : UL

NFPA Standard : 72A

Standby Generator? : NO

Hours of Standby Battery : 60

Comments :

:

Job Rev : 16

Built Rev : 15

Built Date : 26-Jun-13 12:19

Current

As Built

-----

-----

Programmer Rev : 9.02.22 8.05

System Defaults Rev : 99 80

Database (DBF) Format : 99 81

CFIG Format : 0 0

-----  
-----  
SHEPARD'S BUILDING

SYSTEM OPERATION

Page 2

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

# OPTIONS

## SUMMARY

Standard System Operations	Enabled?	Settings
-----	-----	-----
Alarm Silence Inhibit.....	NO	
Time Limit Signal Control...	NO	
System Trouble Reminder.....	NO	
Dedicated Waterflow Signals.	NO	
Sprinkler Supv. Operation...	NO	
Alarm Verification Setup....	NO	
Individual Acknowledge .....	NO	GLOBAL
Elevator Recall Operation...	YES	*
Non-Steady Audible Evac Sig.	NO	
Non-Steady Visual Evac Sig.	YES	MARCH TIME
Door Holder Operation.....	YES	*
Display First Alarm.....	NO	

Expanded System Operations	Enabled?	Settings
-----	-----	-----
24-Hr Time/Date Format.....	NO	12 HOUR
Coding Group Configuration..	NO	
Audio Coding Configuration..	NO	
Audio Option Configuration..	YES	*
Walk Test by Group.....	NO	
Non-General Alarm Operation.	NO	
Pre-Programmed User Lists...	YES	*
Temperature in Centigrade...	NO	FAHRENHEIT
Default Local Mode.....	YES	
Paging Channel Selection....	YES	Paging Channel: 1

Other Selections	Enabled?	Settings
-----	-----	-----
Access Levels		*
Non-Default Passcodes	YES	
City Connect		Local Energy Masterbox
Custom Control	YES	Program: 3, 4, 5, 6

\* Operation ENABLED. See Options Detail Report for full description.

SHEPARD'S BUILDING

CARD SUMMARY BY LOCATION

Page 3

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD

CARD LOCATION LISTING:

LOCATION

# LOCAL CONTROLLER UNIT:

## DAUGHTER CARDS:

Range	Card	Card Type	Zone
-----	-----	-----	-----
	0	(7003) 4100+ Master Controller	
	1	(0113) 2120/RS232 Interface	
	2	(6005) Power Supply/Charger	
	3	(4331) 3 Input Class A Signal	SIG3-8
	4	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX3-6
	6	(0210) Audio Controller	
	7	(0110) MAPNET Interface	M1-1 - 48
	8	(0304) Remote Unit Interface (RUI)	RUI 1
	9	(4011) 2 Ckt Class A Signal (IAC)	SIG9-14
	35	(3003) 8 Pt, 3 Amp Relay w/ Feedback	AUX27-34

## ANNUNCIATORS:

Range	Annun Card	Card Type	Zone
-----	-----	-----	-----
	0	64 LED / 64 Sw Controller	
	5	(0301) 64 LED / 64 Sw Controller	

## REMOTE UNIT INTERFACE 1 (RUI 1):

Type Unit	Card	Card Type	Zone
Range	-----	-----	-----
Ann 1	10	(6005) Power Supply/Charger (Audio)	
Ann 1	11	(0110) MAPNET Interface	M2-1 -
127			
Ann 1	12	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX7-10
Ann 1	13	(4011) 2 Ckt Class A Signal (IAC)	SIG15-20
Ann 1	14	(4331) 3 Input Class A Signal	SIG21-26
Ann 2	15	(4331) 3 Input Class A Signal	SIG27-32
Ann 2	16	(6005) Power Supply/Charger (Audio)	
Ann 2	17	(0110) MAPNET Interface	M3-1 -
127			
Ann 2	18	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX11-14
Ann 2	19	(4031) 6 Ckt Class A Signal (IAC)	SIG33-38
Ann 3	20	(4331) 3 Input Class A Signal	SIG39-44
Ann 3	21	(6005) Power Supply/Charger (Audio)	
Ann 3	22	(0110) MAPNET Interface	M4-1 -
127			
Ann 3	23	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX15-18
Ann 3	24	(4011) 2 Ckt Class A Signal (IAC)	SIG45-50
Ann 4	25	(4331) 3 Input Class A Signal	SIG51-56
Ann 4	26	(6005) Power Supply/Charger (Audio)	
Ann 4	27	(0110) MAPNET Interface	M5-1 -

127

Ann	4	28	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX19-22
Ann	4	29	(4031) 6 Ckt Class A Signal (IAC)	SIG57-62

-----  
SHEPARD'S BUILDING

CARD SUMMARY BY LOCATION

Page 4

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CARD

CARD LOCATION LISTING:

LOCATION

continued

REMOTE UNIT INTERFACE 1 (RUI 1):

Type	Unit	Card	Card Type	Zone
Range				
-----	----	-----	-----	-----
-----				
Ann	4	36	(0304) Remote Unit Interface (RUI)	
Ann	5	30	(4331) 3 Input Class A Signal	SIG63-68
Ann	5	31	(6005) Power Supply/Charger (Audio)	
Ann	5	32	(0110) MAPNET Interface	M6-1 -
127				
Ann	5	33	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX23-26
Ann	5	34	(4011) 2 Ckt Class A Signal (IAC)	SIG69-74
Ann	6	37	(4603-9101) LCD Annunciator	

REMOTE UNIT INTERFACE 2 (RUI 2):

Type	Unit	Card	Card Type	Zone
Range				
-----	----	-----	-----	-----
-----				
			no remote units	

-----  
SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 5

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

PNIS		Device	Point
Zone Name	Custom Label	Type	Type
Code			
-----			
-----			
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG10	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG11	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG12	SPARE	SIG12	SPEAKER
SIG13	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG14	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG16	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG17	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG19	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG20	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG46	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG47	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

		Device	Point
PNIS			
Zone Name	Custom Label	Type	Type
Code			
SIG49	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG50	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG70	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG71	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER
SIG73	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG74	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG75	VIRTUAL NAC 1 - ALL APPLIANCE OUTPUTS	A/V	SIGNAL
SIG76	VIRTUAL NAC 2 - ALL AUDIBLE DEVICES	AUD	SSIGNAL
SIG78	VIRTUAL NAC 4 - ALL VISUAL DEVICES	VIS	RVISUAL
SIG79	VIRTUAL NAC 5 - ALL ISOLATOR DEVICES	A/V	RELAY
AUX3	LOWER LEVEL DOOR HOLDER CIRCUIT	AUX3	DHOLDER
AUX4	AUX RELAY POINT AUX4		RRELAY
AUX5	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX5	DHOLDER
AUX6	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX6	DHOLDER
AUX7	GROUND FLOOR NORTH DOOR HOLDER CIR	AUX7	DHOLDER
AUX8	SECOND FLOOR NORTH DOOR HOLDER CIR	AUX8	DHOLDER
AUX9	SPARE		RRELAY
AUX10	SPARE		RRELAY
AUX11	GROUND FLOOR SOUTH DOOR HOLDER CIR	AUX11	DHOLDER
AUX12	SECOND FLOOR SOUTH DOOR HOLDER CIR	AUX12	DHOLDER
AUX13	SPARE		RRELAY



AUX14	SPARE		RRELAY
AUX15	THIRD FLOOR DOOR HOLDER CIRCUIT	AUX15	DHOLDER
AUX16	FOURTH FLOOR DOOR HOLDER CIRCUIT	AUX16	DHOLDER
AUX17	SPARE		RRELAY
AUX18	SPARE		RRELAY

-----  
 -----  
 SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 7

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 -----  
 POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

PNIS		Device	Point
Zone Name	Custom Label	Type	Type
Code			
-----			
AUX19	THIRD FLOOR SOUTH DOOR HOLDER CIR	AUX19	DHOLDER
AUX20	FOURTH FLOOR SOUTH DOOR HOLDER CIR	AUX20	DHOLDER
AUX21	GAS VALVE SHUTDOWN	AUX21	RRELAY
AUX22	SPARE		RRELAY
AUX23	FIFTH FLOOR NORTH DOOR HOLDER CIR	AUX23	DHOLDER
AUX24	SIXTH FLOOR NORTH DOOR HOLDER CIR	AUX24	DHOLDER
AUX25	SPARE		RRELAY
AUX26	SPARE		RRELAY
AUX27	DOOR 104 MONITORS M2-41 IAM-ANN LT	AUX27	RELAY
AUX28	DOOR 110 MONITORS M3-35 IAM-ANN LT	AUX28	RELAY
AUX29	DOOR 113 MONITORS M2-43 IAM-ANN LT	AUX29	RELAY
AUX30	DOOR 122 MONITORS M2-45 IAM-ANN LT	AUX30	RELAY
AUX31	DOOR 128 MONITORS M2-47 IAM-ANN LT	AUX31	RELAY
AUX32	AUX RELAY CARD 35 RELAY CKT	AUX32	RELAY
AUX33	DOOR ALARM TROUBLE-ANN LT & PIEZO	AUX33	RELAY
AUX34	DOOR ALARM ANNUNCIATOR PIEZO	AUX34	RELAY
FB3	AUX RELAY FEEDBACK PT FB3		ONOFF
FB4	AUX RELAY FEEDBACK PT FB4		ONOFF
FB5	AUX RELAY FEEDBACK PT FB5		ONOFF
FB6	AUX RELAY FEEDBACK PT FB6		ONOFF
FB7	AUX RELAY FEEDBACK PT FB7		ONOFF
FB8	AUX RELAY FEEDBACK PT FB8		ONOFF
FB9	AUX RELAY FEEDBACK PT FB9		ONOFF
FB10	AUX RELAY FEEDBACK PT FB10		ONOFF
FB11	AUX RELAY FEEDBACK PT FB11		ONOFF
FB12	AUX RELAY FEEDBACK PT FB12		ONOFF
FB13	AUX RELAY FEEDBACK PT FB13		ONOFF
FB14	AUX RELAY FEEDBACK PT FB14		ONOFF
FB15	AUX RELAY FEEDBACK PT FB15		ONOFF
FB16	AUX RELAY FEEDBACK PT FB16		ONOFF
FB17	AUX RELAY FEEDBACK PT FB17		ONOFF

FB18	AUX RELAY FEEDBACK PT FB18	ONOFF
FB19	AUX RELAY FEEDBACK PT FB19	ONOFF
FB20	AUX RELAY FEEDBACK PT FB20	ONOFF
FB21	AUX RELAY FEEDBACK PT FB21	ONOFF
FB22	AUX RELAY FEEDBACK PT FB22	ONOFF
FB23	AUX RELAY FEEDBACK PT FB23	ONOFF
FB24	AUX RELAY FEEDBACK PT FB24	ONOFF
FB25	AUX RELAY FEEDBACK PT FB25	ONOFF
FB26	AUX RELAY FEEDBACK PT FB26	ONOFF
FB27	AUX RELAY CARD 35 FEEDBACK PT FB27	ONOFF
FB28	AUX RELAY CARD 35 FEEDBACK PT FB28	ONOFF
FB29	AUX RELAY CARD 35 FEEDBACK PT FB29	ONOFF
FB30	AUX RELAY CARD 35 FEEDBACK PT FB30	ONOFF
FB31	AUX RELAY CARD 35 FEEDBACK PT FB31	ONOFF
FB32	AUX RELAY CARD 35 FEEDBACK PT FB32	ONOFF

-----  
 -----  
 SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 8

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

# POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

						Device	Point
PNIS							
Zone Name	Custom Label					Type	Type
Code							
-----							
-----							
FB33	AUX RELAY CARD 35 FEEDBACK PT FB33						ONOFF
FB34	AUX RELAY CARD 35 FEEDBACK PT FB34						ONOFF
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1	PHOTO				SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2	PHOTO				SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3	PHOTO				SMOKE
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4	MAZAM				SO
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5	PHOTO				SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6	PHOTO				SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7	PHOTO				SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8	PHOTO				SMOKE
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9	MAZAM				SO
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10	MAZAM				WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12	PHOTO				SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13	PHOTO				SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14	PHOTO				SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15	PHOTO				SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16	ADRPUL				PULL
M1-17	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-17	MAZAM				SO
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18	PHOTO				SMOKE
M1-19	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-19	MAZAM				SO
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20	PHOTO				SMOKE

M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21	PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22	PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23	ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24	PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25	ADRPUL	PULL
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26	PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27	ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28	PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29	PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30	PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31	MAZAM	WATER
M1-32	ZN1 LOWER LEVEL SOUTH-TAMPER SW	M1-32	MAZAM	SO
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33	MAZAM	WATER
M1-34	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-34	MAZAM	SO
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35	PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36	ADRPUL	PULL
M1-37	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-37	MAZAM	SO
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38	MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39	PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40	ADRPUL	PULL
M1-41	ZN3 LOWER LEVEL SO-SPKLR PRESS SW	M1-41	MAZAM	SO
M1-42	DRILL SWITCH DAYCARE CENTER GND FL	M1-42	GENIAM	UTILITY
M1-43	DRILL SWITCH MET SCHOOL 4TH FL SO.	M1-43	GENIAM	UTILITY
M1-44	REMOTE MICROPHONE ASTALK ON/OFF SW	M1-44	GENIAM	UTILITY
M1-45	ALL EMERGENCY EXIT DOORS UNLOCK	M1-45	GENIAM	UTILITY

SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 9

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

		Device	Point
PNIS			
Zone Name	Custom Label	Type	Type
Code			
M1-46	TURNSTILE RELSE SECURITY DESK2 ENT.	M1-46 RZAM	DHOLDER
M1-48	ZN 4 GROUND FLOOR SECURITY OFFICE	M1-48 PHOTO	SMOKE
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	2N4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL

M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL	PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL	PULL
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RZAM	RELAY
M2-41	GROUND FLR NORTH DOOR MON DR 104	M2-41 GENIAM	UTILITY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RZAM	RELAY
M2-43	DOOR MONITOR STR B GRD FL N DR 113	M2-43 GENIAM	UTILITY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RZAM	RELAY
M2-45	DOOR MON NEAR REST RM GRD FL DR122	M2-45 GENIAM	UTILITY

-----

SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 10

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

		Device	Point
PNIS			
Zone Name	Custom Label	Type	Type
Code			

M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY
-------	-----------------------------------	------------	-------

M2-47	DOOR MON NEAR ELECTRIC ROOM DR 128	M2-47	GENIAM	UTILITY
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48	MAZAM	SUPDET
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98	PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99	PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100	ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101	ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102	PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103	PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104	PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105	MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106	PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107	ADRPUL	PULL
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108	PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109	PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110	PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111	PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112	PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113	PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115	ADRPUL	PULL
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116	PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117	PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118	PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119	PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120	PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121	PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122	PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123	PHOTO	SMOKE
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124	ADRPUL	PULL
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126	PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127	PHOTO	SMOKE
M3-1	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-1	ADRPUL	PULL
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4	PHOTO	SMOKE
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5	PHOTO	SMOKE
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6	PHOTO	SMOKE
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7	PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8	PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9	PHOTO	SMOKE
M3-10	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-10	ADRPUL	PULL
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11	PHOTO	SMOKE
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12	MAZAM	WATER
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13	PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14	PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15	PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16	PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17	PHOTO	SMOKE

-----

SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 11

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

POINT SUMMARY

System Point Summary (ascending by zone name):

continued

PNIS

```
Zone Name Custom Label
Code
```

Device Point

Type      Type

M3-18	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-18	PHOTO	SMOKE
M3-19	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-19	PHOTO	SMOKE
M3-20	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-20	ADRPUL	PULL
M3-21	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-21	ADRPUL	PULL
M3-22	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-22	PHOTO	SMOKE
M3-23	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-23	PHOTO	SMOKE
M3-24	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-24	PHOTO	SMOKE
M3-25	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-25	ADRPUL	PULL
M3-26	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-26	ADRPUL	PULL
M3-27	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-27	PHOTO	SMOKE
M3-28	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-28	PHOTO	SMOKE
M3-30	ZN5	GROUND	FLOOR	SOUTH-STAIR C	M3-30	PHOTO	SMOKE
M3-31	ZN5	GROUND	FLOOR	SOUTH-STAIR C	M3-31	ADRPUL	PULL
M3-34		GROUND	FLOOR	DOOR LOCK DR 110	M3-34	RZAM	RELAY
M3-35		GROUND	FLOOR	DOOR MON DR 110	M3-35	GENIAM	UTILITY
M3-50	ZN5	GROUND	FLOOR	DAY CARE ROOM 137	M3-50	PHOTO	SMOKE
M3-51	ZN5	GROUND	FLOOR	DAY CARE ROOM 137	M3-51	PHOTO	SMOKE
M3-52	ZN5	GROUND	FLOOR	DAY CARE ROOM 137	M3-52	PHOTO	SMOKE
M3-53	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-53	PHOTO	SMOKE
M3-54	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-54	PHOTO	SMOKE
M3-55	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-55	PHOTO	SMOKE
M3-56	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-56	PHOTO	SMOKE
M3-57	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-57	PHOTO	SMOKE
M3-110	ZN7	SECOND	FLOOR	SOUTH-ELECTRC RM	M3-110	PHOTO	SMOKE
M3-111	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-111	PHOTO	SMOKE
M3-112	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-112	PHOTO	SMOKE
M3-113	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-113	PHOTO	SMOKE
M3-114	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-114	ADRPUL	PULL
M3-115	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-115	PHOTO	SMOKE
M3-116	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-116	PHOTO	SMOKE
M3-117	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-117	PHOTO	SMOKE
M3-118	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-118	PHOTO	SMOKE
M3-119	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-119	PHOTO	SMOKE
M3-120	ZN7	SECOND	FLOOR	SOUTH-SPKLR FLOW	M3-120	MAZAM	WATER
M3-121	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-121	ADRPUL	PULL
M3-122	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-122	PHOTO	SMOKE
M3-123	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-123	PHOTO	SMOKE
M3-124	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-124	PHOTO	SMOKE
M3-125	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-125	PHOTO	SMOKE
M3-126	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-126	PHOTO	SMOKE
M3-127	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-127	PHOTO	SMOKE
M4-1	ZN8	THIRD	FLOOR	NORTH-STAIR A	M4-1	PHOTO	SMOKE
M4-2	ZN8	THIRD	FLR	NORTH-PASS ELEV LOBBY	M4-2	ADRPUL	PULL
M4-3	ZN8	THIRD	FLR	NORTH-PASS ELEV LOBBY	M4-3	PHOTO	SMOKE
M4-4	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-4	PHOTO	SMOKE
M4-5	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-5	PHOTO	SMOKE

-----  
SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 12

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

PNIS Device Point

Zone Name Custom Label

Type Type

Code

-----  
-----  
M4-6 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-6 PHOTO SMOKE  
M4-7 ZN8 THIRD FLR NORTH-ELECTRIC RM 305 M4-7 PHOTO SMOKE  
M4-8 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-8 PHOTO SMOKE  
M4-9 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-9 PHOTO SMOKE  
M4-10 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-10 PHOTO SMOKE  
M4-11 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-11 ADRPUL PULL  
M4-12 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-12 PHOTO SMOKE  
M4-13 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-13 PHOTO SMOKE  
M4-14 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-14 PHOTO SMOKE  
M4-15 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-15 PHOTO SMOKE  
M4-16 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-16 ADRPUL PULL  
M4-17 ZN8 THIRD FLOOR NORTH-SPKLR FLOW M4-17 MAZAM WATER  
M4-18 ZN8 THIRD FLR NORTH-ELECT RM 304A M4-18 PHOTO SMOKE  
M4-19 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-19 PHOTO SMOKE  
M4-20 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-20 PHOTO SMOKE  
M4-21 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-21 PHOTO SMOKE  
M4-22 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-22 PHOTO SMOKE  
M4-23 ZN8 THIRD FLR NORTH-FR ELEV LOBBY M4-23 ADRPUL PULL  
M4-24 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-24 PHOTO SMOKE  
M4-25 ZN8 THIRD FLOOR NORTH-STAIR B M4-25 PHOTO SMOKE  
M4-113 ZN10 FOURTH FLR NO-ELECT RM 412A M4-113 PHOTO SMOKE  
M4-114 ZN10 FOURTH FLR NORTH-SPKLR FLOW M4-114 MAZAM WATER  
M4-115 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-115 ADRPUL PULL  
M4-116 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-116 PHOTO SMOKE  
M4-117 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-117 PHOTO SMOKE  
M4-118 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-118 PHOTO SMOKE  
M4-119 ZN10 FOURTH FLR NO-FR ELEV LOBBY M4-119 ADRPUL PULL  
M4-120 ZN10 FOURTH FLR NO-FR ELEV LOBBY M4-120 PHOTO SMOKE  
M4-121 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-121 PHOTO SMOKE  
M4-122 ZN10 FOURTH FLR NO-ELECT RM 414 M4-122 PHOTO SMOKE  
M4-123 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-123 PHOTO SMOKE  
M4-124 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-124 PHOTO SMOKE  
M4-125 ZN10 FOURTH FLOOR NORTH-CORRIDOR M4-125 PHOTO SMOKE  
M4-126 ZN10 FOURTH FL NO-PASS ELEV LOBBY M4-126 PHOTO SMOKE  
M4-127 ZN10 FOURTH FL NO-PASS ELEV LOBBY M4-127 ADRPUL PULL  
M5-1 ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-1 PHOTO SMOKE  
M5-2 ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-2 PHOTO SMOKE  
M5-3 ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-3 PHOTO SMOKE

M5-4	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-4	PHOTO	SMOKE
M5-6	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-6	PHOTO	SMOKE
M5-7	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-7	ADRPUL	PULL
M5-8	ZN9	THIRD FLOOR SOUTH-SPKLR FLOW	M5-8	MAZAM	WATER
M5-9	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-9	PHOTO	SMOKE
M5-10	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-10	PHOTO	SMOKE
M5-11	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-11	PHOTO	SMOKE
M5-12	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-12	PHOTO	SMOKE

-----  
 -----  
 SHEPARD'S BUILDING

SYSTEM POINT SUMMARY

Page 13

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

# POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

PNIS		Device	Point
Zone Name	Custom Label	Type	Type
Code			

M5-13	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-13	ADRPUL	PULL
M5-14	ZN9	THIRD FLOOR SOUTH-ELECT RM 320	M5-14	PHOTO	SMOKE
M5-15	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-15	PHOTO	SMOKE
M5-16	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-16	PHOTO	SMOKE
M5-17	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-17	PHOTO	SMOKE
M5-18	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-18	PHOTO	SMOKE
M5-107	ZN11	FOURTH FL SOUTH-ELECT RM 428	M5-107	PHOTO	SMOKE
M5-108		GENERATOR RUNNING	M5-108	MAZAM	SUPERV
M5-109	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-109	PHOTO	SMOKE
M5-110	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-110	PHOTO	SMOKE
M5-111	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-111	PHOTO	SMOKE
M5-112	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-112	PHOTO	SMOKE
M5-113	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-113	ADRPUL	PULL
M5-114	ZN11	FOURTH FLOOR SOUTH-STAIR C	M5-114	PHOTO	SMOKE
M5-115	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-115	PHOTO	SMOKE
M5-116	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-116	PHOTO	SMOKE
M5-117	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-117	PHOTO	SMOKE
M5-118	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-118	PHOTO	SMOKE
M5-119	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-119	PHOTO	SMOKE
M5-120	ZN11	FOURTH FLOOR SOUTH-STAIR D	M5-120	PHOTO	SMOKE
M5-121	ZN11	FOURTH FLR SOUTH-SPKLR FLOW	M5-121	MAZAM	WATER
M5-122	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-122	ADRPUL	PULL
M5-123	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-123	PHOTO	SMOKE
M5-124	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-124	PHOTO	SMOKE
M5-125	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-125	PHOTO	SMOKE
M5-126	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-126	PHOTO	SMOKE
M5-127	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE



M6-2	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-3	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-3	ADRPUL	PULL
M6-5	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-5	ADRPUL	PULL
M6-6	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-6	PHOTO	SMOKE
M6-7	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-7	PHOTO	SMOKE
M6-8	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-8	PHOTO	SMOKE
M6-9	ZN12	FIFTH FLR NORTH-ELECT RM 519	M6-9	PHOTO	SMOKE
M6-10	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-10	PHOTO	SMOKE
M6-11	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-11	PHOTO	SMOKE
M6-12	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-12	ADRPUL	PULL
M6-13	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-13	PHOTO	SMOKE
M6-14	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-14	PHOTO	SMOKE
M6-15	ZN12	FIFTH FLR NORTH-ELECT RM 516	M6-15	PHOTO	SMOKE
M6-16	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-16	PHOTO	SMOKE
M6-17	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-17	ADRPUL	PULL
M6-18	ZN12	FIFTH FLOOR NORTH-SPKLR FLOW	M6-18	MAZAM	WATER
M6-19	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-19	PHOTO	SMOKE
M6-20	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-20	ADRPUL	PULL

-----

-----

SHEPARD'S BUILDING

Page 14

9520019D node:1 rev:16

19-NOV-13

SYSTEM POINT SUMMARY

10:27:30, TUE,

-----

-----

POINT SUMMARY

System Point Summary (ascending by zone name):

ZONE

continued

		Device	Point
PNIS			
Zone Name	Custom Label	Type	Type
Code			
-----			
-----			

M6-21	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-21	PHOTO	SMOKE
M6-93		PASSNGR ELEV DAMPER CONTROL STATUS	M6-93	RZAM	CDAMPER
M6-94		FREIGHT ELEV DAMPER CONTROL STATUS	M6-94	RZAM	CDAMPER
M6-96	ZN13	COMPUTER ROOM FM 200 TROUBLE	M6-96	MAZAM	TROUBLE
M6-97	ZN13	SIXTH FLR NORTH-ELECT RM 630	M6-97	PHOTO	SMOKE
M6-98	ZN15	PASSENGER ELEV PENTHOUSE	M6-98	PHOTO	SMOKE
M6-99	ZN15	PASSENGER ELEV PENTHOUSE	M6-99	ADRPUL	PULL
M6-100	ZN15	FREIGHT ELEVATOR PENTHOUSE	M6-100	ADRPUL	PULL
M6-101	ZN15	FREIGHT ELEVATOR PENTHOUSE	M6-101	PHOTO	SMOKE
M6-102	ZN15	FREIGHT ELEV PENTHOUSE REAR	M6-102	MAZAM	HEAT
M6-103		FREIGHT ELEV ALTERNATE RECALL	M6-103	RZAM	ALTERN
M6-104		FREIGHT ELEVATOR PRIMARY RECALL	M6-104	RZAM	PRIMARY
M6-105	ZN13	SIXTH FL NORTH-FR ELEV LOBBY	M6-105	PHOTO	SMOKE
M6-106	ZN15	TOP OF FREIGHT ELEV SHAFT	M6-106	HEAT	HEAT
M6-107	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-107	PHOTO	SMOKE
M6-108	ZN13	SIXTH FL NORTH-FR ELEV LOBBY	M6-108	ADRPUL	PULL
M6-109	ZN13	SIXTH FLOOR NORTH-STAIR B	M6-109	PHOTO	SMOKE
M6-110	ZN13	SIXTH FLOOR NORTH-SPKLR FLOW	M6-110	MAZAM	WATER

M6-111	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-111	ADRPUL	PULL
M6-112	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-112	PHOTO	SMOKE
M6-113	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-113	PHOTO	SMOKE
M6-114	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-114	PHOTO	SMOKE
M6-115	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-115	PHOTO	SMOKE
M6-116	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-116	PHOTO	SMOKE
M6-117	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-117	PHOTO	SMOKE
M6-118	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-118	PHOTO	SMOKE
M6-119	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-119	HEAT	HEAT
M6-120	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-120	HEAT	HEAT
M6-121	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-121	HEAT	HEAT
M6-122	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-122	ADRPUL	PULL
M6-123	ZN13	SIXTH FLOOR NORTH-STAIR A	M6-123	PHOTO	SMOKE
M6-124	ZN13	6TH FLOOR COMPUTER RM FM200	M6-124	MAZAM	FIRE
M6-126		PASSENGER ELEV ALTERNATE RECALL	M6-126	RZAM	ALTERN
M6-127		PASSENGER ELEV PRIMARY RECALL	M6-127	RZAM	PRIMARY

-----

-----

SHEPARD'S BUILDING

DIGITAL PSEUDO POINT SUMMARY

Page 15

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 128

DIGITAL SUMMARY

256 Point Digital Pseudo

P0 - P45

Point PNIS Codes	Custom Label	Type
-----	-----	-----
-----		---
P0	SYSTEM RESET KEY	UTILITY
P1	ALARM SILENCE KEY	UTILITY
P2	FRONT PANEL LAMPTEST CONTROL (ANNUNC. 0)	UTILITY
P3	FIRE ALARM DETECT	UTILITY
P4	GLOBAL ACKNOWLEDGE ENABLE	UTILITY
P5	SET SERVICE PSEUDO VALUES	UTILITY
P6	ALARM SILENCE	UTILITY
P7	EXTRA CARD IN THE SYSTEM	TROUBLE
P8	KEYPAD ACTIVE	UTILITY
P9	SYSTEM OUT OF CQB'S	TROUBLE
P10	CODED INPUT ACTIVE	UTILITY
P11	UNACKNOWLEDGED FIRE ALARM EXISTS	UTILITY
P12	UNACKNOWLEDGED SUPERVISORY EXISTS	UTILITY
P13	UNACKNOWLEDGED TROUBLE EXISTS	UTILITY
P14	SYSTEM DISABLED - PROGRAMMER DOWNLOAD	TROUBLE
P15	CFIG RAM WRITE PROTECT MISSING (SW1-1)	TROUBLE
P16	SMPL PROGRAM 0 - SYSTEM DEFAULT	UTILITY
P17	SMPL PROGRAM 1 - DEFAULT AUDIO	UTILITY
P18	SMPL PROGRAM 2 - SYSTEM OPTIONS (CODING)	UTILITY
P19	SYSTEM EMERGENCY DOOR LOCK OPERATION	UTILITY
P20	ELEVATOR DAMPER CONTROL OPERATION	UTILITY
P21	BYPASSES AND REMOTE MICROPHONE CONTROL	UTILITY

P22	DRILL SW DAYCARE/MET SCHOOL OPERATION	UTILITY
P23	SMPL PROGRAM 7 - USER CUSTOM CONTROL	UTILITY
P24	CODING GROUP 0 ACTIVE	UTILITY
P25	CODING GROUP 1 ACTIVE	UTILITY
P26	CODING GROUP 2 ACTIVE	UTILITY
P27	CODING GROUP 3 ACTIVE	UTILITY
P28	CODING GROUP 4 ACTIVE	UTILITY
P29	CODING GROUP 5 ACTIVE	UTILITY
P30	CODING GROUP 6 ACTIVE	UTILITY
P31	CODING GROUP 7 ACTIVE	UTILITY
P32	COLD START	TROUBLE
P33	WARM START	TROUBLE
P34	CITY DISCONNECT	TROUBLE
P35	MANUAL EVACUATION SWITCH INPUT	UTILITY
P36	ELEVATOR BYPASS	TROUBLE
P37	DOORHOLDER BYPASS	TROUBLE
P38	CONTROL POINT BYPASS	TROUBLE
P39	SYSTEM EXECUTING FROM RAM	TROUBLE
P40	AUTOMATIC DETECTOR RESET	UTILITY
P41	MASTER FIRE ALARM ACK KEY	UTILITY
P42	MASTER SUPERVISORY ACK KEY	UTILITY
P43	MASTER TROUBLE ACK KEY	UTILITY
P44	CODING BUS DISABLE SWITCH	UTILITY
P45	DRILL SWITCH INPUT	UTILITY

-----

-----

SHEPARD'S BUILDING                      DIGITAL PSEUDO POINT SUMMARY

Page 16

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 128

DIGITAL SUMMARY

256 Point Digital Pseudo

P46 - P91

continued

Point	Custom Label	Type
PNIS Codes		
-----	-----	-----
-----		
P46	DOOR HOLDER TRIGGER	UTILITY
P47	SIGNALS/VISUALS ACTIVE	UTILITY
P48	MANUAL EVACUATION	FIRE
P49	SYSTEM AT ACCESS LEVEL 1 OR GREATER	UTILITY
P50	SYSTEM AT ACCESS LEVEL 2 OR GREATER	UTILITY
P51	SYSTEM AT ACCESS LEVEL 3 OR GREATER	UTILITY
P52	SYSTEM AT ACCESS LEVEL 4	UTILITY
P53	SYSTEM LIST OVERFLOW - WARM START NEEDED	TROUBLE
P54	NETWORK MIKE KEYED	UTILITY
P55	CRT KEYPAD INACTIVITY TIMER DISABLE	UTILITY
P56	CITY CIRCUIT STD TROUBLE RELAY OPERATION	UTILITY
P57	KEYPAD INACTIVITY TIMER DISABLE	UTILITY
P58	SYSTEM TIME/DATE INVALID OR NOT SET	TROUBLE

P59	ALARM VERIFICATION TALLY LIMIT EXCEEDED	TROUBLE
P60	ALARM VERIFICATION GROUP 0 ACTIVE	UTILITY
P61	ALARM VERIFICATION GROUP 1 ACTIVE	UTILITY
P62	ALARM VERIFICATION GROUP 2 ACTIVE	UTILITY
P63	ALARM VERIFICATION GROUP 3 ACTIVE	UTILITY
P64	ALARM VERIFICATION GROUP 4 ACTIVE	UTILITY
P65	ALARM VERIFICATION GROUP 5 ACTIVE	UTILITY
P66	ALARM VERIFICATION GROUP 6 ACTIVE	UTILITY
P67	ALARM VERIFICATION GROUP 7 ACTIVE	UTILITY
P68	FIRST STAGE TIMER EXPIRED	UTILITY
P69	THE EVAC MESSAGE HAS PLAYED	UTILITY
P70	WALK TEST GROUP 0 ENABLED	TROUBLE
P71	WALK TEST GROUP 1 ENABLED	TROUBLE
P72	WALK TEST GROUP 2 ENABLED	TROUBLE
P73	WALK TEST GROUP 3 ENABLED	TROUBLE
P74	WALK TEST GROUP 4 ENABLED	TROUBLE
P75	WALK TEST GROUP 5 ENABLED	TROUBLE
P76	WALK TEST GROUP 6 ENABLED	TROUBLE
P77	WALK TEST GROUP 7 ENABLED	TROUBLE
P78	ALARM SILENCE/ALARM CUTOUT PSEUDO	UTILITY
P79	RESET SPKRS WHEN AUDIO CODING COMPLETE	UTILITY
P80	MASTER MICROPHONE KEYED	UTILITY
P81	REMOTE MICROPHONE 1 KEYED	UTILITY
P82	REMOTE MICROPHONE 2 KEYED	UTILITY
P83	REMOTE MICROPHONE 1 READY TO TALK	UTILITY
P84	REMOTE MICROPHONE 2 READY TO TALK	UTILITY
P85	VTG 1 - ACTIVE	UTILITY
P86	VTG 2 - ACTIVE	UTILITY
P87	EVACUATION MESSAGE ON	UTILITY
P88	EVACUATION MESSAGE OFF	UTILITY
P89	EVACUATION MESSAGE LED	UTILITY
P90	ALERT MESSAGE ON	UTILITY
P91	ALERT MESSAGE OFF	UTILITY

-----

SHEPARD'S BUILDING                      DIGITAL PSEUDO POINT SUMMARY

Page 17

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

CARD No: 128

DIGITAL SUMMARY

256 Point Digital Pseudo

P92 - P137

continued

Point	Custom Label	Type
PNIS Codes		
-----		
-----		
P92	ALERT MESSAGE LED	UTILITY
P93	DRILL MESSAGE ON	UTILITY
P94	DRILL MESSAGE OFF	UTILITY
P95	DRILL MESSAGE LED	UTILITY

P96	ALL CLEAR MESSAGE ON	UTILITY
P97	ALL CLEAR MESSAGE OFF	UTILITY
P98	ALL CLEAR MESSAGE LED	UTILITY
P99	AUX MSG 1 ON	UTILITY
P100	AUX MSG 1 OFF	UTILITY
P101	AUX MSG 1 LED	UTILITY
P102	AUX MSG 2 ON	UTILITY
P103	AUX MSG 2 OFF	UTILITY
P104	AUX MSG 2 LED	UTILITY
P105	PHONE PAGING ON	UTILITY
P106	PHONE PAGING OFF	UTILITY
P107	PHONE PAGING LED	UTILITY
P108	AUDIO OVERRIDE ON	UTILITY
P109	AUDIO OVERRIDE OFF	UTILITY
P110	AUDIO OVERRIDE TROUBLE	TROUBLE
P111	ALL SPEAKERS MINUS ON	UTILITY
P112	ALL SPEAKERS MINUS OFF	UTILITY
P113	ALL SPEAKERS MINUS LED	UTILITY
P114	ALL SPEAKERS CHANNEL 1 ON	UTILITY
P115	ALL SPEAKERS CHANNEL 1 OFF	UTILITY
P116	ALL SPEAKERS CHANNEL 1 LED	UTILITY
P117	ALL SPEAKERS CHANNEL 2 ON	UTILITY
P118	ALL SPEAKERS CHANNEL 2 OFF	UTILITY
P119	ALL SPEAKERS CHANNEL 2 LED	UTILITY
P120	ALL SPEAKERS CHANNEL 3 ON	UTILITY
P121	ALL SPEAKERS CHANNEL 3 OFF	UTILITY
P122	ALL SPEAKERS CHANNEL 3 LED	UTILITY
P123	LOCAL SPEAKER EVAC ON	UTILITY
P124	LOCAL SPEAKER EVAC OFF	UTILITY
P125	LOCAL SPEAKER EVAC LED	UTILITY
P126	LOCAL SPEAKER ALERT ON	UTILITY
P127	LOCAL SPEAKER ALERT OFF	UTILITY
P128	LOCAL SPEAKER ALERT LED	UTILITY
P129	ALL SPEAKERS TALK ON	UTILITY
P130	ALL SPEAKERS TALK OFF	UTILITY
P131	ALL SPEAKERS TALK LED	UTILITY
P132	ANALOG SENSOR ALMOST DIRTY LOG ENABLE	TROUBLE
P133	LOG ANALOG SENSOR PEAK VALUE ENABLE	UTILITY
P134	CLEAR ANALOG SENSOR PEAK VALUE	TROUBLE
P135	ALL ALERT	UTILITY
P136	ALL EVAC	UTILITY
P137	ALL ALERT LED	UTILITY

-----

SHEPARD'S BUILDING

DIGITAL PSEUDO POINT SUMMARY

Page 18

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 128

DIGITAL SUMMARY

256 Point Digital Pseudo

P138 - P183

continued

Point PNIS Codes	Custom Label	Type
P138	MASTER MIKE PRETONE PLAYING ON VTG2	UTILITY
P139	REMOTE MIKE 1 PRETONE PLAYING ON VTG2	UTILITY
P140	REMOTE MIKE 2 PRETONE PLAYING ON VTG2	UTILITY
P141	MANUAL AUDIO EVAC ON	UTILITY
P142	MANUAL AUDIO EVAC OFF	UTILITY
P143	MANUAL AUDIO EVAC LED	UTILITY
P144	DISABLE SUPERVISION ON VTG 1 (2120 APPL)	UTILITY
P145	DISABLE SUPERVISION ON VTG 2 (2120 APPL)	UTILITY
P146	EMPTY AUDIO SERVICE QUEUE	UTILITY
P147	EVAC MSG PLAYING WHEN MICROPHONE KEYED	UTILITY
P148	SYSTEM OUT OF AQB'S	TROUBLE
P149	SPEAKER SWITCH OFF AUTO	TROUBLE
P150	AUDIO CODING GROUP 1 ACTIVE	UTILITY
P151	AUDIO CODING GROUP 2 ACTIVE	UTILITY
P152	VTG 1 - AUDIO SUPERVISION ACTIVE	UTILITY
P153	VTG 2 - AUDIO SUPERVISION ACTIVE	UTILITY
P154	PHONE TALK LINE RELAY FEEDBACK	UTILITY
P155	PHONE NETWORK RELAY FEEDBACK	UTILITY
P156	LOCAL MASTER PHONE HANDSET OFF HOOK	UTILITY
P157	PHONE TALK LINE RELAY CONTROL INPUT	UTILITY
P158	PHONE NETWORK RELAY CONTROL INPUT	UTILITY
P159	PHONE TALK LINE RELAY CONTROL	UTILITY
P160	PHONE NETWORK RELAY CONTROL	UTILITY
P161	MASTER PHONE OFFHOOK SUPERVISION	TROUBLE
P162	MASTER MIKE PRETONE PLAYING ON VTG1	UTILITY
P163	REMOTE MIKE 1 PRETONE PLAYING ON VTG1	UTILITY
P164	REMOTE MIKE 2 PRETONE PLAYING ON VTG1	UTILITY
P165	AMPS SWITCHED TO BATTERY	UTILITY
P166	ENABLE RM PHONE TO RM PHONE CONVERSATION	UTILITY
P167	ALERT MSG PLAYING WHEN MICROPHONE KEYED	UTILITY
P168	MICROPHONE TO EVAC IN EFFECT	UTILITY
P169	MICROPHONE TO ALERT IN EFFECT	UTILITY
P170	MICROPHONE TO TALK (CHANNEL 3) IN EFFECT	UTILITY
P171	BACKGROUND MUSIC RELAY CHANNEL 1	UTILITY
P172	BACKGROUND MUSIC RELAY CHANNEL 2	UTILITY
P173	BACKGROUND MUSIC RELAY CHANNEL 3	UTILITY
P174	VTG 1 CODE'S PRECODE PLAYING	UTILITY
P175	VTG 1 CODE'S AFTER CODE PLAYING	UTILITY
P176	AFTER CODE START - VTG 1	UTILITY
P177	VTG 1 'QUIET' MESSAGE PLAYING	UTILITY
P178	VTG 2 CODE'S PRECODE PLAYING	UTILITY
P179	VTG 2 CODE'S AFTER CODE PLAYING	UTILITY
P180	AFTER CODE START - VTG 2	UTILITY
P181	VTG 2 'QUIET' MESSAGE PLAYING	UTILITY
P182	(2120 APPL) VTG1 CODE START	UTILITY
P183	(2120 APPL) STOP VTG1 QUEUE	UTILITY

19-NOV-13

-----  
-----  
CARD No: 128  
DIGITAL SUMMARY  
256 Point Digital Pseudo  
P184 - P229

continued

Point PNIS Codes	Custom Label	Type
-----	-----	-----
P184	(2120 APPL) VTG2 CODE START	UTILITY
P185	(2120 APPL) STOP VTG2 QUEUE	UTILITY
P186	MIKE DISABLE	UTILITY
P187	VTG & AMPLIFIER TROUBLE DISABLE	UTILITY
P188	VTG SUPERVISION TONE NOT ACTIVE	TROUBLE
P189	SATELLITE PHONE TIMEOUT DISABLE	UTILITY
P190	NETWORK MIKE PRETONE PLAYING	UTILITY
P191	MASTER MIKE KEYED	UTILITY
P192	REMOTE MIKE 1 KEYED	UTILITY
P193	REMOTE MIKE 2 KEYED	UTILITY
P194	MIKES ARE READY TO PAGE	UTILITY
P195	S21 SWITCH ACTIVATED	UTILITY
P196	RAM BATTERY MISSING/FAILED	TROUBLE
P197	2120 1 COMM LOSS	UTILITY
P198	INHIBIT SONALERT	UTILITY
P199	INHIBIT ALARM DEFAULT	UTILITY
P200	FORCE COLD START	UTILITY
P201	AC VOLTAGE FAILURE/BROWNOUT	UTILITY
P202	DETECTOR RESET	UTILITY
P203	LCD ANNUNCIATORS OVERRIDE KEYSWITCH	UTILITY
P204	SIGNALS SILENCED	UTILITY
P205	TRUEALARM SENSITIVITY MODIFIED	TROUBLE
P206	PRINT QUEUE OVERFLOW	UTILITY
P207	NETWORK DIAGNOSTIC MODE	TROUBLE
P208	OUT OF NQB'S	TROUBLE
P209	COMMUNICATIONS SHORT CIRCUIT TROUBLE	TROUBLE
P210	NETWORK DETECTOR RESET	UTILITY
P211	NETWORK SYSTEM RESET	UTILITY
P212	DETECTOR/SYSTEM RESET	UTILITY
P213	4120 NETWORK CARD CONFIGURED	UTILITY
P214	CLEAR VERIFICATION TALLIES	TROUBLE
P215	PRIORITY 2 ALARM DETECT	UTILITY
P216	PRIORITY 2 ALARM RESET REQUEST	UTILITY
P217	NETWORK SIGNAL SILENCE	UTILITY
P218	UNACKNOWLEDGED PRIORITY 2 ALARM EXISTS	UTILITY
P219	MASTER PRIORITY 2 ALARM ACK KEY	UTILITY
P220	NETWORK PRIORITY 2 RESET	UTILITY
P221	SIGNALS ACTIVE - OFF ON SILENCE	UTILITY
P222	REMOTE DOWNLOAD ENABLED	TROUBLE
P223	MASTER MICROPHONE READY TO TALK	UTILITY
P224	NETWORK INITIALIZATION INCOMPLETE	TROUBLE
P225	NETWORK OPERATING IN DEGRADED STYLE-7	TROUBLE
P226	NETWORK INITIALIZATION IN PROGRESS	TROUBLE





-----  
CARD No: 144  
ANALOG SUMMARY  
256 Point Analog Pseudo  
A0 - A45

Point	Custom Label	Type
-----		
A0	NUMBER OF SYSTEM FIRE ALARMS	ANALOG
A1	NUMBER OF SYSTEM SUPERVISORIES	ANALOG
A2	NUMBER OF SYSTEM TROUBLES	ANALOG
A3	NUMBER OF OLD (UNCLEARED) FIRE ALARMS	ANALOG
A4	NUMBER OF OLD (UNCLEARED) SUPERVISORIES	ANALOG
A5	NUMBER OF OLD (UNCLEARED) TROUBLES	ANALOG
A6	CURRENT HOUR	ANALOG
A7	CURRENT MINUTE	ANALOG
A8	CURRENT SECOND	ANALOG
A9	CURRENT DAY	ANALOG
A10	CURRENT MONTH	ANALOG
A11	CURRENT YEAR	ANALOG
A12	CURRENT ACCESS LEVEL	ANALOG
A13	ACCESS LEVEL TIMEOUT	TIMER
A14	SYSTEM RESET WINDOW TIMER	TIMER
A15	SYSTEM RESET WINDOW TIMER SETPOINT	ANALOG
A16	DETECTOR RESET PULSE TIMER	TIMER
A17	4-WIRE RESET RELAY PULSE TIMER	TIMER
A18	FIRE ALARM CLEAR DELAY TIMER	TIMER
A19	FIRE ALARM CLEAR DELAY TIMER SETPOINT	ANALOG
A20	FIRE ALARM CLEAR PULSE TIMER	TIMER
A21	SYSTEM RESET PULSE TIMER	TIMER
A22	ALARM SILENCE INHIBIT TIMER	TIMER
A23	ALARM SILENCE INHIBIT TIMER SETPOINT	ANALOG
A24	FIRE ALARM CUTOUT TIMER	TIMER
A25	FIRE ALARM CUTOUT TIMER SETPOINT	ANALOG
A26	FIRE ALARM CUTOUT SILENCE PULSE TIMER	TIMER
A27	TROUBLE REMINDER CYCLE TIMER	TIMER
A28	TROUBLE REMINDER OFF-TIME SETPOINT	ANALOG
A29	TROUBLE REMINDER ON-TIME SETPOINT	ANALOG
A30	DOOR HOLDER ALARM DROP TIMER	TIMER
A31	DOOR HOLDER ALARM DROP TIMER SETPOINT	ANALOG
A32	DOOR HOLDER BROWNOUT DROP TIMER	TIMER
A33	DOOR HOLDER BROWNOUT DROP TIMER SETPOINT	ANALOG
A34	SYSTEM STARTUP PULSE TIMER	TIMER
A35	FIRE ALARM AUDIBLE SIGNAL OPERATION	ANALOG
A36	FIRE ALARM VISUAL SIGNAL OPERATION	ANALOG
A37	ALARM VERIFICATION - RETARD TIME	ANALOG
A38	ALARM VERIFICATION - RESET TIME	ANALOG
A39	ALARM VERIFICATION - CONFIRMATION TIME	ANALOG
A40	ALARM VERIFICATION - TALLY LIMIT	ANALOG
A41	WALK TEST ABORT TIMEOUT SETPOINT	ANALOG
A42	WALK TEST REACTIVATE DELAY SETPOINT	ANALOG
A43	MONITOR ZONE ENABLE DELAY SETPOINT	ANALOG
A44	CODED INPUT TIMEOUT SETPOINT	ANALOG
A45	OFF TIME AFTER PNIS (NON-CONT.) CODES	ANALOG

-----

-----  
SHEPARD'S BUILDING

ANALOG PSEUDO POINT SUMMARY

Page 23

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 144

ANALOG SUMMARY

256 Point Analog Pseudo

A46 - A91

continued

Point	Custom Label	Type
-----	-----	-----
A46	CITY CIRCUIT CONFIGURATION	ANALOG
A47	ALERT TONE/MSG AFTER MICROPHONE UNKEYED	ANALOG
A48	TOTAL AUDIO CHANNELS	ANALOG
A49	CHANNEL 1 ROUTING	ANALOG
A50	CHANNEL 2 ROUTING	ANALOG
A51	CHANNEL 3 ROUTING	ANALOG
A52	LOCAL ROUTING	ANALOG
A53	EVAC TONE/MSG AFTER MICROPHONE UNKEYED	ANALOG
A54	SUPERVISION MSG#	ANALOG
A55	EVACUATION MSG#	ANALOG
A56	ALERT MSG#	ANALOG
A57	DRILL MSG#	ANALOG
A58	ALL CLEAR MSG#	ANALOG
A59	AUX 1 MSG#	ANALOG
A60	AUX 2 MSG#	ANALOG
A61	MICROPHONE PRETONE MSG#	ANALOG
A62	PHONE OFFHOOK TIMER	TIMER
A63	PHONE CALLBACK TIMER	TIMER
A64	PHONE TIMEOUT TIMER	TIMER
A65	REMOTE MASTER PHONE TIMEOUT TIMER	TIMER
A66	SPEAKER SWITCH OFF AUTO COUNT	ANALOG
A67	AUDIO RESET PULSE TIMER	TIMER
A68	VTG 1 PRIORITY	ANALOG
A69	VTG 2 PRIORITY	ANALOG
A70	CHANNEL 1 ROUTING PRIORITY	ANALOG
A71	CHANNEL 2 ROUTING PRIORITY	ANALOG
A72	CHANNEL 3 ROUTING PRIORITY	ANALOG
A73	LOCAL SPEAKER ROUTING PRIORITY	ANALOG
A74	AUDIO SUPERVISION PULSE TIMER VTG1	TIMER
A75	AUDIO SUPERVISION PULSE TIMER VTG2	TIMER
A76	ENABLE/DISABLE STATISTIC GROUP	ANALOG
A77	ENABLE/DISABLE STATISTIC OUTPUT PORT	ANALOG
A78	5 SEC TIMER FOR REMOTE MASTER PHONES	TIMER
A79	CLEAR PEAK PULSE	ANALOG
A80	PRECODE MESSAGE NUMBER - VTG 1	ANALOG
A81	AFTER CODE MESSAGE NUMBER - VTG 1	ANALOG
A82	PRECODE MESSAGE NUMBER - VTG 2	ANALOG
A83	AFTER CODE MESSAGE NUMBER - VTG 2	ANALOG
A84	'QUIET' MESSAGE NUMBER	ANALOG
A85	2 SECOND TIMER - VTG 1	TIMER
A86	2 SECOND TIMER - VTG 2	TIMER

A87	MIKE INHIBIT TIMER	TIMER
A88	MIKE INHIBIT TIMER SETPOINT	ANALOG
A89	PHONE CALLBACK TIMER SETPOINT	ANALOG
A90	PHONE TIMEOUT TIMER SETPOINT	ANALOG
A91	VTG & AMPLIFIER TROUBLE DISABLE TIMER	TIMER

-----  
-----  
SHEPARD'S BUILDING

ANALOG PSEUDO POINT SUMMARY

Page 24

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 144

ANALOG SUMMARY

256 Point Analog Pseudo

A92 - A137

continued

Point	Custom Label	Type
-----	-----	-----
A92	SUPERVISION NOT ACTIVE - TBL DELAY TIMER	TIMER
A93	4 WIRE DETECTOR RESET EXTEND TIMER	TIMER
A94	ACTIVE MESSAGE NUMBER - VTG 1	ANALOG
A95	ACTIVE MESSAGE NUMBER - VTG 2	ANALOG
A96	ACTUAL CHIPSET PLUGGED INTO VTG 1	ANALOG
A97	ACTUAL CHIPSET PLUGGED INTO VTG 2	ANALOG
A98	BATTERY TROUBLE COUNTER	COUNTER
A99	AC POWER FAIL COUNTER	COUNTER
A100	SYSTEM TYPE	ANALOG
A101	FIRST STAGE TIMER	ANALOG
A102	FIRST STAGE TIMER SETPOINT	ANALOG
A103	MASTER MIKE 5 SECOND UNKEY DELAY	ANALOG
A104	REMOTE MIKE 1 5 SECOND UNKEY DELAY	ANALOG
A105	REMOTE MIKE 2 5 SECOND UNKEY DELAY	ANALOG
A106	MASTER MIKE'S PRETONE TIMER	ANALOG
A107	MASTER MIKE'S PRETONE SETPOINT	ANALOG
A108	REMOTE MIKE 1'S PRETONE TIMER	ANALOG
A109	REMOTE MIKE 1'S PRETONE SETPOINT	ANALOG
A110	REMOTE MIKE 2'S PRETONE TIMER	ANALOG
A111	REMOTE MIKE 2'S PRETONE SETPOINT	ANALOG
A112	GROUND TROUBLE COUNTER	COUNTER
A113	PAGING CHANNEL	ANALOG
A114	TRUEALARM MODIFICATION COUNTER	COUNTER
A115	EXCESSIVELY DIRTY (OUT OF RANGE)	ANALOG
A116	DIRTY SENSOR COUNTER	COUNTER
A117	ALMOST DIRTY COUNTER	COUNTER
A118	ALARMS SILENCED DELAY TIMER	TIMER
A119	NUMBER OF LOCAL SYSTEM POINTS' TROUBLES	COUNTER
A120	SYSTEM PAGING STATUS	ANALOG
A121	KEYPAD INACTIVITY TIMEOUT SETPOINT	ANALOG
A122	NUMBER OF SYSTEM PRIORITY 2 ALARMS	ANALOG
A123	NUMBER OF OLD (UNCLEARED) PRI2 ALARMS	ANALOG
A124	PRI2 RESET WINDOW TIMER	TIMER
A125	PRI2 RESET WINDOW TIMER SETPOINT	ANALOG

A126	PRI2 ALARM CLEAR DELAY TIMER	TIMER
A127	PRI2 ALARM CLEAR DELAY TIMER SETPOINT	ANALOG
A128	PRI2 ALARM CLEAR PULSE TIMER	TIMER
A129	PRIORITY 2 RESET PULSE TIMER	TIMER
A130	PRIORITY 2 RESET START TIMER	TIMER
A131	SUPERVISION DELAY SETPOINT CHL1	ANALOG
A132	SUPERVISION DELAY SETPOINT CHL2	ANALOG
A133	SUPERVISION NOT ACTIVE DELAY SETPOINT	ANALOG
A134	LEFT END NETWORK NODE	ANALOG
A135	RIGHT END NETWORK NODE	ANALOG
A136	TRUEALERT DIAGNOSTICS TIMER	TIMER
A137	TRUEALARM CONSTANT VALUE	ANALOG

-----  
 SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY

Page 25

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 CARD No: 144  
 ANALOG SUMMARY  
 256 Point Analog Pseudo  
 A138 - A138

continued

Point	Custom Label	Type
A138	TRUEALARM LOW VALUE FILTER DELAY	ANALOG

-----  
 SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY

Page 26

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 CARD No: 145  
 ANALOG SUMMARY  
 256 Point Analog Pseudo

no labels assigned - presumed unused

-----  
 SHEPARD'S BUILDING POINT LIST SUMMARY

Page 27

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 CARD No: 160  
 POINT LIST

256 Point List Pseudo  
L0 - L42

List Name	Description	Points
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)	36
L1	CODING GROUP 1 SIGNALS/RELAYS	EMPTY
L2	CODING GROUP 2 SIGNALS/RELAYS	EMPTY
L3	CODING GROUP 3 SIGNALS/RELAYS	EMPTY
L4	CODING GROUP 4 SIGNALS/RELAYS	EMPTY
L5	CODING GROUP 5 SIGNALS/RELAYS	EMPTY
L6	CODING GROUP 6 SIGNALS/RELAYS	EMPTY
L7	CODING GROUP 7 SIGNALS/RELAYS	EMPTY
L8	FIRE ALARM SIGNALS OFF ON SILENCE	35
L9	FIRE ALARM SIGNALS OFF ON RESET	EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE	EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET	11
L12	FIRE ALARM VISUALS OFF ON SILENCE	1
L13	FIRE ALARM VISUALS OFF ON RESET	EMPTY
L14	TROUBLE RELAYS OFF ON CLEAR	EMPTY
L15	TROUBLE RELAYS OFF ON ACKNOWLEDGE	EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET	EMPTY
L17	DOOR HOLDER CONTROL RELAYS	14
L18	GENERAL FIRE ALARM MONITOR ZONES	277
L19	PRIMARY ELEVATOR RECALL MONITOR ZONES	201
L20	ALTERNATE ELEVATOR RECALL MONITOR ZONES	75
L21	PRIMARY ELEVATOR CAPTURE RELAYS	2
L22	ALTERNATE ELEVATOR CAPTURE RELAYS	2
L23	WATERFLOW ALARM MONITOR ZONES	14
L24	WATERFLOW SIGNALS OFF ON SILENCE	EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET	EMPTY
L26	SPRINKLER SUPERVISORY MONITOR ZONES	8
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS	EMPTY
L28	USER SYSTEM LISTS	23
L29	EDITABLE GENERAL ALARM SYSTEM LISTS	24
L30	ALARM VERIFICATION GROUP 0	EMPTY
L31	ALARM VERIFICATION GROUP 1	EMPTY
L32	ALARM VERIFICATION GROUP 2	EMPTY
L33	ALARM VERIFICATION GROUP 3	EMPTY
L34	ALARM VERIFICATION GROUP 4	EMPTY
L35	ALARM VERIFICATION GROUP 5	EMPTY
L36	ALARM VERIFICATION GROUP 6	EMPTY
L37	ALARM VERIFICATION GROUP 7	EMPTY
L38	4 WIRE MONITOR ZONES	EMPTY
L39	NOT USED	EMPTY
L40	WALK TEST GROUP 0	296
L41	WALK TEST GROUP 1	EMPTY
L42	WALK TEST GROUP 2	EMPTY

NOTE: \* Indicates Auto List Generation disabled for system list.

-----  
CARD No: 160  
POINT LIST  
256 Point List Pseudo  
L43 - L85

continued

List Name	Description	Points
-----	-----	-----
L43	WALK TEST GROUP 3	EMPTY
L44	WALK TEST GROUP 4	EMPTY
L45	WALK TEST GROUP 5	EMPTY
L46	WALK TEST GROUP 6	EMPTY
L47	WALK TEST GROUP 7	EMPTY
L48	VNACS OFF ON SILENCE	EMPTY
L49	VNACS OFF ON RESET	EMPTY
L50	WALK TEST GROUP 0 - SIGNALS/RELAYS	56
L51	WALK TEST GROUP 1 - SIGNALS/RELAYS	EMPTY
L52	WALK TEST GROUP 2 - SIGNALS/RELAYS	EMPTY
L53	WALK TEST GROUP 3 - SIGNALS/RELAYS	EMPTY
L54	WALK TEST GROUP 4 - SIGNALS/RELAYS	EMPTY
L55	WALK TEST GROUP 5 - SIGNALS/RELAYS	EMPTY
L56	WALK TEST GROUP 6 - SIGNALS/RELAYS	EMPTY
L57	WALK TEST GROUP 7 - SIGNALS/RELAYS	EMPTY
L58	NOT USED	EMPTY
L59	NOT USED	EMPTY
L60	CODING GROUP 0 - NOT USED (NON-PNIS)	EMPTY
L61	CODING GROUP 1 - MONITOR ZONES	EMPTY
L62	CODING GROUP 2 - MONITOR ZONES	EMPTY
L63	CODING GROUP 3 - MONITOR ZONES	EMPTY
L64	CODING GROUP 4 - MONITOR ZONES	EMPTY
L65	CODING GROUP 5 - MONITOR ZONES	EMPTY
L66	CODING GROUP 6 - MONITOR ZONES	EMPTY
L67	CODING GROUP 7 - MONITOR ZONES	EMPTY
L68	NOT USED	EMPTY
L69	NOT USED	EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM	EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM	EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET	5
L73	CONTROL POINTS OFF - ON SYSTEM RESET	2
L74	CONTROL POINTS OFF - ON SILENCE	1
L75	LPHONE MODE LEDS TRACKING DIGITAL PSEUDO	EMPTY
L76	VARIABLE SENSITIVITY PHOTO ANALOG SENSOR	204
L77	VARIABLE SENSITIVITY ION ANALOG SENSOR	EMPTY
L78	ANALOG SENSORS WITH PIEZO	EMPTY
L79	ANALOG SENSORS WITH RELAY	EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS	20
L81	AUDIO CODING GROUP 1 - MONITOR ZONES	EMPTY
L82	AUDIO CODING GROUP 2 - MONITOR ZONES	EMPTY
L83	AUX1 MESSAGE SPEAKERS	EMPTY
L84	AUX2 MESSAGE SPEAKERS	EMPTY

NOTE: \* Indicates Auto List Generation disabled for system list.

-----  
-----  
SHEPARD'S BUILDING

POINT LIST SUMMARY

Page 29

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CARD No: 160

POINT LIST

256 Point List Pseudo

L86 - L136

continued

List Name	Description	Points
-----	-----	-----
L86	RESTART MESSAGE AFTER MIKE - VTG 2	EMPTY
L87	AHU RELAYS ON - ON FIRE ALARM	2
L88	AHU RELAYS OFF - ON FIRE ALARM	EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET	2
L90	ALL SPEAKERS - NON EDITABLE	20
L91	AUDIO CODING GROUP 1 - SIGNAL CIRCUITS	EMPTY
L92	AUDIO CODING GROUP 2 - SIGNAL CIRCUITS	EMPTY
L93	PHONE CIRCUITS	EMPTY
L94	REMOTE MASTER PHONE CIRCUITS	EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF	EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT	EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH	EMPTY
L98	SWITCH POWER SUPPLY AMPS TO BATTERY	6
L99	SWITCH POWER SUPPLY AMPS TO BKGRND MUSIC	6
L100	POINTS TO EXCLUDE FROM AUTOMAP	EMPTY
L101	RESET POWER SUPPLY AMPS	6
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS	22
L103	EXTERNAL DETECTOR RESET PSEUDO	EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO	EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO	EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO	EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE	EMPTY
L108	EXTERNAL SPEAKERS AND SPEAKER LISTS	EMPTY
L109	ALARM SILENCED LED CONTROL	2
L110	INHIBIT NETWORK LABEL UPDATE	EMPTY
L112	EXTERNAL PRIORITY 2 RESET PSEUDOS	EMPTY
L128	ALL EMERGENCY EXIT DOOR LOCKS	5
L129	GROUND FLOOR SPEAKER CIRCUITS	2
L130	SECOND FLOOR SPEAKER CIRCUITS	2
L131	THIRD FLOOR SPEAKER CIRCUITS	1
L132	FOURTH FLOOR SPEAKER CIRCUITS	1
L133	DAYCARE SPEAKER CIRCUITS	1
L134	MET SCHOOL SPEAKER CIRCUITS	1
L135	ALL STROBE CIRCUITS FOR BLDG DRILL	36

NOTE: \* Indicates Auto List Generation disabled for system list.

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 30

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

CARD No: 160 L0  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 0  
 L0

continued

Description: CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL



SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 31

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L8  
POINT LIST  
256 Point List Pseudo  
LIST No: 8  
L8

continued

Description: FIRE ALARM SIGNALS OFF ON SILENCE

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL

SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL

Page 32

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----

-----  
 CARD No: 160 L11  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 11  
 L11

continued

Description: FIRE ALARM RELAYS OFF ON RESET

Point	Custom Point Label	Device Type	Point Type
AUX4	AUX RELAY POINT AUX4		RRELAY
AUX9	SPARE		RRELAY
AUX10	SPARE		RRELAY
AUX13	SPARE		RRELAY
AUX14	SPARE		RRELAY
AUX17	SPARE		RRELAY
AUX18	SPARE		RRELAY
AUX21	GAS VALVE SHUTDOWN	AUX21	RRELAY
AUX22	SPARE		RRELAY
AUX25	SPARE		RRELAY
AUX26	SPARE		RRELAY

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL

Page 33

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----

-----  
 CARD No: 160 L12  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 12  
 L12

continued

Description: FIRE ALARM VISUALS OFF ON SILENCE

Point	Custom Point Label	Device Type	Point Type
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
-----			
-----			
SHEPARD'S BUILDING		POINT LIST DETAIL	
Page 34			
9520019D node:1 rev:16		10:27:30, TUE,	
19-NOV-13			

```

CARD   No: 160      L17
POINT LIST
256 Point List Pseudo
LIST   No: 17
L17

```

continued  
Description: DOOR HOLDER CONTROL RELAYS

Point	Custom Point Label	Device Type	Point Type
AUX3	LOWER LEVEL DOOR HOLDER CIRCUIT	AUX3	DHOLDER
AUX5	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX5	DHOLDER
AUX6	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX6	DHOLDER
M1-46	TURNSTILE RELSE SECURITY DESK2 ENT.	M1-46 RZAM	DHOLDER
AUX7	GROUND FLOOR NORTH DOOR HOLDER CIR	AUX7	DHOLDER
AUX8	SECOND FLOOR NORTH DOOR HOLDER CIR	AUX8	DHOLDER
AUX11	GROUND FLOOR SOUTH DOOR HOLDER CIR	AUX11	DHOLDER
AUX12	SECOND FLOOR SOUTH DOOR HOLDER CIR	AUX12	DHOLDER
AUX15	THIRD FLOOR DOOR HOLDER CIRCUIT	AUX15	DHOLDER
AUX16	FOURTH FLOOR DOOR HOLDER CIRCUIT	AUX16	DHOLDER
AUX19	THIRD FLOOR SOUTH DOOR HOLDER CIR	AUX19	DHOLDER
AUX20	FOURTH FLOOR SOUTH DOOR HOLDER CIR	AUX20	DHOLDER
AUX23	FIFTH FLOOR NORTH DOOR HOLDER CIR	AUX23	DHOLDER
AUX24	SIXTH FLOOR NORTH DOOR HOLDER CIR	AUX24	DHOLDER

SHEPARD'S BUILDING                      POINT LIST DETAIL  
Page 35  
9520019D node:1 rev:16                      10:27:30, TUE,  
19-NOV-13

CARD No: 160 L18  
POINT LIST  
256 Point List Pseudo  
LIST No: 18  
L18

continued  
Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16 ADRPUL	PULL
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23 ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25 ADRPUL	PULL
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27 ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36 ADRPUL	PULL
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40 ADRPUL	PULL
M1-48	ZN 4 GROUND FLOOR SECURITY OFFFICE	M1-48 PHOTO	SMOKE
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	2N4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 36

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L18

POINT LIST  
 256 Point List Pseudo  
 LIST No: 18  
 L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL	PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL	PULL
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE

-----  
 -----  
 CARD No: 160 L18  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 18  
 L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124 ADRPUL	PULL
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE
M3-1	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-1 ADRPUL	PULL
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4 PHOTO	SMOKE
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5 PHOTO	SMOKE
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6 PHOTO	SMOKE
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE
M3-10	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-10 ADRPUL	PULL
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11 PHOTO	SMOKE
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE

M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25	ADRPUL	PULL
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26	ADRPUL	PULL
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27	PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28	PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 38

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

CARD No: 160 L18  
POINT LIST  
256 Point List Pseudo  
LIST No: 18  
L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-114	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-114 ADRPUL	PULL
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M3-121	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-121 ADRPUL	PULL
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE

M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4	PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5	PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6	PHOTO	SMOKE
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7	PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8	PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9	PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10	PHOTO	SMOKE
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11	ADRPUL	PULL
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12	PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13	PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14	PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 39

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L18  
POINT LIST  
256 Point List Pseudo  
LIST No: 18  
L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-119	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-119 ADRPUL	PULL
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE



M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126	PHOTO	SMOKE
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-127	ADRPUL	PULL
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1	PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2	PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3	PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4	PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6	PHOTO	SMOKE
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-7	ADRPUL	PULL
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8	MAZAM	WATER
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9	PHOTO	SMOKE
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10	PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11	PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12	PHOTO	SMOKE
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-13	ADRPUL	PULL
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14	PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15	PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16	PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17	PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 40

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L18  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 18  
 L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113 ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115 PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116 PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117 PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122 ADRPUL	PULL
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE

M5-124	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-124	PHOTO	SMOKE
M5-125	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-125	PHOTO	SMOKE
M5-126	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-126	PHOTO	SMOKE
M5-127	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE
M6-2	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-3	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-3	ADRPUL	PULL
M6-5	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-5	ADRPUL	PULL
M6-6	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-6	PHOTO	SMOKE
M6-7	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-7	PHOTO	SMOKE
M6-8	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-8	PHOTO	SMOKE
M6-9	ZN12	FIFTH FLR NORTH-ELECT RM 519	M6-9	PHOTO	SMOKE
M6-10	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-10	PHOTO	SMOKE
M6-11	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-11	PHOTO	SMOKE
M6-12	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-12	ADRPUL	PULL
M6-13	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-13	PHOTO	SMOKE
M6-14	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-14	PHOTO	SMOKE
M6-15	ZN12	FIFTH FLR NORTH-ELECT RM 516	M6-15	PHOTO	SMOKE
M6-16	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-16	PHOTO	SMOKE
M6-17	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-17	ADRPUL	PULL
M6-18	ZN12	FIFTH FLOOR NORTH-SPKLR FLOW	M6-18	MAZAM	WATER
M6-19	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-19	PHOTO	SMOKE
M6-20	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-20	ADRPUL	PULL
M6-21	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-21	PHOTO	SMOKE
M6-97	ZN13	SIXTH FLR NORTH-ELECT RM 630	M6-97	PHOTO	SMOKE

-----

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 41

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 160 L18

POINT LIST

256 Point List Pseudo

LIST No: 18

L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
-----	-----	-----	-----
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100 ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102 MAZAM	HEAT
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106 HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE
M6-108	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-108 ADRPUL	PULL
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109 PHOTO	SMOKE

M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110 MAZAM	WATER
M6-111	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-111 ADRPUL	PULL
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112 PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113 PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114 PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115 PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116 PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117 PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118 PHOTO	SMOKE
M6-119	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119 HEAT	HEAT
M6-120	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120 HEAT	HEAT
M6-121	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121 HEAT	HEAT
M6-122	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-122 ADRPUL	PULL
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE
M6-124	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124 MAZAM	FIRE

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 42

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

CARD No: 160 L19  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 19  
 L19

continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
-----	-----	-----	-----
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16 ADRPUL	PULL
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23 ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25 ADRPUL	PULL

M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27 ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36 ADRPUL	PULL
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40 ADRPUL	PULL
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 43

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

CARD No: 160 L19  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 19  
 L19

continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
-----	-----	-----	-----
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE

M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124 ADRPUL	PULL
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-114	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-114 ADRPUL	PULL
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M3-121	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-121 ADRPUL	PULL
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 44

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

CARD No: 160 L19  
POINT LIST  
256 Point List Pseudo  
LIST No: 19  
L19

continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11 ADRPUL	PULL
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE

M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-119	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-119 ADRPUL	PULL
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE
M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126 PHOTO	SMOKE
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-127 ADRPUL	PULL
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-7 ADRPUL	PULL
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE

-----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 45

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----

-----  
 CARD No: 160 L19

POINT LIST

256 Point List Pseudo

LIST No: 19

L19

continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
-------	--------------------	-------------	------------

M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10	PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11	PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12	PHOTO	SMOKE
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-13	ADRPUL	PULL
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14	PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15	PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16	PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17	PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18	PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107	PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109	PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110	PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111	PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112	PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113	ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114	PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115	PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116	PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117	PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118	PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119	PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120	PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121	MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122	ADRPUL	PULL
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123	PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124	PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125	PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126	PHOTO	SMOKE
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE
M6-2	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-3	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-3	ADRPUL	PULL
M6-5	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-5	ADRPUL	PULL
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6	PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7	PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8	PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9	PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10	PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11	PHOTO	SMOKE
M6-12	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-12	ADRPUL	PULL
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13	PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14	PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 46

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L19

POINT LIST

256 Point List Pseudo

LIST No: 19

L19

continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE
M6-17	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-17 ADRPUL	PULL
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE
M6-20	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-20 ADRPUL	PULL
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21 PHOTO	SMOKE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97 PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100 ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102 MAZAM	HEAT
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106 HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE
M6-108	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-108 ADRPUL	PULL
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109 PHOTO	SMOKE
M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110 MAZAM	WATER
M6-111	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-111 ADRPUL	PULL
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112 PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113 PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114 PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115 PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116 PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117 PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118 PHOTO	SMOKE
M6-119	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119 HEAT	HEAT
M6-120	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120 HEAT	HEAT
M6-121	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121 HEAT	HEAT
M6-122	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-122 ADRPUL	PULL
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE
M6-124	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124 MAZAM	FIRE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 47

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L20

POINT LIST

256 Point List Pseudo

LIST No: 20

L20

continued



## Description: ALTERNATE ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	ZN4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL	PULL
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET
M3-1	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-1 ADRPUL	PULL
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4 PHOTO	SMOKE
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5 PHOTO	SMOKE
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6 PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 48

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L20  
POINT LIST  
256 Point List Pseudo  
LIST No: 20  
L20

continued

Description: ALTERNATE ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE
M3-10	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-10 ADRPUL	PULL
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11 PHOTO	SMOKE
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25 ADRPUL	PULL
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26 ADRPUL	PULL
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL	PULL

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 49

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L21  
POINT LIST

# 256 Point List Pseudo

LIST No: 21

L21

continued

Description: PRIMARY ELEVATOR CAPTURE RELAYS

Point	Custom Point Label	Device Type	Point Type
M6-104	FREIGHT ELEVATOR PRIMARY RECALL	M6-104 RZAM	PRIMARY
M6-127	PASSENGER ELEV PRIMARY RECALL	M6-127 RZAM	PRIMARY

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 50

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L22

POINT LIST

256 Point List Pseudo

LIST No: 22

L22

continued

Description: ALTERNATE ELEVATOR CAPTURE RELAYS

Point	Custom Point Label	Device Type	Point Type
M6-103	FREIGHT ELEV ALTERNATE RECALL	M6-103 RZAM	ALTERN
M6-126	PASSENGER ELEV ALTERNATE RECALL	M6-126 RZAM	ALTERN

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 51

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L23

POINT LIST

256 Point List Pseudo

LIST No: 23

L23

continued

Description: WATERFLOW ALARM MONITOR ZONES

Device Point

Point	Custom Point Label	Type	Type
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER
M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110 MAZAM	WATER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 52

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L26  
POINT LIST  
256 Point List Pseudo  
LIST No: 26  
L26

continued

Description: SPRINKLER SUPERVISORY MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4 MAZAM	SO
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9 MAZAM	SO
M1-17	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-17 MAZAM	SO
M1-19	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-19 MAZAM	SO
M1-32	ZN1 LOWER LEVEL SOUTH-TAMPER SW	M1-32 MAZAM	SO
M1-34	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-34 MAZAM	SO
M1-37	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-37 MAZAM	SO
M1-41	ZN3 LOWER LEVEL SO-SPKLR PRESS SW	M1-41 MAZAM	SO

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 53

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L28  
POINT LIST

## 256 Point List Pseudo

LIST No: 28

L28

continued

Description: USER SYSTEM LISTS

Point	Custom Point Label	Device Type	Point Type
L38	4 WIRE MONITOR ZONES		EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM		EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM		EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET		CONTROL
L73	CONTROL POINTS OFF - ON SYSTEM RESET		CONTROL
L74	CONTROL POINTS OFF - ON SILENCE		CONTROL
L83	AUX1 MESSAGE SPEAKERS		EMPTY
L84	AUX2 MESSAGE SPEAKERS		EMPTY
L85	RESTART MESSAGE AFTER MIKE - VTG 1		EMPTY
L86	RESTART MESSAGE AFTER MIKE - VTG 2		EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF		EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT		EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH		EMPTY
L100	POINTS TO EXCLUDE FROM AUTOMAP		EMPTY
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS		MIXED
L103	EXTERNAL DETECTOR RESET PSEUDO		EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO		EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO		EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO		EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE		EMPTY
L109	ALARM SILENCED LED CONTROL		DPSEUDO
L112	EXTERNAL PRIORITY 2 RESET PSEUDOS		EMPTY
L110	INHIBIT NETWORK LABEL UPDATE		EMPTY

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 54

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L29

POINT LIST

256 Point List Pseudo

LIST No: 29

L29

continued

Description: EDITABLE GENERAL ALARM SYSTEM LISTS

Point	Custom Point Label	Device Type	Point Type
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)		CONTROL

L8	FIRE ALARM SIGNALS OFF ON SILENCE	CONTROL
L9	FIRE ALARM SIGNALS OFF ON RESET	EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE	EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET	CONTROL
L12	FIRE ALARM VISUALS OFF ON SILENCE	CONTROL
L13	FIRE ALARM VISUALS OFF ON RESET	EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET	EMPTY
L17	DOOR HOLDER CONTROL RELAYS	CONTROL
L18	GENERAL FIRE ALARM MONITOR ZONES	MIXED
L21	PRIMARY ELEVATOR CAPTURE RELAYS	CONTROL
L22	ALTERNATE ELEVATOR CAPTURE RELAYS	CONTROL
L24	WATERFLOW SIGNALS OFF ON SILENCE	EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET	EMPTY
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS	EMPTY
L48	VNACS OFF ON SILENCE	EMPTY
L49	VNACS OFF ON RESET	EMPTY
L78	ANALOG SENSORS WITH PIEZO	EMPTY
L79	ANALOG SENSORS WITH RELAY	EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS	CONTROL
L87	AHU RELAYS ON - ON FIRE ALARM	CONTROL
L88	AHU RELAYS OFF - ON FIRE ALARM	EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET	CONTROL
L108	EXTERNAL SPEAKERS AND SPEAKER LISTS	EMPTY

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 55

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

CARD No: 160 L40  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 40  
 L40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4 MAZAM	SO
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9 MAZAM	SO
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE

M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14	PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15	PHOTO	SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16	ADRPUL	PULL
M1-17	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-17	MAZAM	SO
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18	PHOTO	SMOKE
M1-19	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-19	MAZAM	SO
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20	PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21	PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22	PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23	ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24	PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25	ADRPUL	PULL
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26	PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27	ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28	PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29	PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30	PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31	MAZAM	WATER
M1-32	ZN1 LOWER LEVEL SOUTH-TAMPER SW	M1-32	MAZAM	SO
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33	MAZAM	WATER
M1-34	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-34	MAZAM	SO
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35	PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36	ADRPUL	PULL
M1-37	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-37	MAZAM	SO
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38	MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39	PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40	ADRPUL	PULL
M1-41	ZN3 LOWER LEVEL SO-SPKLR PRESS SW	M1-41	MAZAM	SO
M1-42	DRILL SWITCH DAYCARE CENTER GND FL	M1-42	GENIAM	UTILITY
M1-43	DRILL SWITCH MET SCHOOL 4TH FL SO.	M1-43	GENIAM	UTILITY

-----

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 56

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 160 L40

POINT LIST

256 Point List Pseudo

LIST No: 40

L40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
-----	-----	-----	-----
M1-44	REMOTE MICROPHONE ASTALK ON/OFF SW	M1-44 GENIAM	UTILITY
M1-45	ALL EMERGENCY EXIT DOORS UNLOCK	M1-45 GENIAM	UTILITY
M1-48	ZN 4 GROUND FLOOR SECURITY OFFICE	M1-48 PHOTO	SMOKE
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE

M2-3	2N4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL PULL
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL PULL
M2-41	GROUND FLR NORTH DOOR MON DR 104	M2-41 GENIAM UTILITY

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 57

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 -----  
 CARD No: 160 L40  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 40  
 L40

continued

Description: WALK TEST GROUP 0

Device Point



Point	Custom Point Label	Type	Type
M2-43	DOOR MONITOR STR B GRD FL N DR 113	M2-43 GENIAM	UTILITY
M2-45	DOOR MON NEAR REST RM GRD FL DR122	M2-45 GENIAM	UTILITY
M2-47	DOOR MON NEAR ELECTRIC ROOM DR 128	M2-47 GENIAM	UTILITY
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124 ADRPUL	PULL
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE
M3-1	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-1 ADRPUL	PULL
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4 PHOTO	SMOKE
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5 PHOTO	SMOKE
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6 PHOTO	SMOKE
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE
M3-10	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-10 ADRPUL	PULL
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11 PHOTO	SMOKE
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 58

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

CARD No: 160 L40  
POINT LIST  
256 Point List Pseudo  
LIST No: 40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25 ADRPUL	PULL
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26 ADRPUL	PULL
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-35	GROUND FLOOR DOOR MON DR 110	M3-35 GENIAM	UTILITY
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-114	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-114 ADRPUL	PULL
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M3-121	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-121 ADRPUL	PULL
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE

19-NOV-13

-----  
CARD No: 160 L40  
POINT LIST  
256 Point List Pseudo  
LIST No: 40  
L40

continued  
Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11 ADRPUL	PULL
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-119	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-119 ADRPUL	PULL
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 60

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L40

POINT LIST

256 Point List Pseudo

LIST No: 40

L40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY M4-127	ADRPUL	PULL
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-1	PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-2	PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-3	PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-4	PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-6	PHOTO	SMOKE
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-7	ADRPUL	PULL
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW M5-8	MAZAM	WATER
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-9	PHOTO	SMOKE
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-10	PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-11	PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-12	PHOTO	SMOKE
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-13	ADRPUL	PULL
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320 M5-14	PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-15	PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-16	PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-17	PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR M5-18	PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428 M5-107	PHOTO	SMOKE
M5-108	GENERATOR RUNNING M5-108	MAZAM	SUPERV
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-109	PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-110	PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-111	PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-112	PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-113	ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C M5-114	PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-115	PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-116	PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-117	PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-118	PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-119	PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D M5-120	PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW M5-121	MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-122	ADRPUL	PULL

M5-123	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-123	PHOTO	SMOKE
M5-124	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-124	PHOTO	SMOKE
M5-125	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-125	PHOTO	SMOKE
M5-126	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-126	PHOTO	SMOKE
M5-127	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE
M6-2	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-3	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-3	ADRPUL	PULL

-----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 61

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----

-----  
 CARD No: 160 L40

POINT LIST

256 Point List Pseudo

LIST No: 40

L40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
-----	-----	-----	-----
M6-5	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-5 ADRPUL	PULL
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6 PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7 PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8 PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9 PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10 PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11 PHOTO	SMOKE
M6-12	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-12 ADRPUL	PULL
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13 PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14 PHOTO	SMOKE
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE
M6-17	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-17 ADRPUL	PULL
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE
M6-20	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-20 ADRPUL	PULL
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21 PHOTO	SMOKE
M6-96	ZN13 COMPUTER ROOM FM 200 TROUBLE	M6-96 MAZAM	TROUBLE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97 PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100 ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102 MAZAM	HEAT
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106 HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE

M6-108	ZN13	SIXTH FL NORTH-FR ELEV LOBBY	M6-108	ADRPUL	PULL
M6-109	ZN13	SIXTH FLOOR NORTH-STAIR B	M6-109	PHOTO	SMOKE
M6-110	ZN13	SIXTH FLOOR NORTH-SPKLR FLOW	M6-110	MAZAM	WATER
M6-111	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-111	ADRPUL	PULL
M6-112	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-112	PHOTO	SMOKE
M6-113	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-113	PHOTO	SMOKE
M6-114	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-114	PHOTO	SMOKE
M6-115	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-115	PHOTO	SMOKE
M6-116	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-116	PHOTO	SMOKE
M6-117	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-117	PHOTO	SMOKE
M6-118	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-118	PHOTO	SMOKE
M6-119	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-119	HEAT	HEAT
M6-120	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-120	HEAT	HEAT
M6-121	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-121	HEAT	HEAT
M6-122	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-122	ADRPUL	PULL

-----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 62

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 CARD No: 160 L40  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 40  
 L40

continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE
M6-124	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124 MAZAM	FIRE

-----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 63

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

-----  
 CARD No: 160 L50  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 50  
 L50

continued

Description: WALK TEST GROUP 0 - SIGNALS/RELAYS

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 64

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L50

POINT LIST

## 256 Point List Pseudo

LIST No: 50

L50

continued

Description: WALK TEST GROUP 0 - SIGNALS/RELAYS

Point	Custom Point Label	Device Type	Point Type
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 65

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L72

POINT LIST

256 Point List Pseudo

LIST No: 72

L72

continued

Description: CONTROL POINTS ON - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RZAM	RELAY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RZAM	RELAY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RZAM	RELAY
M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY
M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RZAM	RELAY

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 66



9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
-----  
CARD No: 160 L73  
POINT LIST  
256 Point List Pseudo  
LIST No: 73  
L73

continued

Description: CONTROL POINTS OFF - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS M6-93	RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS M6-94	RZAM	CDAMPER

-----  
-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 67

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
-----  
CARD No: 160 L74  
POINT LIST  
256 Point List Pseudo  
LIST No: 74  
L74

continued

Description: CONTROL POINTS OFF - ON SILENCE

Point	Custom Point Label	Device Type	Point Type
0-7-3	Master Output - City Alarm relay		OUTPUT

-----  
-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 68

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
-----  
CARD No: 160 L76  
POINT LIST  
256 Point List Pseudo  
LIST No: 76  
L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO	SMOKE
M1-48	ZN 4 GROUND FLOOR SECURITY OFFICE	M1-48 PHOTO	SMOKE
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	ZN4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 69

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----  
CARD No: 160 L76  
POINT LIST  
256 Point List Pseudo  
LIST No: 76  
L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4 PHOTO	SMOKE
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5 PHOTO	SMOKE
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6 PHOTO	SMOKE
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11 PHOTO	SMOKE
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 70

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L76

POINT LIST

256 Point List Pseudo

LIST No: 76

L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE

M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8	PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9	PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10	PHOTO	SMOKE
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12	PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13	PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14	PHOTO	SMOKE

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 71

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L76  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 76  
 L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE
M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126 PHOTO	SMOKE
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10 PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11 PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12 PHOTO	SMOKE
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14 PHOTO	SMOKE

M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15	PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16	PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17	PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18	PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107	PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109	PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110	PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111	PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112	PHOTO	SMOKE
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114	PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115	PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116	PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117	PHOTO	SMOKE

-----  
 -----  
 SHEPARD'S BUILDING

POINT LIST DETAIL

Page 72

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

CARD No: 160 L76  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 76  
 L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label		Device Type	Point Type
-----	-----	-----	-----	-----
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118	PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119	PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120	PHOTO	SMOKE
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123	PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124	PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125	PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126	PHOTO	SMOKE
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE
M6-2	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6	PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7	PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8	PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9	PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10	PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11	PHOTO	SMOKE
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13	PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14	PHOTO	SMOKE
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15	PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16	PHOTO	SMOKE
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19	PHOTO	SMOKE
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21	PHOTO	SMOKE

M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97	PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98	PHOTO	SMOKE
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101	PHOTO	SMOKE
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105	PHOTO	SMOKE
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107	PHOTO	SMOKE
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109	PHOTO	SMOKE
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112	PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113	PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114	PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115	PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116	PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117	PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118	PHOTO	SMOKE
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123	PHOTO	SMOKE

-----

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 73

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----

-----

CARD No: 160 L80

POINT LIST

256 Point List Pseudo

LIST No: 80

L80

continued

Description: GENERAL FIRE ALARM SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

-----  
-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 74

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 160 L87

POINT LIST

256 Point List Pseudo

LIST No: 87

L87

continued

Description: AHU RELAYS ON - ON FIRE ALARM

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS M6-93	RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS M6-94	RZAM	CDAMPER

-----

-----  
-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 75

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 160 L89

POINT LIST

256 Point List Pseudo

LIST No: 89

L89

continued

Description: AHU RELAYS OFF - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS M6-93	RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS M6-94	RZAM	CDAMPER

-----

-----  
-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 76

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 160 L90



POINT LIST  
 256 Point List Pseudo  
 LIST No: 90  
 L90

continued  
 Description: ALL SPEAKERS - NON EDITABLE

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 77

9520019D node:1 rev:16  
 19-NOV-13

10:27:30, TUE,

CARD No: 160 L98

POINT LIST  
 256 Point List Pseudo  
 LIST No: 98  
 L98

continued  
 Description: SWITCH POWER SUPPLY AMPS TO BATTERY

Point	Custom Point Label	Device Type	Point Type
2-0-18	Amplifier Batteries		TROUBLE
10-0-18	Amplifier Batteries		TROUBLE
16-0-18	Amplifier Batteries		TROUBLE

21-0-18	Amplifier Batteries	TROUBLE
26-0-18	Amplifier Batteries	TROUBLE
31-0-18	Amplifier Batteries	TROUBLE

-----  
 -----  
 SHEPARD'S BUILDING                      POINT LIST DETAIL  
 Page 78  
 9520019D node:1 rev:16                      10:27:30, TUE,  
 19-NOV-13  
 -----  
 -----

CARD No: 160      L99  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 99  
 L99

continued  
 Description: SWITCH POWER SUPPLY AMPS TO BKGRND MUSIC

Point	Custom Point Label	Device Type	Point Type
2-0-19	Amplifier Background Music		TROUBLE
10-0-19	Amplifier Background Music		TROUBLE
16-0-19	Amplifier Background Music		TROUBLE
21-0-19	Amplifier Background Music		TROUBLE
26-0-19	Amplifier Background Music		TROUBLE
31-0-19	Amplifier Background Music		TROUBLE

-----  
 -----  
 SHEPARD'S BUILDING                      POINT LIST DETAIL  
 Page 79  
 9520019D node:1 rev:16                      10:27:30, TUE,  
 19-NOV-13  
 -----  
 -----

CARD No: 160      L101  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 101  
 L101

continued  
 Description: RESET POWER SUPPLY AMPS

Point	Custom Point Label	Device Type	Point Type
2-0-20	Amplifier Reset		TROUBLE
10-0-20	Amplifier Reset		TROUBLE
16-0-20	Amplifier Reset		TROUBLE
21-0-20	Amplifier Reset		TROUBLE

26-0-20	Amplifier Reset	TROUBLE
31-0-20	Amplifier Reset	TROUBLE

-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 80

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 160 L102

POINT LIST

256 Point List Pseudo

LIST No: 102

L102

continued

Description: LISTS TO AUTO-GENERATE EXTERNAL POINTS

Point	Custom Point Label	Device Type	Point Type
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)		CONTROL
L8	FIRE ALARM SIGNALS OFF ON SILENCE		CONTROL
L9	FIRE ALARM SIGNALS OFF ON RESET		EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE		EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET		CONTROL
L12	FIRE ALARM VISUALS OFF ON SILENCE		CONTROL
L13	FIRE ALARM VISUALS OFF ON RESET		EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET		EMPTY
L17	DOOR HOLDER CONTROL RELAYS		CONTROL
L18	GENERAL FIRE ALARM MONITOR ZONES		MIXED
L21	PRIMARY ELEVATOR CAPTURE RELAYS		CONTROL
L22	ALTERNATE ELEVATOR CAPTURE RELAYS		CONTROL
L24	WATERFLOW SIGNALS OFF ON SILENCE		EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET		EMPTY
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS		EMPTY
L78	ANALOG SENSORS WITH PIEZO		EMPTY
L79	ANALOG SENSORS WITH RELAY		EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS		CONTROL
L87	AHU RELAYS ON - ON FIRE ALARM		CONTROL
L88	AHU RELAYS OFF - ON FIRE ALARM		EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET		CONTROL
L93	PHONE CIRCUITS		EMPTY

-----

-----  
SHEPARD'S BUILDING

POINT LIST DETAIL

Page 81

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
CARD No: 160 L109

POINT LIST

## 256 Point List Pseudo

LIST No: 109

L109

continued

Description: ALARM SILENCED LED CONTROL

Point	Custom Point Label	Device Type	Point Type
P85	VTG 1 - ACTIVE		UTILITY
P221	SIGNALS ACTIVE - OFF ON SILENCE		UTILITY

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 82

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L128

POINT LIST

256 Point List Pseudo

LIST No: 128

L128

continued

Description: ALL EMERGENCY EXIT DOOR LOCKS

Point	Custom Point Label	Device Type	Point Type
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RZAM	RELAY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RZAM	RELAY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RZAM	RELAY
M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY
M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RZAM	RELAY

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 83

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L129

POINT LIST

256 Point List Pseudo

LIST No: 129

L129

continued

Description: GROUND FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT SIG15		SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT SIG33		SPEAKER

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL  
 Page 84  
 9520019D node:1 rev:16 10:27:30, TUE,  
 19-NOV-13  
 -----

-----  
 CARD No: 160 L130  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 130  
 L130

continued  
 Description: SECOND FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT SIG18		SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT SIG36		SPEAKER

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL  
 Page 85  
 9520019D node:1 rev:16 10:27:30, TUE,  
 19-NOV-13  
 -----

-----  
 CARD No: 160 L131  
 POINT LIST  
 256 Point List Pseudo  
 LIST No: 131  
 L131

continued  
 Description: THIRD FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT SIG45		SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 86

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L132

POINT LIST

256 Point List Pseudo

LIST No: 132

L132

continued

Description: FOURTH FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT SIG48		SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 87

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L133

POINT LIST

256 Point List Pseudo

LIST No: 133

L133

continued

Description: DAYCARE SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS SIG34		SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 88

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L134

POINT LIST

256 Point List Pseudo

LIST No: 134

L134

continued

Description: MET SCHOOL SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 89

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L135

POINT LIST

256 Point List Pseudo

LIST No: 135

L135

continued

Description: ALL STROBE CIRCUITS FOR BLDG DRILL

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL

SIG8	SPARE	SIG8	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 90

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 160 L136

POINT LIST

256 Point List Pseudo

LIST No: 136

L136

continued

Description: ALL SPEAKER CIRCUITS FOR ALL BLDG DRILL

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER

SHEPARD'S BUILDING

PANEL KEYS AND LEDS REPORT

Page 91



9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
CARD No: 0 SLOT No: 5  
LED/KEY  
(7003) 4100+ Master Controller  
MASTER SLOT  
Display Panel Control Keys/LEDs  
0-5

Pt	KEY Mode	Ref Addr	Ref Custom Label
Ref	Type		

1	TOF	P34	CITY DISCONNECT
TROUBLE			
2	TOF	P36	ELEVATOR BYPASS
TROUBLE			
3	TOF	P37	DOORHOLDER BYPASS
TROUBLE			
4	TOF	P256	FAN/DAMPER CONTROL BYPASS
TROUBLE			
5	TOF	P257	SIGNAL CIRCUITS BYPASS
TROUBLE			

Pt	LED Mode	Ref Addr	Ref Custom Label
Ref	Type		

6	ON	P34	CITY DISCONNECT
TROUBLE			
7	ON	P36	ELEVATOR BYPASS
TROUBLE			
8	ON	P37	DOORHOLDER BYPASS
TROUBLE			
9	ON	P256	FAN/DAMPER CONTROL BYPASS
TROUBLE			
10	ON	P257	SIGNAL CIRCUITS BYPASS
TROUBLE			

-----  
SHEPARD'S BUILDING REMOTE UNIT INTERFACE (RUI) REPORT

Page 92

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
CARD No: 8  
RUI  
(0304) Remote Unit Interface (RUI)  
CARD  
RUI Channel: 1  
8

Input Communication Rate : 9600 BAUD

Output Communication Rate : 9600 BAUD

Card No	Card Type	Unit
11	(0110) MAPNET Interface	Unit 1
12	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 1
13	(4011) 2 Ckt Class A Signal (IAC)	Unit 1
14	(4331) 3 Input Class A Signal	Unit 1
15	(4331) 3 Input Class A Signal	Unit 2
17	(0110) MAPNET Interface	Unit 2
18	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 2
20	(4331) 3 Input Class A Signal	Unit 3
22	(0110) MAPNET Interface	Unit 3
23	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 3
24	(4011) 2 Ckt Class A Signal (IAC)	Unit 3
25	(4331) 3 Input Class A Signal	Unit 4
27	(0110) MAPNET Interface	Unit 4
28	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 4
30	(4331) 3 Input Class A Signal	Unit 5
32	(0110) MAPNET Interface	Unit 5
33	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 5
34	(4011) 2 Ckt Class A Signal (IAC)	Unit 5
10	(6005) Power Supply/Charger (Audio)	Unit 1
16	(6005) Power Supply/Charger (Audio)	Unit 2
21	(6005) Power Supply/Charger (Audio)	Unit 3
26	(6005) Power Supply/Charger (Audio)	Unit 4
31	(6005) Power Supply/Charger (Audio)	Unit 5
19	(4031) 6 Ckt Class A Signal (IAC)	Unit 2
29	(4031) 6 Ckt Class A Signal (IAC)	Unit 4
36	(0304) Remote Unit Interface (RUI)	Unit 4
37	(4603-9101) LCD Annunciator	Unit 6

SHEPARD'S BUILDING REMOTE UNIT INTERFACE (RUI) REPORT

Page 93

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CARD No: 36

RUI

(0304) Remote Unit Interface (RUI)

CARD

RUI Channel: 2

36

Input Communication Rate : 9600 BAUD

Output Communication Rate : 9600 BAUD

Card No	Card Type	Unit
	no remote annunciators	

-----  
SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 94

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----

-----  
UNIT No: 0

UNIT 0

CARD No: 0 (base)

0-4

64 LED / 64 Sw Controller

CONTROL PANEL LED/SWITCH

ANNUNCIATOR 0

UNIT COMPOSITION:

Card No	Card Type	Display Card
Point Usage		
-----	-----	-----
0	64 LED / 64 Sw Controller	0 LEDs / 0
SWs		
5	(0301) 64 LED / 64 Sw Controller	40 LEDs / 32
SWs		
1	(0113) 2120/RS232 Interface	N/A
2	(6005) Power Supply/Charger	N/A
3	(4331) 3 Input Class A Signal	N/A
4	(3002) 4 Pt, 10 Amp Relay w/ Feedback	N/A
7	(0110) MAPNET Interface	N/A
8	(0304) Remote Unit Interface (RUI)	N/A
9	(4011) 2 Ckt Class A Signal (IAC)	N/A
35	(3003) 8 Pt, 3 Amp Relay w/ Feedback	N/A

NOTE: Card 0, Annun 0 = Master Controller slot 4

CONTROLLER CARD CONFIGURATION DETAIL:

Controller	Display Card	Display Card Type
Card No		
-----	-----	-----
0		no display cards assigned
5	1	0403 - 8 Momen Sw/8 Red LED
	2	L404 - 8 Maint Sw/16 Red-Grn LED
	3	0204 - Microphone Enclosure
	4	0204 - Microphone Enclosure
	5	0412 - 1 Channel Audio Control
Module	6	0409 - Blank Display Card
	7	0409 - Blank Display Card
	8	L403 - 8 Momen Sw/8 Red LED

-----

-----  
SHEPARD'S BUILDING                      UNIT DETAIL REPORT  
Page 95  
9520019D node:1 rev:16                      10:27:30, TUE,  
19-NOV-13  
-----

-----  
UNIT No: 0  
UNIT 0  
CARD No: 0 (base)  
DISPLAY 9  
64 LED / 64 Sw Controller  
0-4

DISPLAY CARD DETAIL:

NO DISPLAY CARDS ASSIGNED

-----  
SHEPARD'S BUILDING                      UNIT DETAIL REPORT  
Page 96  
9520019D node:1 rev:16                      10:27:30, TUE,  
19-NOV-13  
-----

-----  
UNIT No: 0  
UNIT 0  
CARD No: 5  
DISPLAY 1  
(0301) 64 LED / 64 Sw Controller  
5

DISPLAY CARD DETAIL:

DISPLAY CARD: 1      0403 - 8 Momen Sw/8 Red LED

LED Range 1 - 8      Switch Range 65 - 72.

Pt	Mode	Ref Addr	Ref Custom Label
Ref Type			
1	SP1	SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT SIG72
SPEAKER			
2	SP1	SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT SIG69
SPEAKER			
3	SP1	L132	FOURTH FLOOR SPEAKER CIRCUITS
CONTROL			
4	SP1	L131	THIRD FLOOR SPEAKER CIRCUITS
CONTROL			
5	SP1	L130	SECOND FLOOR SPEAKER CIRCUITS

CONTROL  
6 SP1 L129 GROUND FLOOR SPEAKER CIRCUITS  
CONTROL  
7 SP1 SIG9 LOWER LEVEL SPEAKER CIRCUIT SIG9  
SPEAKER  
8 ASTALK

-----  
-----  
SHEPARD'S BUILDING UNIT DETAIL REPORT  
Page 97  
9520019D node:1 rev:16 10:27:30, TUE,  
19-NOV-13  
-----

-----  
UNIT No: 0  
UNIT 0  
CARD No: 5  
DISPLAY 2  
(0301) 64 LED / 64 Sw Controller  
5

DISPLAY CARD DETAIL:

DISPLAY CARD: 2 L404 - 8 Maint Sw/16 Red-Grn LED

Pt	SW	Mode	Ref Addr	Ref Custom Label
Ref Type				

73	SMPL			
74	SMPL			
75	SMPL			
76	SMPL			
77	SMPL			
78	SMPL			
79	SMPL			
80	SMPL			

Pt	LED Mode	Ref Addr	Ref Custom Label
Ref Type			

9	SMPL		
10	SMPL		
11	SMPL		
12	SMPL		
13	SMPL		
14	SMPL		
15	SMPL		
16	SMPL		

Pt	LED Mode	Ref Addr	Ref Custom Label
Ref Type			

17 SMPL  
18 SMPL  
19 SMPL  
20 SMPL  
21 SMPL  
22 SMPL  
23 SMPL  
24 SMPL

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 98

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 0

UNIT 0

CARD No: 5

DISPLAY 5

(0301) 64 LED / 64 Sw Controller

5

DISPLAY CARD DETAIL:

DISPLAY CARD: 5 0412 - 1 Channel Audio Control Module

LED Range 25 - 32 Switch Range 81 - 88.

Pt	Mode	Ref Addr	Ref Custom Label
Ref	Type		

1	ASEVAC		
2	AEVAC		
3	ASTALK		
4			
5			
6			
7			
8	A1LOCAL		

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 99

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 0

UNIT 0  
CARD No: 5  
DISPLAY 8  
(0301) 64 LED / 64 Sw Controller  
5

DISPLAY CARD DETAIL:

DISPLAY CARD: 8 L403 - 8 Momen Sw/8 Red LED

Pt	SW	Mode	Ref Addr	Ref Custom Label
Ref	Type			
89	ONOFF		M2-40	GROUND FLR NORTH DOOR LOCK DR 104 M2-40
RELAY				
90	ONOFF		M3-34	GROUND FLOOR DOOR LOCK DR 110 M3-34
RELAY				
91	ONOFF		M2-42	GROUND FLR NORTH DOOR LOCK DR 113 M2-42
RELAY				
92	ONOFF		M2-44	GROUND FLR NORTH DOOR LOCK DR 122 M2-44
RELAY				
93	ONOFF		M2-46	GROUND FLR NORTH DOOR LOCK DR 128 M2-46
RELAY				
94	SMPL			
95	SMPL			
96	SMPL			

Pt	LED	Mode	Ref Addr	Ref Custom Label
Ref	Type			
33	ON		M2-40	GROUND FLR NORTH DOOR LOCK DR 104 M2-40
RELAY				
34	ON		M3-34	GROUND FLOOR DOOR LOCK DR 110 M3-34
RELAY				
35	ON		M2-42	GROUND FLR NORTH DOOR LOCK DR 113 M2-42
RELAY				
36	ON		M2-44	GROUND FLR NORTH DOOR LOCK DR 122 M2-44
RELAY				
37	ON		M2-46	GROUND FLR NORTH DOOR LOCK DR 128 M2-46
RELAY				
38	SMPL			
39	SMPL			
40	SMPL			

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 100

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 1  
UNIT 1

I/O Unit 1  
UNIT COMPOSITION:

Card No	Card Type
10	(6005) Power Supply/Charger (Audio)
11	(0110) MAPNET Interface
12	(3002) 4 Pt, 10 Amp Relay w/ Feedback
13	(4011) 2 Ckt Class A Signal (IAC)
14	(4331) 3 Input Class A Signal

SHEPARD'S BUILDING UNIT DETAIL REPORT

Page 101

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 2  
UNIT 2

I/O Unit 2  
UNIT COMPOSITION:

Card No	Card Type
15	(4331) 3 Input Class A Signal
16	(6005) Power Supply/Charger (Audio)
17	(0110) MAPNET Interface
18	(3002) 4 Pt, 10 Amp Relay w/ Feedback
19	(4031) 6 Ckt Class A Signal (IAC)

SHEPARD'S BUILDING UNIT DETAIL REPORT

Page 102

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 3  
UNIT 3

I/O Unit 3



UNIT COMPOSITION:

Card No	Card Type
---------	-----------

20	(4331) 3 Input Class A Signal
21	(6005) Power Supply/Charger (Audio)
22	(0110) MAPNET Interface
23	(3002) 4 Pt, 10 Amp Relay w/ Feedback
24	(4011) 2 Ckt Class A Signal (IAC)

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 103

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

UNIT No: 4

UNIT 4

I/O Unit 4

UNIT COMPOSITION:

Card No	Card Type
---------	-----------

25	(4331) 3 Input Class A Signal
26	(6005) Power Supply/Charger (Audio)
27	(0110) MAPNET Interface
28	(3002) 4 Pt, 10 Amp Relay w/ Feedback
29	(4031) 6 Ckt Class A Signal (IAC)
36	(0304) Remote Unit Interface (RUI)

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 104

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

UNIT No: 5

UNIT 5

I/O Unit 5

UNIT COMPOSITION:

Card No	Card Type
---------	-----------

30	(4331) 3 Input Class A Signal
31	(6005) Power Supply/Charger (Audio)

32 (0110) MAPNET Interface  
33 (3002) 4 Pt, 10 Amp Relay w/ Feedback  
34 (4011) 2 Ckt Class A Signal (IAC)

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 105

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 6

UNIT 6

CARD No: 37 (base)

37

(4603-9101) LCD Annunciator

REMOTE LCD

ANNUNCIATOR 6

UNIT COMPOSITION:

Card No Card Type

37 (4603-9101) LCD Annunciator

SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 106

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

UNIT No: 6

UNIT 6

CARD No: 37 (base)

37

(4603-9101) LCD Annunciator

CARD DETAIL:

UNIT No: 6

CARD No: 37

(4603-9101) LCD

Annunciator

POINT Address

Default Label

1	LCD - Programmable Control KEY 1
2	LCD - Programmable Control KEY 2
3	LCD - Programmable Control KEY 3
4	LCD - Programmable Control KEY 4
5	LCD - Programmable Control LED 1
6	LCD - Programmable Control LED 2
7	LCD - Programmable Control LED 3

8	LCD - Programmable Control LED 4
9	LCD - FIRE ALARM ACKnowledge Key
10	LCD - SUPERVISORY ACKnowledge Key
11	LCD - TROUBLE ACKnowledge Key
12	LCD - KEY SWITCH
13	LCD - ALARM SILENCE Key
14	LCD - SYSTEM RESET Key
15	LCD - DISPLAY TIME Key
16	LCD - FIRE ALARM LED
17	LCD - SUPERVISORY SERVICE LED
18	LCD - TROUBLE LED
19	LCD - ALARM SILENCED LED
20	LCD - PIEZO

-----  
 SHEPARD'S BUILDING

UNIT DETAIL REPORT

Page 107

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----

UNIT No: 6

UNIT 6

CARD No: 37 (base)

37

(4603-9101) LCD Annunciator

Display Panel CONTROL KEYS/LEDs

Pt	KEY Mode	Ref Addr	Ref Custom Label
----	----------	----------	------------------

Ref Type

1	SMPL		
2	SMPL		
3	SMPL		
4	SMPL		

Pt	LED Mode	Ref Addr	Ref Custom Label
----	----------	----------	------------------

Ref Type

5	SMPL		
6	SMPL		
7	SMPL		
8	SMPL		

-----  
 SHEPARD'S BUILDING

2120/RS232 INTERFACE REPORT

Page 108

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

-----  
-----  
CARD No: 1 2120/RS232  
INTERFACE  
(0113) 2120/RS232 Interface  
CARD

1

PORT	TYPE	BAUD	PARITY	DATA BITS	STOP BITS
A	UNUSED	----	----	0	0
B	UNUSED	----	----	0	0

-----  
-----  
SHEPARD'S BUILDING AUDIO CONFIGURATION REPORT  
Page 109  
9520019D node:1 rev:16 10:27:30, TUE,  
19-NOV-13  
-----  
-----

#### AUDIO

(0210) Audio Controller Card No.: 6  
Number of channels - 1  
Message Memory Board - YES  
Chipset - 87 TONES, WALK TEST, & BOSTON EVAC

Card Inputs	Used
-----	----
Master Microphone	YES
Remote Microphone 1	YES
Remote Microphone 2	NO
Fire Fighters Phone	NO
Network Input	NO
Backup VTG	NO

-----  
-----  
SHEPARD'S BUILDING OPTIONS DETAIL REPORT  
Page 110  
9520019D node:1 rev:16 10:27:30, TUE,  
19-NOV-13  
-----  
-----

#### OPTIONS

##### STANDARD

Elevator Recall Operation:  
List Description

Point Total

L19	PRIMARY ELEVATOR RECALL MONITOR ZONES	201
L20	ALTERNATE ELEVATOR RECALL MONITOR ZONES	75
L21	PRIMARY ELEVATOR CAPTURE RELAYS	2
L22	ALTERNATE ELEVATOR CAPTURE RELAYS	2

Door Holder Operation:

Drop On Alarm Delay after 0 seconds.

Drop on AC Power Loss after 0 minutes, 35 seconds.

List	Description	Point Total
L17	DOOR HOLDER CONTROL RELAYS	14

SHEPARD'S BUILDING

OPTIONS DETAIL REPORT

Page 111

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

OPTIONS

EXPANDED

Audio Operation:

VTG1 Chip Set S87 TONES, WALK TEST, & BOSTON EVAC

MSG	CHL	MSG#	Description
Evac.	1	1	SLOW WHOOP FOREVER
Alert	1	8	MARCH TIME - 60 BPM - CHIME - FOREVER
Drill	1	73	STANDARD DRILL MESSAGE
Clear	1	100	CUSTOM ALL CLEAR MESSAGE
Aux1	1	0	NO MESSAGE DEFINED
Aux2	1	0	NO MESSAGE DEFINED
Microphone Pretone		0	NO MESSAGE DEFINED
MSG After Mike VTG1		1	SLOW WHOOP FOREVER
MSG After Mike VTG2		8	MARCH TIME - 60 BPM - CHIME - FOREVER

Pre-Programmed User Lists: YES

List	List Description	Point
Total		
L38	4 WIRE MONITOR ZONES	EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM	EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM	EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET	5
L73	CONTROL POINTS OFF - ON SYSTEM RESET	2
L74	CONTROL POINTS OFF - ON SILENCE	1
L83	AUX1 MESSAGE SPEAKERS	EMPTY

L84	AUX2 MESSAGE SPEAKERS	EMPTY
L85	RESTART MESSAGE AFTER MIKE - VTG 1	EMPTY
L86	RESTART MESSAGE AFTER MIKE - VTG 2	EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF	EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT	EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH	EMPTY
L100	POINTS TO EXCLUDE FROM AUTOMAP	EMPTY
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS	22
L103	EXTERNAL DETECTOR RESET PSEUDO	EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO	EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO	EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO	EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE	EMPTY
L109	ALARM SILENCED LED CONTROL	2
L112	EXTERNAL PRIORITY 2 RESET PSEUDOS	EMPTY
L110	INHIBIT NETWORK LABEL UPDATE	EMPTY

-----  
 -----  
 SHEPARD'S BUILDING

OPTIONS DETAIL REPORT

Page 112

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
 -----  
 -----

OPTIONS

PASSCODES

Display Function	Protection Level
-----	-----
Alarm Silence	1
System Reset	1
Change Time and Date	2
Panel Control Key 1	2
Panel Control Key 2	2
Panel Control Key 3	2
Panel Control Key 4	2
Panel Control Key 5	2
ON/OFF/AUTO Keys	2
ARM/DISARM Keys	2
Change TrueAlarm Sensitivities	3
DISABLE/ENABLE Keys	3
Clear Trouble Log	3
Clear Alarm Log	3
Enter/exit Walk Test mode	3
Clear Alarm Verification tallies	3
Chg Analog Monitor ZAM Alarm Thresholds	3
Analog Monitor ZAM Calibration Recording	3
* Fire Alarm Acknowledge	1
* Priority 2 Acknowledge	1
* Supervisory Acknowledge	1
* Trouble Acknowledge	1
* Alarm List/Display Time	1
* Change Point Status	4

* Run Diagnostics	4
* Display Diagnostics	2
* Remote Download	4
* Display Idle Time	4
* Memory Access	4

NOTE: \* Indicates protected functions not on order sheet.

## PROTECTION SCALE

Level 1 - Lo

Level 4 - Hi

```

-----
-----
SHEPARD'S BUILDING          OPTIONS DETAIL REPORT
Page 113
9520019D node:1 rev:16      10:27:30, TUE,
19-NOV-13
-----
-----

```

## CUSTOM CONTROL

### EQU SUMMARY

Program: 0  
Program: 0

Equation No.	Label	
L110	INHIBIT NETWORK LABEL UPDATE	EMPTY

```

-----
-----
SHEPARD'S BUILDING          NETWORK INTERFACE REPORT
Page 114
9520019D node:1 rev:16      10:27:30, TUE,
19-NOV-13
-----
-----

```

NO NETWORK CONFIGURED FOR THIS JOB.

```

-----
-----
SHEPARD'S BUILDING          VIRTUAL NACS REPORT
Page 115
9520019D node:1 rev:16      10:27:30, TUE,
19-NOV-13
-----
-----

```





## EQU DETAIL

Program: 3

Program: 3

Label: Hold Emergency Door Locks on-Sys Startup

Equation 1

COMMENTS:

INPUTS:

The ON state of:

A34	TIMER	SYSTEM STARTUP PULSE TIMER
-----	-------	----------------------------

OUTPUTS:

HOLD points ON pri=9,9

M2-40	RELAY	GROUND FLR NORTH DOOR LOCK DR 104
M2-40		
M2-42	RELAY	GROUND FLR NORTH DOOR LOCK DR 113
M2-42		
M2-44	RELAY	GROUND FLR NORTH DOOR LOCK DR 122
M2-44		
M2-46	RELAY	GROUND FLR NORTH DOOR LOCK DR 128
M2-46		
M3-34	RELAY	GROUND FLOOR DOOR LOCK DR 110
M3-34		

END:

Label: Alarm at Door#104-Turn on Aux27 & Aux34

Equation 2

COMMENTS:

INPUTS:

The ON state of:

M2-41	UTILITY	GROUND FLR NORTH DOOR MON DR 104
M2-41		

OUTPUTS:

TRACK points ON pri=9,9

AUX27	RELAY	DOOR 104 MONITORS M2-41 IAM-ANN LT
AUX27		
AUX34	RELAY	DOOR ALARM ANNUNCIATOR PIEZO
AUX34		

END:

Label: Alarm at Door#110-Turn on Aux28 & Aux34

Equation 3

COMMENTS:

INPUTS:

The ON state of:

M3-35	UTILITY	GROUND FLOOR DOOR MON DR 110
M3-35		

OUTPUTS:

TRACK points ON pri=9,9

AUX28	RELAY	DOOR 110 MONITORS M3-35 IAM-ANN LT
AUX28		
AUX34	RELAY	DOOR ALARM ANNUNCIATOR PIEZO
AUX34		

END:

Label: Alarm at Door#113-Turn on Aux29 & Aux34  
Equation 4

COMMENTS:

INPUTS:

The ON state of:

M2-43                      UTILITY                      DOOR MONITOR STR B GRD FL N DR 113  
M2-43

OUTPUTS:

-----  
-----  
SHEPARD'S BUILDING                      CUSTOM CONTROL EQUATION LISTING

Page 118

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CUSTOM CONTROL

EQU DETAIL

Program: 3

Program: 3

TRACK points ON pri=9,9

AUX29                      RELAY                      DOOR 113 MONITORS M2-43 IAM-ANN LT

AUX29

AUX34                      RELAY

DOOR ALARM ANNUNCIATOR PIEZO

AUX34

END:

Label: Alarm at Door#122-Turn on Aux30 & Aux34  
Equation 5

COMMENTS:

INPUTS:

The ON state of:

M2-45                      UTILITY                      DOOR MON NEAR REST RM GRD FL DR122  
M2-45

OUTPUTS:

TRACK points ON pri=9,9

AUX30                      RELAY                      DOOR 122 MONITORS M2-45 IAM-ANN LT

AUX30

AUX34                      RELAY

DOOR ALARM ANNUNCIATOR PIEZO

AUX34

END:

Label: Alarm at Door#128-Turn on Aux31 & Aux34  
Equation 6

COMMENTS:

INPUTS:

The ON state of:

M2-47                      UTILITY                      DOOR MON NEAR ELECTRIC ROOM DR 128  
M2-47  
OUTPUTS:  
TRACK points ON pri=9,9  
AUX31                      RELAY                      DOOR 128 MONITORS M2-47 IAM-ANN LT  
AUX31  
AUX34                      RELAY                      DOOR ALARM ANNUNCIATOR PIEZO  
AUX34  
END:

Label: Trouble any Door lock-Turn on Aux33  
Equation 7

COMMENTS:  
INPUTS:  
The TROUBLE state of:  
L128                      CONTROL                      ALL EMERGENCY EXIT DOOR LOCKS  
OUTPUTS:  
TRACK points ON pri=9,9  
AUX33                      RELAY                      DOOR ALARM TROUBLE-ANN LT & PIEZO  
AUX33  
END:

Label: General Alarm-Release all Emerg Door Lks  
Equation 8

COMMENTS:  
INPUTS:  
The DETECT state of:  
L18                      MIXED                      GENERAL FIRE ALARM MONITOR ZONES  
OR the ON state of:

-----  
-----  
SHEPARD'S BUILDING                      CUSTOM CONTROL EQUATION LISTING  
Page 119  
9520019D node:1 rev:16                      10:27:30, TUE,  
19-NOV-13  
-----  
-----

CUSTOM CONTROL

EQU DETAIL

Program: 3  
Program: 3

M1-45                      UTILITY                      ALL EMERGENCY EXIT DOORS UNLOCK  
M1-45  
OUTPUTS:  
HOLD points OFF pri=9,9  
L128                      CONTROL                      ALL EMERGENCY EXIT DOOR LOCKS  
END:

Label: Relock Emergency Doors-Keyswitch Off  
Equation 9

COMMENTS:

INPUTS:

NOT the ON state of:

M1-45 UTILITY

ALL EMERGENCY EXIT DOORS UNLOCK

M1-45

OUTPUTS:

HOLD points ON pri=9,9

L128 CONTROL

ALL EMERGENCY EXIT DOOR LOCKS

END:

Label: [END-OF-PROGRAM]

Equation 10

-----  
-----  
SHEPARD'S BUILDING

CUSTOM CONTROL EQUATION SUMMARY

Page 120

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CUSTOM CONTROL

EQU SUMMARY

Program: 4

Program: 4

Equation No.

Label

-----  
1 Alm Pass.Elev Shaft/Mach RM-Dmp M6-93 on  
2 Alm Frgt.Elev.Shaft/Mach Rm-Dmp M6-94 on  
3 [END-OF-PROGRAM]  
-----

-----  
-----  
SHEPARD'S BUILDING

CUSTOM CONTROL EQUATION LISTING

Page 121

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CUSTOM CONTROL

EQU DETAIL

Program: 4

Program: 4

Label: Alm Pass.Elev Shaft/Mach RM-Dmp M6-93 on

Equation 1

COMMENTS:

INPUTS:

OR DETect the points:

M6-98	SMOKE	ZN15 PASSENGER ELEV PENTHOUSE
M6-99	PULL	ZN15 PASSENGER ELEV PENTHOUSE
M6-119	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT
M6-120	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT
M6-121	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT

OUTPUTS:

HOLD points ON pri=9,9

M6-93	CDAMPER	PASSNGR ELEV DAMPER CONTROL STATUS
-------	---------	------------------------------------

END:

Label: Alm Frgt.Elev.Shaft/Mach Rm-Dmp M6-94 on  
Equation 2

COMMENTS:

INPUTS:

OR DETect the points:

M6-100	PULL	ZN15 FREIGHT ELEVATOR PENTHOUSE
M6-101	SMOKE	ZN15 FREIGHT ELEVATOR PENTHOUSE
M6-102	HEAT	ZN15 FREIGHT ELEV PENTHOUSE REAR
M6-106	HEAT	ZN15 TOP OF FREIGHT ELEV SHAFT

OUTPUTS:

HOLD points ON pri=9,9

M6-94	CDAMPER	FREIGHT ELEV DAMPER CONTROL STATUS
-------	---------	------------------------------------

END:

Label: [END-OF-PROGRAM]  
Equation 3

-----  
SHEPARD'S BUILDING                      CUSTOM CONTROL EQUATION SUMMARY  
Page 122

9520019D node:1 rev:16  
19-NOV-13

10:27:30, TUE,

-----  
CUSTOM CONTROL

EQU SUMMARY

Program: 5

Program: 5

Equation No.	Label
1	Speaker and Strobe Circuit Bypass on Alm
2	Fan/Damper/Gas Control Bypass on Alarm
3	Remote Microphone Operation-Switch On
4	Remote Microphone Operation-Switch Off
5	city trip
6	[END-OF-PROGRAM]

SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING  
Page 123  
9520019D node:1 rev:16 10:27:30, TUE,  
19-NOV-13

CUSTOM CONTROL

EQU DETAIL

Program: 5

Program: 5

Label: Speaker and Strobe Circuit Bypass on Alm  
Equation 1

COMMENTS:

INPUTS:

The DETECT state of:

L18 MIXED

GENERAL FIRE ALARM MONITOR ZONES

AND the ON state of:

P257 TROUBLE

SIGNAL CIRCUITS BYPASS

OUTPUTS:

HOLD points OFF pri=7,9

SIG3 SSIGNAL

LOWER LEVEL STROBE CIRCUIT

SIG3

SIG4 SSIGNAL

LOWER LEVEL STROBE CIRCUIT

SIG4

SIG5 SSIGNAL

SPARE

SIG5

SIG6 SSIGNAL

SPARE

SIG6

SIG7 SSIGNAL

SPARE

SIG7

SIG8 SSIGNAL

SPARE

SIG8

SIG9 SPEAKER

LOWER LEVEL SPEAKER CIRCUIT

SIG9

SIG10 SIGNAL

\*\*\* SIGNAL CIRCUIT NOT AVAILABLE

\*\*\*

SIG11 SIGNAL

\*\*\* SIGNAL CIRCUIT NOT AVAILABLE

\*\*\*

	SIG12	SPEAKER	SPARE
SIG12			
	SIG13	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG14	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG15	SPEAKER	GROUND FLOOR NORTH SPEAKER CIRCUIT
SIG15			
	SIG16	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG17	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG18	SPEAKER	SECOND FLOOR NORTH SPEAKER CIRCUIT
SIG18			
	SIG19	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG20	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG21	SSIGNAL	GROUND FLOOR NORTH STROBE CIRCUIT
SIG21			
	SIG22	SSIGNAL	GROUND FLOOR NORTH STROBE CIRCUIT
SIG22			
	SIG23	SSIGNAL	SECOND FLOOR NORTH STROBE CIRCUIT
SIG23			
	SIG24	SSIGNAL	SECOND FLOOR NORTH STROBE CIRCUIT
SIG24			
	SIG25	SSIGNAL	SPARE
SIG25			
	SIG26	SSIGNAL	SPARE
SIG26			
	SIG27	SSIGNAL	GROUND FLOOR SOUTH STROBE CIRCUIT
SIG27			
	SIG28	SSIGNAL	GROUND FLOOR SOUTH STROBE CIRCUIT
SIG28			
	SIG29	SSIGNAL	SECOND FLOOR SOUTH STROBE CIRCUIT
SIG29			
	SIG30	SSIGNAL	SECOND FLOOR SOUTH STROBE CIRCUIT
SIG30			
	SIG31	SVISUAL	GND FLR DAYCARE STROBE CIRCUIT
SIG31			
	SIG32	SSIGNAL	SIGNAL CIRCUIT
SIG32			
	SIG33	SPEAKER	GROUND FLOOR SOUTH SPEAKER CIRCUIT
SIG33			
	SIG34	SPEAKER	GROUND FLR DAYCARE CENTER SPEAKERS
SIG34			
	SIG35	SPEAKER	SIGNAL CARD 19 CIRCUIT
SIG35			
	SIG36	SPEAKER	SECOND FLOOR SOUTH SPEAKER CIRCUIT
SIG36			
	SIG37	SPEAKER	SIGNAL CARD 19 CIRCUIT
SIG37			
	SIG38	SPEAKER	SIGNAL CARD 19 CIRCUIT
SIG38			

-----  
-----

-----  
-----  
CUSTOM CONTROL

## EQU DETAIL

Program: 5

Program: 5

	SIG39	SSIGNAL	THIRD FLOOR NORTH STROBE CIRCUIT
SIG39			
	SIG40	SSIGNAL	THIRD FLOOR NORTH STROBE CIRCUIT
SIG40			
	SIG41	SSIGNAL	FOURTH FLOOR NORTH STROBE CIRCUIT
SIG41			
	SIG42	SSIGNAL	FOURTH FLOOR NORTH STROBE CIRCUIT
SIG42			
	SIG43	SSIGNAL	SPARE
SIG43			
	SIG44	SSIGNAL	SPARE
SIG44			
	SIG45	SPEAKER	THIRD FLOOR NORTH SPEAKER CIRCUIT
SIG45			
***	SIG46	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
***	SIG47	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG48	SPEAKER	FOURTH FLOOR NORTH SPEAKER CIRCUIT
SIG48			
***	SIG49	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
***	SIG50	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG51	SSIGNAL	THIRD FLOOR SOUTH STROBE CIRCUIT
SIG51			
	SIG52	SSIGNAL	THIRD FLOOR SOUTH STROBE CIRCUIT
SIG52			
	SIG53	SSIGNAL	FOURTH FLOOR MET SCHOOL STROBES
SIG53			
	SIG54	SSIGNAL	FOURTH FLOOR SOUTH STROBE CIRCUIT
SIG54			
	SIG55	SSIGNAL	SPARE
SIG55			
	SIG56	SSIGNAL	SPARE
SIG56			
	SIG57	SPEAKER	THIRD FLOOR SOUTH SPEAKER CIRCUIT
SIG57			
	SIG58	SPEAKER	FOURTH FLOOR MET SCHOOL SPEAKERS
SIG58			
	SIG59	SPEAKER	SIGNAL CARD 29 CIRCUIT
SIG59			
	SIG60	SPEAKER	FOURTH FLOOR SOUTH SPEAKER CIRCUIT



SIG60			
	SIG61	SPEAKER	SIGNAL CARD 29 CIRCUIT
SIG61			
	SIG62	SPEAKER	SIGNAL CARD 29 CIRCUIT
SIG62			
	SIG63	SSIGNAL	FIFTH FLOOR NORTH STROBE CIRCUIT
SIG63			
	SIG64	SSIGNAL	FIFTH FLOOR NORTH STROBE CIRCUIT
SIG64			
	SIG65	SSIGNAL	SIXTH FLOOR NORTH STROBE CIRCUIT
SIG65			
	SIG66	SSIGNAL	SIXTH FLOOR NORTH STROBE CIRCUIT
SIG66			
	SIG67	SSIGNAL	SPARE
SIG67			
	SIG68	SSIGNAL	SPARE
SIG68			
	SIG69	SPEAKER	FIFTH FLOOR NORTH SPEAKER CIRCUIT
SIG69			
	SIG70	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG71	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG72	SPEAKER	SIXTH FLOOR NORTH SPEAKER CIRCUIT
SIG72			
	SIG73	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			
	SIG74	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE
***			

END:

Label: Fan/Damper/Gas Control Bypass on Alarm  
Equation 2

COMMENTS:

INPUTS:

The ON state of:

P256 TROUBLE

FAN/DAMPER CONTROL BYPASS

OUTPUTS:

HOLD points OFF pri=7,9

M6-93 CDAMPER

PASSNGR ELEV DAMPER CONTROL STATUS

M6-93

SHEPARD'S BUILDING

CUSTOM CONTROL EQUATION LISTING

Page 125

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CUSTOM CONTROL

EQU DETAIL

Program: 5

Program: 5

M6-94	M6-94	CDAMPER	FREIGHT ELEV DAMPER CONTROL STATUS
AUX21	AUX21	RRELAY	GAS VALVE SHUTDOWN

END:

Label: Remote Microphone Operation-Switch On  
Equation 3

COMMENTS:

INPUTS:

The ON state of:

M1-44	M1-44	UTILITY	REMOTE MICROPHONE ASTALK ON/OFF SW
-------	-------	---------	------------------------------------

M1-44

OUTPUTS:

TRACK points ON pri=9,9

P114	P114	UTILITY	ALL SPEAKERS CHANNEL 1 ON
------	------	---------	---------------------------

END:

Label: Remote Microphone Operation-Switch Off  
Equation 4

COMMENTS:

INPUTS:

NOT the ON state of:

M1-44	M1-44	UTILITY	REMOTE MICROPHONE ASTALK ON/OFF SW
-------	-------	---------	------------------------------------

M1-44

OUTPUTS:

TRACK points ON pri=9,9

P115	P115	UTILITY	ALL SPEAKERS CHANNEL 1 OFF
------	------	---------	----------------------------

END:

Label: city trip  
Equation 5

COMMENTS:

INPUTS:

The ON state of:

P11	P11	UTILITY	UNACKNOWLEDGED FIRE ALARM EXISTS
-----	-----	---------	----------------------------------

AND NOT the ON state of:

P34	P34	TROUBLE	CITY DISCONNECT
-----	-----	---------	-----------------

OUTPUTS:

HOLD points ON pri=9,9

0-7-3	0-7-3	OUTPUT	Master Output - City Alarm relay
-------	-------	--------	----------------------------------

END:

Label: [END-OF-PROGRAM]  
Equation 6

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION SUMMARY

Page 126

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CUSTOM CONTROL

EQU SUMMARY

Program: 6

Program: 6

Equation No.	Label
1	Daycare Drill Switch On-Spkr/Strbes On
2	Daycare Drill Switch Off-Spkr/Strbes Off
3	All Bldg Drill Sw On-Spkr/Strbes On
4	All Bldg Drill Sw Off-Spkr/Strbes Off
5	[END-OF-PROGRAM]

SHEPARD'S BUILDING

CUSTOM CONTROL EQUATION LISTING

Page 127

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13

CUSTOM CONTROL

EQU DETAIL

Program: 6

Program: 6

Label: Daycare Drill Switch On-Spkr/Strbes On

Equation 1

COMMENTS:

INPUTS:

The ON state of:

M1-42 UTILITY DRILL SWITCH DAYCARE CENTER GND FL  
M1-42

AND NOT the ON state of:

P257 TROUBLE SIGNAL CIRCUITS BYPASS

OUTPUTS:

MARCH TIME G0; L12; on=1/4; off=1/4; pri=9,9

SILENCE VTG1 pri=15,15

PLAY VTG1=A55 CHL1=VTG1 L133=CHL1 trk=P89 pri=9,9

SPEAKER CHL1 pri=9,9

L133 CONTROL DAYCARE SPEAKER CIRCUITS

END:

Label: Daycare Drill Switch Off-Spkr/Strbes Off

Equation 2

COMMENTS:

INPUTS:

NOT the ON state of:

M1-42                      UTILITY                      DRILL SWITCH DAYCARE CENTER GND FL  
M1-42

OUTPUTS:

HOLD points OFF pri=9,9

L12                      CONTROL

FIRE ALARM VISUALS OFF ON SILENCE

SILENCE VTG1 pri=9,9

HOLD points OFF pri=9,9

L133                      CONTROL

DAYCARE SPEAKER CIRCUITS

END:

Label: All Bldg Drill Sw On-Spkr/Strbes On

Equation 3

COMMENTS:

INPUTS:

The ON state of:

M1-43                      UTILITY                      DRILL SWITCH MET SCHOOL 4TH FL SO.  
M1-43

AND NOT the ON state of:

P257                      TROUBLE

SIGNAL CIRCUITS BYPASS

OUTPUTS:

HOLD points ON pri=9,9

L135                      CONTROL

ALL STROBE CIRCUITS FOR BLDG DRILL

MARCH TIME G0; L12; on=1/4; off=1/4; pri=9,9

SILENCE VTG1 pri=15,15

PLAY VTG1=A55 CHL1=VTG1 L136=CHL1 trk=P89 pri=9,9

SPEAKER CHL1 pri=9,9

L136                      CONTROL

ALL SPEAKER CIRCUITS FOR ALL BLDG

DRILL

-----  
SHEPARD'S BUILDING                      CUSTOM CONTROL EQUATION LISTING

Page 128

9520019D node:1 rev:16

10:27:30, TUE,

19-NOV-13  
-----  
-----

CUSTOM CONTROL

EQU DETAIL

Program: 6

Program: 6

END:

Label: All Bldg Drill Sw Off-Spkr/Strbes Off

Equation 4

COMMENTS:

INPUTS:

NOT the ON state of:

M1-43                      UTILITY                      DRILL SWITCH MET SCHOOL 4TH FL SO.

M1-43

    OUTPUTS:

        HOLD points OFF pri=9,9

            L135                      CONTROL                      ALL STROBE CIRCUITS FOR BLDG DRILL

        SILENCE VTG1 pri=9,9

        HOLD points OFF pri=9,9

            L136                      CONTROL                      ALL SPEAKER CIRCUITS FOR ALL BLDG

DRILL

    END:

Label: [END-OF-PROGRAM]

Equation 5

-----

-----

SHEPARD'S BUILDING                      REPORT CATEGORY INDEX

Page 129

9520019D node:1 rev:16                      10:27:30, TUE,

19-NOV-13

-----

-----

INDEX

Report Category	Page Number
-----	-----
GENERAL INFORMATION	1
SYSTEM OPERATION	2
CARD SUMMARY BY LOCATION	3
SYSTEM POINT SUMMARY	5
DIGITAL PSEUDO POINT SUMMARY	15
ANALOG PSEUDO POINT SUMMARY	22
POINT LIST SUMMARY	27
POINT LIST DETAIL	30
PANEL KEYS AND LEDS REPORT	91
REMOTE UNIT INTERFACE (RUI) REPORT	92
UNIT DETAIL REPORT	94
2120/RS232 INTERFACE REPORT	108
AUDIO CONFIGURATION REPORT	109
OPTIONS DETAIL REPORT	110
NETWORK INTERFACE REPORT	114
TRUEALERT CARD DETAIL	--
VIRTUAL NACS REPORT	115
CUSTOM CONTROL EQUATION LISTING	117