THE
UNIVERSITY
OF RHODE ISLAND
DIVISION OF
ADMINISTRATION
AND FINANCE

THINK BIG WE DO™

PURCHASING DEPARTMENT
581 Plains Road, Suite 3, Kingston, RI 02881 USA p: 401.874.2171 f: 401.874.2306 uri.edu/purchasing

DATE: 4/2/2013

ADDENDUM # 1

BID NO. : 2336
OPENING: 4/10/13 - 3:00 PM
COMMODITY: Persona Lock Installation

Attached please find the sign-in sheet for the mandatory pre-bid conference held on 3/26/13 at 11:00 AM.

As noted at the pre-bid; bidders should familiarize themselves with RIGL 37-13-3.1 with regard to Apprenticeship, which requires that any public works contract awarded by the State/URI valued at $1,000,000 or more shall employ apprentices required for the performance of the awarded contract. Additional information regarding this RI General Law and information from the RI Dept. of Labor and Training can be found at:
http://webserver.rilin.state.ri.us/Statutes/TITLE37/37-13/37-13-3.1.HTM
http://www.dlt.ri.gov/apprenticeship/

Also included with this addendum are the questions that were submitted by the close of business on Friday 3/29/13 and the corresponding answers.

Due to the late posting of this addendum, the bid opening date has been changed:
From: 4/4/2013
To: 4/10/2013

Tracey A. Angell
Assistant Director, Purchasing Department
University of Rhode Island

The University of Rhode Island is an equal opportunity employer committed to the principles of affirmative action.

***PRE-BID CONFERENCE**

E: 3/26/2013	TIME: 11:00 AM	LOCATION: URI Hillside Hall, Kingston, RI

BID NO: 2336	BID TITLE: Persona Lock Installation	BID OPENING DATE: 4/4/13-3:00 PM

NAME	AFFILIATION	E-MAIL
David Carbone	Assa Ablay - Persona	dcarbone@personacampus.com
Ian Robertson	Kolram	ian@kolram.com
Tom Thompson	Kolram	Tom@Kolram.com
Jim Casey	Siemens	James.Casey@siemens.com
Bill Smith	Siemens	williamSmith@siemen.com
Felix Appolonia	Columbus Door Co	fappolonia@columbusdoor.com
Rick Mut	Nationwide Security Corp.	rickm@nationwidesecuritycorp.com
Mike Viscuso	" "	mikev@nationwidesecuritycorp.com
Craig Rogers	Bonner Electric	CROGERS@Bonnerelectric.com
Justin Wakim	Maron Construction Company	jwakim@mccri.com
J. Bahry	Bahry Building Company	mb@bahrybuilding.com
Tracey Argyll	URI Purchasing	targyll@uri.edu
MARCO TOMMASINI	TECTON ARCHITECTS	MARCOT@TECTONPC.com
Rich D'Andrea	Facilities Access Control	HIRAM@URI.EDU

KOLRAM
ACCESS SERVICES

Ian Robertson
Information Technologies/Network Specialist

SYSTEMS INTEGRATORS
50 United Drive, North Haven, CT 06473
Phone: 203.234.8688 Fax: 203.985.0399 Cell: 203.627.5305
Web: www.kolram.com Email: ian@kolram.com

ASSA ABLOY

Ed Wassmer
Regional EAC Campus Manager

Tel (203) 603-5941
Fax (203) 643-2044
Mobile (203) 530-7775
ewassmer@assaabloydss.com
www.assaabloydss.com
www.personacampus.com

Door Security Solutions
74 Manorwood Drive
Brandford, CT 06405

SIEMENS Infrastructure & Cities

Siemens Industry, Inc.
Infrastructure & Cities Sector
Building Technologies Division

85 John Road, Unit 1
Canton, MA 02021
USA

James Casey
Sales Executive

Direct: +1 781 774-8184
Fax: +1 866 577-7525
james.casey@siemens.com

NSC
NATIONWIDE SECURITY CORPORATION

Rick Mut
Sales Representative

47 Montowese Avenue • North Haven CT 06473
Tel: (203) 785-0300 Ext. *104 • Fax: (203) 867-8736
Email: rickm@nationwidesecuritycorp.com
www.nationwidesecuritycorp.com

"Helping Companies Preserve Profits & Create a Safe Productive Workplace"

COLUMBUS

Total Opening Systems
Educational, Healthcare, Commercial

COLUMBUS DOOR COMPANY
Felix Appolonia, AHC/CDC

Tel (401) 781-7792
Fax (401) 467-3620
1884 Elmwood Avenue,
Warwick, RI 02888

- Steel Doors, Frames & Entrance Systems
- Architectural Wood Doors
- Builders Hardware

BONNER ELECTRIC, INC.

1865 Norwich-New London Tpke.
P.O. Box 366
Uncasville, CT 06382
CT Lic. 102976
RI Lic. A0228

Craig Rogers

(860) 848-8539
(860) 848-4279 FAX
(860) 625-3987 CELL

Aerial Bucket Truck
Machine Wiring
Programmable Controls
Computer Wiring
Industrial Maintenance
Variable Speed Drives

crogers@bonnerelectric.com

Bid 2236 Persona Locks; Questions and Answers

1. The door schedule shows a new door contact on all existing exterior doors. Are we replacing existing contact with new or are we running new cable to new contact?

Answer: The door contact is new, and an existing door contact does not exist. New wiring shall be provided to the new door contact.

2. If adding new door contacts on new and existing doors is a new Request to Exit sensor required?

Answer: No. The door contact is to detect when a door is left open.

3. Are we adding a hood to all exterior existing card reader locations as well as new card reader locations?

Answer: Per Detail 1/G1.2, new hood is to be installed at all exterior card reader locations. This applies to new and existing exterior card readers.

4. Electrical plans call for all new power supplies, is it ok to reuse the existing power supplies where we can?

Answer: If the existing power supplies are compatible with the new system, it shall be acceptable to reuse the power supplies. If the power supplies are to be reused, the Contractor shall verify with the Engineer. Contractor is to presume providing all new power supplies per Electrical Plans.

After reviewing the bid documents and drawings, we have the following questions pertaining to URI Project KC.R.MISC.2012.002...

1. Will URI provide a network drop at each Vertex V1000 panel in each Resident Hall?

Answer: A network drop already exists at each location.

2. Will lodging be available on site? If so, what months can it be offered?

Answer: Lodging is not offered as part of this project.

3. At Barlow, Door 035B calls for a WIFI Exit Device, but not shown on Door Schedule. Please verify?

Answer: Provide WiFi exit device at Barlow Hall Door 035B per note on drawing. This door designation is not indicated on door schedule.