



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

February 21, 2012

**ADDENDUM NUMBER ONE**

**RFQ # 7449431**

**TITLE: EXTERIOR DOOR REPLACEMENT CANNON BUILDING,  
DOH**

**Closing Date and Time: 2/29/12 at 1:45 PM**

**Per the issuance of this ADDENDUM # 1  
(3 pages, including this cover sheet)**

**Specification Change /Addition / Clarification**

# RFP/LOI #7449431

\*\*\*ADDENDUM ONE\*\*\*

Exterior Door Replacement  
Cannon Building  
3 Capitol Hill  
Providence, Rhode Island

February 15, 2012

## NOTICE:

This Addendum modifies, amends and supplements designated part of the CONTRACT DOCUMENTS for the project identified as "Exterior Door Replacement, Cannon Building", dated October 14, 2011, are hereby made a part thereof by reference, and shall be as binding as though inserted in its entirety in the locations designated hereunder. It shall be the responsibility of the Contractor to notify all subcontractor and suppliers he proposes to use for the various parts of the work of any changes or modifications contained in this Addendum. No claim for additional compensation due to lack of knowledge of the contents of this Addendum will be considered.

## PRE-BID CONFERENCE:

A pre-bid conference for this project was held at the site on February 15, 2012, 10:00 AM local time. The sign-in sheet for this conference is attached to the end of this Addendum.

## CLARIFICATIONS:

Contractor's Questions

1. Can we block off the South exit ways?

**Response: No. South exit must be maintained at all times.**

2. Can we work after hours?

**Response: Yes. Work may begin after 5:00 PM Monday through Friday and normal business hours on Saturday.**

3. Will concrete patching be the responsibility of the contractor at threshold replacement?

**Response: Yes. If required, contractor shall patch existing concrete slab to ensure proper installation of new thresholds.**

END OF WRITTEN ADDENDUM

\*\*\*ADDENDUM ONE\*\*\*  
PAGE 1 OF 1

