



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 11, 2012

ADDENDUM NUMBER FIVE

RFQ # 7449625

TITLE: RI STATE HOUSE – SERVER ROOMS

Closing Date and Time: 6/22/12 at 1:45 PM

**Per the issuance of this ADDENDUM # 5
(2 pages, including this cover sheet)**

Specification Change /Addition / Clarification

RI STATE HOUSE - SERVER ROOMS
Capitol Hill - Providence, Rhode Island

June 11, 2012

TO: All Bidders

ADDENDUM #5 - RFQ #7749625

The Contract Documents for the above referenced Project are hereby modified per the following. All other Drawing and Project Manual items not addressed herein shall remain in full effect. The Bidder shall acknowledge the receipt of this Addendum on the Bid Form.

DRAWINGS:

- 1) **Re: E-2:** Add the following notes & information:
 - A. Any brand of Security System A/V device that will be considered compatible with the deluge panel is acceptable. System sensor speaker strobes are currently installed throughout the building.
 - B. Security System A/V devices may be installed on the ceiling as shown on the Drawings or on the wall above the doors as long as the room is properly covered.
 - C. Fixed and Pan/Tilt/Zoom security cameras are shown on the Drawings. Coordinate with the Security System Vendor for the exact models required for the system.
 - D. There will be 2 horn/strobe devices required for each Server Room. Speaker strobes are not required in the Server Rooms.

- 2) **Re: E-1:** Add the following notes & information:
 - A. The Security System vendor is "Integrated Security" out of Foxboro, Massachusetts. Contact: Bob Levesque.

END OF ADDENDUM #5