



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

May 17, 2012

ADDENDUM NUMBER THREE

RFQ # 7449665

**TITLE: FIRE ALARM SYSTEM REPLACEMENT,
MINIMUM SECURITY, DOC**

Closing Date and Time: 5/29/12 at 1:45 PM

**Per the issuance of this ADDENDUM # 3
(3 pages, including this cover sheet)**

Specification Change /Addition / Clarification

Hughes Associates, Inc.
New England Office
117 Metro Center Boulevard, Suite 1002
Warwick, RI 02886
Tel: 401-736-8992
Fax: 401-736-8929

Addendum #3

To: All Bidders

CC: Christopher Furtado – Department of Corrections

From: Mark J. Blackburn, P.E., CFPS

Date: May 16, 2012

Subject: Department of Corrections – Minimum Security Building
Automatic Fire Alarm System
Addendum #3

Project No. 1MJB00208.000

Bidders,

Please allow this memorandum to serve as Addendum #3 for the fire alarm system installation project at the Minimum Security Building located in Cranston, RI. The following summarizes the discussion at the pre-bid conference:

- 1 Enclosed with this addendum is the pre-bid sign-in sheet;
- 2 The Contractor shall include all labor, materials, programming and testing to install the following:
 - a Two (2) addressable photoelectric smoke detectors within the newly constructed vestibule and storage room on the 1st floor of Wing B;
 - b One (1) horn/strobe notification appliance in the newly constructed vestibule on the 1st floor of Wing B;
 - c One (1) addressable heat detector in the newly constructed activity room on the 1st of Wing C; and
 - d One (1) strobe notification appliance in the newly constructed activity room on the 1st of Wing C.
3. The existing fire alarm system must remain operational throughout the installation. As the existing control unit is being reused and upgraded, it is understood that the system will be impaired during final connections, programming, testing and replacement of control unit components. Impairments should be limited to a single shift. The Contractor must include necessary overtime to restore the system to normal status.
4. Upon acceptance of the new fire alarm system, the Contractor is responsible for removing all existing devices and components, wiring and all exposed raceway. The Contractor shall be responsible for firestopping all existing and new penetrations related to fire alarm system wiring and conduit.

All bidders must acknowledge receipt and compliance with this addendum in their bid.

STATE OF RHODE ISLAND -- DEPARTMENT OF CORRECTIONS
 FACILITIES & MAINTENANCE UNIT

PRE-BID FOR: Minimum Security
 PROJECT: Five Alarm Upgrade
 Date: May 15, 2012

NAME	ADDRESS	FIRM	PHONE
Mark Blackwell	117 Metro-Center Blvd Warwick, RI	Hughes Asson	736-8912
STEVE CAPOZZOLI	34 OAKDALE AVE JOHNSTON, RI	CALSON CORP.	878-1100
BRIAN DAILEY	44 Blanding Rd Roholobata 02864	H&C Security	728-2031
RICHARD TOLLO	21 PINE ST. WARWICK, RI 02888	JT O'ROURKE	785-9850
Steve LANTON	270 Chestnut St Warwick, RI 02886	AFA	401-255-8629
JOHN MIGUEZ	2883 SO COUNTY RD	R F AUDET	884 3310
APRIL KELMAN	106 DOYLE AVE PROV RI 02946	CK Electric	331-3909
PAUL JANKOWSKI	320 Newport Ave E Prov RI 02916	PARAN SERVICES	401 935 6919
Chris Johnson	70 BACON ST PAWTUCKET, RI 02860	FSSG	401-723-7301
DAN DAILEY	70 BACON ST PAWT RI 02860	FSSG	401-723-7301
D. LALAMA	2885 CHURCH ST WARWICK, RI	ECSDA	353-2575
P. DE LAJOY		LCSDA	353-2575
WIN PLACE	2000 PLAINFIELD AVE CRANSTON RI	HONEYWELL	690 6652
Jamit Sears	203 Concord St Pawtucket RI	Metro USA	855-8882
SCOTT COLLARD	19 Highland Ave Coveury RI 02816	Colmas Enterprises	821-8601
DON CROOKS	690 NORTON GARDEN	Simplex	401 328 7809

PARK DRIVE
 PAVING CO