



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

August 2, 2012

ADDENDUM # 1

RFQ #7457863

Title: Testing & Inspection of Fire Alarm – URI CCE.

Bid Opening Date and Time 8/21/12 @ 10:00 AM (EDT)

**Vendor Submitted Questions
(see attached)**

Gary P. Mosca

Buyer

Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.

Vendor Submitted Questions

Bid #7457863

Testing & Inspection of Fire Alarm – URI CCE

Line #12 Flow and Standpipes inspection- Five (5) year inspections.

- Quantity listed is 1.00, (there are (4) standpipe risers in the building), do we bid the cost for all 4 in the unit price column?

Answer: Yes. Vendors are bidding the price for a inspection. Quantity is listed as one (1) is correct because bid is calling for one inspection.

- Is the inspection to be performed in accordance with NFPA 25, Chapters 6&12?

Answer: Yes

Line #13 Replacement of all Smoke (Dectors Covers) if required. Please clarify what you are requesting here?

Answer: Bid asking for the price to replace all smoke detectors covers IF REQUIRED in accordance with NFPA 72. Vendors are to bid a price per cover. It is unknown the amount if any to be replaced.

Will there be a walkthrough? Or will we be given a device count for smokes, pulls, heats, horn strobes, strobes, tampers and flow switches? Which is needed to do the bid.

Answer: There will not be walkthrough regarding bid #7457863. In accordance with bid terms & conditions clause "**Inspection**" vendors are responsible for inspection of equipment and/or location. (refer to bid terms). Vendors may contact the following to visit and inspect site prior to submitting a bid.

Gary A. Lulli
Director, Facilities & Operations
URI Providence Campus
80 Washington Street
Providence, RI 02903-1803
Phone: 401-277-5030
Fax: 401-277-5205

or

Ed Coppola
URI Providence/Facilities
80 Washington St.
Shepard Building (Room 325B)
Providence, RI 02903
Phone: 401-277-5179
Fax: 401-277-5205

Continued:

The following information is ESTIMATES ONLY. The State is not responsible for any quantity amounts provided for bid or bidding information.

- Number of smoke detectors – Approximately 200
- Number of pull stations – Approximately 47
- Number of flow switches – Approximately 20
- The following requested information is unavailable - Number of "heats" , "horn strobes", "strobes", "tamperers"

END DOCUMENT