



State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387

August 22, 2012

**ADDENDUM # 2**

**RFQ #7457896**

**Title: New Emergency Generator at the Warwick Campus - CCRI**

**Bid Opening Date and Time 8/29/12 @ 2:00 PM (EDT)**

**Vendor Questions & Pre-Bid Attendance Sheet  
(See attached)**

**Notice to Vendors:**

**Clarification:**

**Bid Form/ Document 00410 – dated 5/2/12 is the PREVAILING FORM.  
There is NO CONTINGENCY for this project.**

**Disk base file (page 86) Attachment “A” – 01200, dated 5/2/12 listed under  
PDF file 05.23.12, indicating 10% contingency is not in effect.**

*Gary P. Mosca*

**Buyer**

*Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.*

**August 8, 2012**

**Pre-Bid Conference**

**BID #7457896 – New Emergency Generator at the Warwick Campus – CCRI**

**Vendor Questions:**

- 1) Is there any asbestos to be removed?
  - Project site has been tested and not found. Any removal of asbestos is not part of this project.
  
- 2) What other portion of the project is not electrical?
  - Removal of fire pump and sprinkler piping.
  
- 3) Will switch over take place during normal business hours or off hours.
  - Switch over will be during off hours. For informational purposes normal business hours are Monday – Friday 8:00 AM -10:00 PM  
Saturday 8:00 AM – 4:00 PM
  
- 4) Are there any utilities in the area location for the new generator?
  - Yes, the conductors from the utility transformer to the main panel.
  
- 5) Is contractor required to remove exhaust pipe from existing generator?
  - Yes. Delete the note on drawing P/FP1.0 which reads “RE DIESEL GENERATOR IN ITS ENTIRETY” and replace it with “REMOVE EXISTING DIESEL POWERED FIREPUMP AND ENTIRE EXHAUST STACK. PATCH CONCRETE ROOF AND SEAL WATERTIGHT.”

New Emergency Generator at the Warwick Campus - CCRI

Company	Representative	Address	Email	Phone
1. Commercial Electric, Inc.	ROY DALRYMP	491 WATERMAN AVE EAST PROVIDENCE RHODESIA	ROY@COMMERCIALELECTRICINC.COM	438-0707
2. "	FRANK BIANCO	"	"	"
3. PASTAN	PAUL STANLWSKI	SEEKUNK MA	pojanservices@yahoo.com	401 9356919
4. CALSON CORP	STEVE CAROZZOLI	34 OAKDALE AVE JOHNSTON RI	STRECC@CALSONCORP.COM	401-873-1100
5. ANDERU CORP	ROY SORANSTO	17 YETLARD RD MA CRANFIE	ROY5651@AOL.COM	781-265 7242
6. Rossi Electric	David Principo	65 Western Industrial Drive	principo@rossielec.com	265-3385
7. FALL RIVER Electric	Suzanne Lydon	75 CORNEAU ST FALL RIVER MA	chancejohnston@fallriver.biz	508-675-0523x17
8. EASTERN Electric	PAUL GRUND	536 WELLSFORD AVE CRANSTON	eastern@easternelectric.net	401-780-9161
9. SHERIDAN Elec.	MICHAEL WORMAN	137 HADLEIGH RD WATERVILLE, ME	MIKE@SHERIDANelectric.com	732-4515
10.				
11.				
12.				