



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

**Solicitation Information
October 23, 2012**

ADDENDUM # 3

RFQ#7458116

**Title: RE-ROOFING AND RELATED ROOF REPAIRS AT RI CDC WAREHOUSE
BID CLOSING DATE: OCTOBER 26, 2012 AT 10:30 AM**

Notice to Vendors:

SEE ATTACHED FOR CLARIFICATION

**Thomas Bovis
Interdepartmental Project Manager**

Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.

DOCUMENT 00900

ADDENDA AND MODIFICATIONS

ADDENDUM NO. 3, 23 October 2012

RE: Re-Roofing and Related Roofing Repairs at the Rhode Island Central Food-Distribution Warehouse, 144 Power Road, Cranston, RI 02920

FROM: Castellucci, Galli Corporation
175 High Service Avenue
North Providence, Rhode Island 02911

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May, 2012; Addendum No. 1, dated 15 October, 2012; and Addendum No. 2, dated 18 October, 2012 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of one (1) page.

For clarification, please note the following:

1. Additional site visits will not be scheduled for Bidders to visit the building rooftop.
2. FM Global will not be involved with this project.
3. Mechanical fastening of the new roofing system will not be allowed as this may potentially compromise the effectiveness of the vapor retarder by penetrating the barrier via fasteners.

END OF ADDENDUM