



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

November 16, 2012

**ADDENDUM NUMBER TWO**

**RFQ # 7458184**

**TITLE: PRUDENCE ISLAND OUTDOOR PAVILION - DEM**

**Closing Date and Time: 11/27/12 at 1:45 PM (Note Change)**

**Per the issuance of this ADDENDUM #2 (3 pages, including the cover sheet) the following change(s) are noted:**

**Please be advised the Bid Closing Date and Time has been extended to:**

**From: 11/20/12 at 1:45 PM  
To: 11/27/12 at 1:45 PM**

**SEE ATTACHED**

**Specification Change /Addition / Clarification**

# RFP/LOI #7458184

\*\*\*ADDENDUM TWO\*\*\*

Prudence Island Outdoor Pavilion  
Narragansett Bay Research Reserve  
Prudence Island, RI

November 14, 2012

## NOTICE:

This Addendum modifies, amends and supplements designated part of the CONTRACT DOCUMENTS for the project identified as "Prudence Island Outdoor Pavilion, Narragansett Bay Research Reserve, Prudence Island, Rhode Island", dated March 1, 2012, and Addendum One, dated October 26, 2012, are hereby made a part thereof by reference, and shall be as binding as though inserted in its entirety in the locations designated hereunder. It shall be the responsibility of the Contractor to notify all subcontractor and suppliers he proposes to use for the various parts of the work of any changes or modifications contained in this Addendum. No claim for additional compensation due to lack of knowledge of the contents of this Addendum will be considered.

## DRAWINGS:

Drawing E1.0, Electrical Floor Plans

Power and Systems Plan: Plan shall indicate an additional Fire Alarm Multi-sensor Detector within Closet Room 101. Contractor shall carry the cost to provide and install this device in their base bid.

## PRE-BID CONFERENCE:

A mandatory pre-bid conference for this project was held at the site on November 7, 2012. The sign-in sheet for this conference is attached to the end of this Addendum.

## NOTICE TO ALL CONTRACTORS:

Contractors shall call our office to verify number of Addendum issued at least 24 hours in advance of bid submission. Failure to acknowledge receipt of this addendum on the bid form may, at the sole discretion of the Owner, serve as justification to reject bids.

END OF WRITTEN ADDENDUM

\*\*\*ADDENDUM TWO\*\*\*  
PAGE 1 OF 1

