



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: www.purchasing.ri.gov

January 9, 2013

**ADDENDUM NUMBER ONE**

**RFQ # 7458339**

**TITLE: LEWIS CITY BRIDGE REPLACEMENT ARCADIA MGMT.  
AREA, DEM**

**Closing Date and Time: 1/24/13 at 2:00 PM**

**Per the issuance of this ADDENDUM #1  
(2 pages, including this cover sheet)**



**Specification Change /Addition / Clarification**

**Below is a question and the answer to the question we received.**

**Question:** Please clarify the grade of steel being used.

The spec section 05500 states the steel shapes to be ASTM A36 but on plan S102, RI Standard details states the steel shapes to be a weathering steel (Grade ASTM A588).

Answer: Refer to the Structural Steel notes on Sheet C001; all beams shall be ASTM A992 (Grade 50) and ASTM A36 for channels, angles and plates. The steel for the timber guardrail shall be ASTM A588 weathering steel.