State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #2

RFQ #7458349 **TITLE: 2013-DF-051 HURRICANE SANDY CLEANING, FLUSHING & VIDEO DRAINAGE STRUCTURES AND PIPES**

OPENING DATE AND TIME: 12/21/12 – 11:15 A.M.

Prospective bidders and all concerned are hereby advised of the attached changes/modifications for the above referenced RFQ and are hereby requested to change their copies accordingly.

NOTE: NEW OPENING DATE & TIME.

SEE ATTACHED CLARIFICATIONS.

Lisa Hill

LISA HILL
CHIEF BUYER

Bidders must include a signed copy of this addendum with their bid submission as acknowledgment.

Company Name (Print) **Signature of Authorized Representative**

BID NO. 7458349
ADDENDUM NO. 2

HURRICANE SANDY CLEANING, FLUSHING AND VIDEO DRAINAGE STRUCTURES AND PIPES

RHODE ISLAND CONTRACT NO. 2013-DF-051

1) No erosion and sediment control plan is required for Hurricane Sandy repairs; the RIDOT Standards and Specifications apply.
2) If an outfall is clogged, the Rhode Island Department of Environmental Management allows clearing to a maximum of 10 feet from the end of the pipe. The width of debris/sediment removal may vary in order to allow for full operation of the drainage system.
3) Disposal requirements for debris from pipes and catch basins are provided in the RIDOT Standards and Specifications.
4) Staging areas are selected by the Contractor and approved by RIDOT.