



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

**Solicitation Information
February 12, 2013**

ADDENDUM # 3

RFQ#7459268

**Title: URI – PASTORE HALL AUDITORIUM HVAC REPLACEMENT
BID CLOSING DATE: February 20, 2013 AT 11:00 AM (EST)**

Notice to Vendors:

SEE ATTACHED ADDITIONAL INFORMATION FOR PROJECT

**Thomas Bovis
Interdepartmental Project Manager**

Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.



CREATIVE ENVIRONMENT CORP.

CONSULTING ENGINEERS
50 OFFICE PARKWAY
EAST PROVIDENCE, RI 02914

120 MAPLE STREET, SUITE 304
SPRINGFIELD, MA 01103

ADDENDUM #3

DATE: February 11, 2013

PROJECT: UNIVERSITY OF RHODE ISLAND
PASTORE HALL ~ AIR HANDLING UNIT REPLACEMENT

URI PROJECT #: KC.G.PAST.2011.002
RI STATE BID #: 7459268

FROM: CREATIVE ENVIRONMENT CORP. (CEC#20981)

TO: ALL BIDDERS

This Addendum forms a part of the Contract Documents and modifies the original bidding documents dated January 20, 2010 and updated October 2012, as noted below. Failure to acknowledge receipt of this Addendum in the space provided on the Bid Form may subject the Bidder to disqualification.

REVISIONS AND/OR ALTERATIONS TO THE DRAWINGS:

1. Drawing E-1 at "New Electrical Floor Plan": Eliminate the new fire alarm duct smoke detectors serving new EF-1 and EF-2, and provide new fire alarm shutdown relays for each fan.
2. Drawing E-1 at "New Electrical Floor Plan": Provide new fire alarm shutdown relays for both AHU-1 and AHU-2.

END OF ADDENDUM