



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

BID # 7461239

**BID TITLE: HURRICANE EMERGENCY REPAIRS
SCARBOROUGH STATE BEACH**

OPENING DATE AND TIME: 3/5/13 1:30PM

THIS ADDENDUM POSTS SIGN IN SHEET FROM MANDATORY PRE BID HELD 2/26/13 AT 9AM.

**THIS ADDENDUM CLARIFIES ISSUES RAISED AT THE PRE BID AND ANSWERS QUESTIONS
SUBMITTED TO [BIDINFO@PURCHASING.RI.GOV](mailto:bidinfo@purchasing.ri.gov)**

**THE ONLY INSURANCE REQUIREMENTS THAT PERTAIN TO THIS BID WILL BE THOSE THAT APPLY
TO GENERAL LIABILITY, AUTO, AND WORKER'S COMPENSATION.**


**BIDDERS' ATTENTION IS REFERRED TO STATE REQUIREMENTS PERTAINING TO THE CONDITIONS
OF EMPLOYMENT TO BE OBSERVED, INCLUDING THE EQUAL EMPLOYMENT OPPORTUNITY ACT
AND REQUIREMENTS THAT 10 PERCENT OF THE DOLLAR VALUE OF THE WORK MUST BE
PERFORMED BY MINORITY BUSINESS ENTERPRISES, AND WAGE RATES TO BE PAID UNDER THE
CONTRACT FOR THIS PROJECT MUST BE IN ACCORDANCE WITH THOSE PREVAILING WAGES ON
FILE IN THE RHODE ISLAND DEPARTMENT OF LABOR, OFFICE OF THE DIRECTOR, AND INCLUDED
IN THIS PROJECT MANUAL. BIDDERS ARE SUBJECT TO TERMS, CONDITIONS AND PROVISIONS OF
STATE'S GENERAL CONDITIONS OF PURCHASE, AND TO THE PROVISIONS OF CHAPTERS 2, 12, 13 AND
14.1 OF TITLE 37, GENERAL LAWS OF THE STATE OF RHODE ISLAND 1956, AS AMENDED.**

**REQUEST FOR QUOTE PAGE 1 IS TO BE SUBMITTED AS ATTACHED. ACTUAL BID DOCUMENTS TO BE
SUBMITTED ARE CONTAINED WITHIN THE BID SPECIFICATIONS.**

**PLEASE NOTE PUBLIC COPY REQUIREMENT (IF OVER \$500,000) AS NOTED IN BID SPECIFICATIONS
AND DISCUSSED IN PRE BID.**

**PLEASE NOTE BID BOND REQUIREMENT AS NOTED IN BID SPECIFICATIONS AND DISCUSSED IN PRE
BID.**

NO FURTHER QUESTIONS WILL BE TAKEN.



Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
ONE CAPITOL HILL
PROVIDENCE RI 02908

CREATION DATE : 15-FEB-13 BID NUMBER: 7461239 TITLE: HURRICANE EMERGENCY REPAIRS-SCARBOROUGH STATE BEACH BID CLOSING DATE AND TIME: 05-MAR-2013 01:30:00
--

BUYER: Cadoret, David PHONE #: N/A

B I L L T O	DOA CONTROLLER ONE CAPITOL HILL, 4TH FLOOR SMITH ST PROVIDENCE, RI 02908 US
--	--

S H I P T O	DEM PLANNING & DEVELOPMENT 235 PROMENADE ST, SUITE 330 PROVIDENCE, RI 02908 US
--	--

Requisition Number: 1305486

Note to Bidders: THERE WILL BE A MANDATORY PREBID AT THE LOCATION. SEE ATTACHED FOR DATE AND TIME.

Line	Description	Quantity	Unit	Unit Price	Total
1	HURRICANE EMERGENCY DISASTER RECOVERY REPAIRS TO SCARBOROUGH STATE BEACH REMOVAL OF PAVEMENT, CONCRETE AND MORTAR REPAIRS, INSTALLATION TO FILL VOIDS, STONE REPAIRS, CURB REPAIRS, FULL DEPTH SAW CUT, EXCAVATION, EROSION CONTROLS, BITUMINOUS CONCRETE, CONCRETE SIDEWALK, REPAIR OF EXISTING CONCRETE WALL CAPS, BENCH REPAIRS, PLACEMENT OF HAND RAILS, DRAINAGE TRENCH GRATES, CONCRETE GRINDING, SWEEPING PAVEMENT, TRAFFIC CONTROL, MAINTENANCE AND PROTECTION OF TRAFFIC AND OTHER INCIDENTALS NECESSARY TO COMPLETE THE REPAIR WORK AT SCARBOROUGH STATE BEACH, NARRAGANSETT RI PER SPECIFIFCATIONS	1.00	Each		SEE ATTACHED

Delivery: _____

Terms of Payment: _____

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer

NOTICE OF ADDENDUM NO. 1

State of Rhode Island
DEM Planning and Development
Bid No. 7461239
Hurricane Emergency
Repair - Scarborough State Beach
Narragansett, Rhode Island

DATE OF ADDENDUM: February 28, 2013

The contract documents are hereby modified to include the following as if fully attached thereto.

Contract Specifications

- 1. Reference BID ITEM - HRS-01 Scarborough Beach, Work Summary, Page 5 and 6, Task C Remove and Replace Concrete Walkways (SY) for Work Areas 1, 2, 3, 31, 32, and 33.** The limit of sidewalk restoration shall include the complete removal of sidewalks less than 12 feet in width from the curb line. Continuous sidewalk areas shall extend approximately 10 feet from the curb line. The repair width shall be adjusted to match existing joints, i.e. dummy, construction, or expansion.
- 2. Reference BID ITEM - HRS-01 Scarborough Beach Repair Work Areas, Page 4, Repair 39 and Sketch No. 9, Page 26.** The Contractor shall fill the void/slope between the ramp to be reconstructed and the existing ramp to the west with sand. The void/slope shall be provide a continuous sloped grade between the upper ramp and lower ramp.
- 3. Reference BID ITEM - HRS-01 Scarborough Beach Page 20, Sketch No. 3.** Delete Sketch No. 3 and replace with the attached revised Sketch No. 3.
- 4. Reference BID ITEM - HRS-01 Scarborough Beach, Work Summary, Page 5 and 6, Work Area 16, & Page 10, Photographs 28 through 30.** The work shall include filling all voids below and adjacent to the sidewalk to be removed and replaced. Voids are anticipated to extent in all directions under the existing sidewalk repair. The Contractor shall include provisions for providing 80 cubic yards of flowable fill to fill these voids.
- 5. Reference BID ITEM - HRS-01 Scarborough Beach, Work Summary Page 6, Reference Note Below Work Table Summary.** The quantities provided above are for informational purposes only, and do not include all items necessary to furnish, to install, and to complete the work. The Contractor shall review the project site to determine their own quantities, the extent of work, and all materials and equipment necessary to restore the project site to pre-storm conditions."

Responses to Comments

- 1) Are there any Army Corp., DEM, EPA, SWIPP, etc. documents, conditions for this project?

Responses: A permit submission has been made to RICRMC. We do not anticipate any adverse restriction or conditions.

- 2) Are the any Geotech, Environmental or other Engineering reports for this project?

Responses: RIDEM record plans are available for various projects which may provide engineering data. Please contact John Callan, 222-2776 ext. 4314 or James D. McGinn, 222-2776 ext. 4313 to review plan at their office.

- 3) Are there any Liquidated Damages or any penalties on this project?

Response: No.

- 4) What are the days and hours of operations?

Response: Construction work is permitted daily from 7:00 a.m. to sunset.

- 5) Will police details be required? If so, how will it be paid for?

Response: Police details are not anticipated.

- 6) What and where is the access to the beach to get trucks and equipment on the beach?

Response: Access to the beach is available from the southerly corner of the parking lot.

- 7) Task F, The Joint Sealer, states to apply joint sealant to all expansion and construction joints located throughout the walkway areas, this quantity would far exceed the 2000 If indicated in the work summary. Is it the intention of this project to only replace the joint sealant that is loose? Or throughout the walkway areas?

Response: The intent is to install joint sealant wherever it is missing or loose.

- 8) Task F, joint Sealant, some on the joints look as if they are much too deep to plug with just the joint sealant. Please advise.

Response: These locations would require the installation of backer rod.

- 9) Is the work for Task H (Grinding Concrete Walkways) only on sidewalk along the Railing, as depicted in Sketch 3?

Response: Grinding is required at several areas as designated on the Work Summary Sheet.


- 10) Is it the intention of this proposal for the work in Task H for the Railing to stay in place and conclude the grinding before it, as depicted on Sketch 3?

Response: The detail has been revised. The railings will not be impacted by grinding operations.

END OF ADDENDUM NUMBER 1

f:\files\wordpro\1457\specification\scarborough beach - addendum 1.docx

F:\FILES\CAD\1454\Figure 1.dwg, SKETCH04, 2/27/2013 2:00:18 PM, USER67, \\Wfnsv01\RICOH-Alicia MP C5501 ALT, 1:1



SIDEWALK GRINDING DETAIL

ADDENDUM NO. 1

PAGE 20

SKETCH NO.

3

DATE: 1/8/2013

REVISED 2/28/2013



Gordon R. Archibald, Inc.
Civil and Environmental Engineers
Pawtucket, Rhode Island

TITLE OF SKETCH

STORM REPAIRS TO
SCARBOROUGH BEACH

SIDEWALK GRINDING DETAIL

STATE of RHODE ISLAND

DEPARTMENT of ADMINISTRATION DIVISION of PURCHASES

MANDATORY PRE-BID CONFERENCE ATTENDANCE SHEET HURRICANE EMERGENCY REPAIRS-SCARBOROUGH STATE BEACH

BID # 7461239

DATE 02/26/13

TIME STARTED

9:00

TIME ENDED

9:50

NAME	COMPANY NAME	EMAIL (OR PHONE)
<u>LARRY GARDNER</u>	<u>Cosco Inc</u>	<u>LGARDNER@COSCOFEVES.COM</u>
<u>FRED SARMIENTO</u>	<u>D'AMBRA</u>	<u>FRED@D-AMBRA.COM</u>
<u>JASON B. NORMAN</u>	<u>E. J. Prescott, Inc</u>	<u>jason.norman@ejprescott.com</u>
<u>DAVID B. BUTTERFIELD</u>	<u>Catalano Const Inc</u>	<u>dbutterfield@catalanoconstruction.com</u>
<u>Tom Mongillo</u>	<u>CASSI IT, Inc</u>	<u>mongillo_t@quest.com</u>
<u>DAVE HICKEY</u>	<u>HKS</u>	<u>HUGKEYANDSON@VERIZON.NET</u>
<u>John DiVito</u>	<u>Norham Const Svc, LLC</u>	<u>JDIVITO@NORHAMCONSTRUCTION.COM</u>
<u>Andy Ieranni</u>	<u>Manafort</u>	<u>GIORANNI@MANAFORE.COM</u>
<u>Sean McLeod</u>	<u>America's site corp</u>	<u>Anthony@A.D.Fazio@smithbar-ni.com</u>
<u>JUSTIN ROGERS</u>	<u>All Island Landscape</u>	<u>SRGERS@ALLISLANDLANDSCAPE.COM</u>
<u>DAVID CADYET</u>	<u>PURCHASING</u>	

STATE of RHODE ISLAND

DEPARTMENT of ADMINISTRATION DIVISION of PURCHASES

MANDATORY PRE-BID CONFERENCE ATTENDANCE SHEET HURRICANE EMERGENCY REPAIRS-SCARBOROUGH STATE BEACH

BID # 7461239 DATE 02/26/13
TIME STARTED 9:00 TIME ENDED 9:50

NAME	COMPANY NAME	EMAIL (OR PHONE)
<u>Jim Fox</u>	<u>Yard Works</u>	<u>463-9133</u> <u>JimFox71@Comcast.com</u>
<u>Mike Donatelli</u>	<u>NEBB</u>	<u>441-5336</u> <u>donatelli4@netnet.net</u>
<u>James Mauthaway</u>	<u>Piccoli</u>	<u>www.Piccoli.com</u>
<u>Todd Travanelle</u>	<u>GRA Inc.</u>	<u>travanelle@graengs.com</u>
<u>Lenny Corrente</u>	<u>Laborers</u>	<u>Lcorrente@LNEROF.ORG</u>
<u>Jim McGinn</u>	<u>EDDEM</u>	<u>james.mcginn@eddem.org</u>
<u>ROGER MONTFETTE</u>	<u>LEN PARKS AREA</u>	
<u>Jon Trakas</u>	<u>Narr. Imp. Co.</u>	<u>331-7420</u> <u>jtrakas@nicuri.com</u>
<u>Joe Colapietro</u>	<u>CARDI Corp</u>	<u>401-739-8300</u> <u>JOE COLAPIETRO@CARDI.COM</u>
<u>Nidal Saiton</u>	<u>Jill Lynch</u>	<u>NSaiton@jilllynch.com</u>
<u>JAY Moon</u>	<u>URSANE CONSTR.</u>	<u>moonj@urbaneconstruction.com</u>