

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

March 27, 2013

ADDENDUM NUMBER ONE

RFQ # 7461330


TITLE: Furnish and Replace Defective Sewer Pipe, DOA

Closing Date and Time: 4/5/13 at 1:45PM

**Per the issuance of this ADDENDUM #1
(5 pages, including this cover sheet)**



Specification Change / Addition / Clarification



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

March 27, 2013

ADDENDUM NUMBER ONE

REQUEST FOR QUOTE: 7461330
FURNISH AND REPLACE DEFECTIVE SEWER PIPE, DOA

Answers to Questions received from various vendors.

- Dimensions provided are for the purpose of discussions. Confirmation of dimensions is the responsibility of the contractor.
- Any disturbed paved, grass or landscape areas, will be restored prior to the application for payment.
- The contractor is responsible for obtaining any permit(s).
- The contractor will contact and co-ordinate the identification of utilities by Dig Safe. The state will locate electrical, fiber optic, water and steam.
- Disposal of debris and any unsuitable material will be in an appropriate manner and off site.
- Four (4) trees, including stumps, will be removed. Two other stumps will also be removed.
- Please see included picture for reference manhole numbers.
- Sewer serves active, occupied buildings whose services to the public may not be interrupted. Therefore contractor must make provisions for the continued discharge of sewerage.
- Sewer manhole # 4 will be replaced with a new precast sewer manhole, including cover and ring.
- There was a recent blockage between manhole 5 and 4. Observations suggest that the condition causing that blockage may also exist between manhole 4 and 3. Therefore contractor will clean and camera, with video record, the line between manholes 3 to 4. The state will review the video findings and will determine if and how much of this line needs to be replaced.
- Work between manhole 4 and 5, including the replacement of manhole 4 and compliance with conditions stated, is the base bid.
- The contractor will provide a cost per foot as an 'add alternate' for additional footage identified in the video and agreed to by the state. All conditions in the base bid will apply.

- Work area will be left clean and free of hazards at the end of each work day and at the completion of work. Work site will be protected to eliminate inadvertent access.
- All work will be performed in a manner consistent with industry standards and compliant with State, Federal and local standards by staff qualified by experience and license. Any license required by the State of Rhode Island will be available on site upon request.

To see all the details that are visible on the screen, use the "Print" link next to the map.

Google

Sewer M.H.
#1

Sewer M.H.
#2

