

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

April 8, 2013

ADDENDUM NUMBER ONE

RFQ # 7461354

TITLE: Replace Cooling Compressors A/C System, DOA


Closing Date and Time: 4/18/13 at 1:45 PM

**Per the issuance of this ADDENDUM #1
(3 pages, including this cover sheet)**



Specification Change /Addition / Clarification

The attached two (2) pages of Specifications were erroneously left of the original bid posting. Please include these in your bid response.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

April 8, 2013

SPECIFICATIONS FOR BID 7461354

New Compressors 50 Service Avenue

Remove and replace existing compressor on Trane Climate Changer Chiller for cooling unit serving first and second floor in the boiler room. Replace existing compressor with new Trane 3 D scroll type compressors 4@ 15 ton each (or approved equal) . Fabricate prime and paint support for the new compressors.

Replace all necessary components and controls. Replace TXV with electronic expansion Valve and install new Trane Tracer microcomputer-based controller. This unit shall microcomputer-based controller that can be monitored all necessary points and be controlled from a remote location. This controller will stage on the unit as load necessitates. Recharge with refrigerant and commission unit.

Include all necessary controls, control wiring and power wiring, (Voltage is 460 volt 3 phase) controllers, compressor related materials, refrigerant and all necessary labor.

PRINT DATE SEPT 2002

FILE NO. PL-RF-COM-CSHA-SU-1001R2

REPLACES: CSHA-SU-1001P2

SUBMITTAL NUMBER CSHA-SU-1001R2



MODEL CSHA-140 & 150
3-D SCROLL
A COMPRESSOR
14 & 15 TON ROTALOCKS

