

# Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS  
 ONE CAPITOL HILL  
 PROVIDENCE RI 02908

**CREATION DATE :** 11-APR-13  
**BID NUMBER:** 7461357,1  
**TITLE:** Replacement of Air Handler & Condensing Unit at the State House, DOA  
  
**BID CLOSING DATE AND TIME:** 26-APR-2013 11:00:00

**BUYER:** Ohara 2nd, John F  
**PHONE #:** 401-574-8125


**B  
I  
L  
L  
T  
O**  
**DOA CONTROLLER**  
**ONE CAPITOL HILL, 4TH FLOOR**  
**SMITH ST**  
**PROVIDENCE, RI 02908**  
**US**

**S  
H  
I  
P  
T  
O**  
**DOA CENTRAL SERVICES**  
**ONE CAPITOL HILL, 2ND FLOOR**  
**SMITH ST**  
**PROVIDENCE, RI 02908**  
**US**

**Requisition Number:** 1308835  
**Amendment Description:** Addendum Number One

Line	Description	Quantity	Unit	Unit Price	Total
1	<p>Addendum Number One</p> <p>DUE TO A SCHEDULING ISSUE THERE WAS NOT A STATE CONTACT PERSON AT THE SITE VISIT HELD ON 4/10/13.</p> <p>THEREFORE A MANDATORY PRE-BID CONFERENCE HAS NOW BEEN SCHEDULED AS FOLLOWS:            WEDNESDAY 4/17/13 AT 10:00 AM            STATE HOUSE REAR PUBLIC ENTRANCE            82 SMITH ST.            PROVIDENCE, RI</p> <p>Vendors are to meet at the Capitol Police Sign-In Desk. From there they will be escorted to the Cafe.</p> <p>The Bid Closing Date &amp; Time has also been rescheduled:            From: 4/18/13 at 11:00 AM            To: 4/26/13 at 11:00 AM</p> <p>ALL vendors who wish to bid on this project MUST ATTEND the Mandatory Pre-Bid Conference 4/17/13.</p> <p>NOTE: Clarification to the specifications:</p> <p>The unit is a Trane 10 ton air handler and matching condenser, with a steam coil for heat. The voltage is 208-230 3 phase.</p> <p>The successful vendor will need to coordinate their work schedule with the State House staff in order not to interrupt the Legislative session.</p> <p><b>TOTAL COST FOR THE STATE HOUSE CAFE AIR HANDLER AND CONDENSING UNIT REPLACEMENT</b>            NOTE: Clarification to the Specifications:</p> <p>The unit is a Trane 10 ton air handler and matching condenser, with a steam coil for heat. The voltage is 208-230 3 phase.</p>	1.00	TOTAL		

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer



# Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS  
 ONE CAPITOL HILL  
 PROVIDENCE RI 02908

**CREATION DATE :** 11-APR-13  
**BID NUMBER:** 7461357,1  
**TITLE:** Replacement of Air Handler & Condensing Unit at the State House, DOA  
**BID CLOSING DATE AND TIME:** 26-APR-2013 11:00:00

**BUYER:** Ohara 2nd, John F  
**PHONE #:** 401-574-8125

**B**  
**I**  
**L**  
**L**  
**L**  
**T**  
**O**  
 DOA CONTROLLER  
 ONE CAPITOL HILL, 4TH FLOOR  
 SMITH ST  
 PROVIDENCE, RI 02908  
 US

**S**  
**H**  
**I**  
**P**  
**T**  
**O**  
 DOA CENTRAL SERVICES  
 ONE CAPITOL HILL, 2ND FLOOR  
 SMITH ST  
 PROVIDENCE, RI 02908  
 US

**Requisition Number:** 1308835  
**Amendment Description:** Addendum Number One

Line	Description	Quantity	Unit	Unit Price	Total
	SPECIFICATIONS  " REPLACE THE AIR HANDLER AND CONDENSING UNIT AT THE STATE HOUSE CAFE " UNIT NEEDS TO BE REPLACED USING THE EXISTING REFRIGERATION TUBING FROM THE CONDENSER LOCATION TO THE AIR HANDLER " THE EXISTING UNIT HAS A DX COOLING COIL AND A STEAM COIL FOR HEAT " REPLACEMENT SHOULD BE THE SAME  " REPLACE ALL CONDENSATE DRAINAGE AND ALL WIRING NEEDED TO MAKE UNIT FUNCTION AS DESIGNED " LEAK TEST AND CHARGE WITH REFRIGERANT AS NEEDED " REFRIGERATION LINE SHOULD BE LEAK TESTED AND REPAIRED IF NEEDED				

Delivery: \_\_\_\_\_

Terms of Payment: \_\_\_\_\_

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer