



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

5/23/13

RFQ #7464381

**Title: Transformer Replacement at the Henry Barnard School – Rhode Island
College Campus**


Submission Deadline: June 4, 2013 @ 10:15 AM local prevailing time.

Per the issuance of ADDENDUM #1 the following are noted:

- Questions and Clarifications
- Pre-Bid attendance sheet

Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.

Gary P. Mosca,
Buyer



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website:
www.purchasing.ri.gov

PRE-BID CONFERENCE

5/14/13

BID #7464381

**TRANSFORMER REPLACEMENT AT THE HENRY BARNARD SCHOOL – RHODE ISLAND COLLEGE
CAMPUS**

VENDOR QUESTIONS AND CLARIFICATIONS

- 1) Are any drawings available?

Response: No

- 2) Is transformer live front?

Response: Yes

- 3) Scope of work specifies loop feed. Shall vendors provide as specifies?

Response: Yes

- 4) Has oil been taken from transformer? Has oil been tested?

Response: No. Owner is responsible for testing oil. Owner will have MPA vendor test oil and possibly dispose of transformer. If oil is clean awarded vendor will dispose of transformer. If oil is contaminated Owner will take responsibility to dispose transformer.

NOTE: Rhode Island College will work concurrent with awarded contractor regarding oil containment. Any site work outside of scope will be handled by Rhode Island College.

- 5) Is vendor responsible to replace pad?

Response: In order to properly level unit the pad must be replaced. Vendor is to replace pad as part of this project.

NOTE: Spill containment will be set up by College.

- 6) Is there a date of transformer manufacture, or Blue Tag?

Response: Cannot locate this information.

NOTE: Project to commence on a Friday and continue next day Saturday and Sunday.

- 7) Is fire pump on a generator?

Response: Yes

End Document

RFP# 7464381- TRANSFORMER REPLACEMENT HENRY BARNARD SCHOOL - RIC

MAY 14, 2013 @ 9:15 AM - Pre-Bid Meeting Attendance

	Company	Representative	Address	Email	Phone
1.	Robert F. Aulet	S Lumbryg	2883 South comby Trail East Greenwich	SLandry@rf-aulet. netcom.net.com	401-561-5070
2.	K ELECTRIC	DAVE KIOZ	2646 WARWICK AVE. WARWICK, R.I. 02884	DAVE@KELECTRIC AOL.COM	401-737-6000
3.					
4.					
5.					
6.					
7.					
8.					
9.					
10.					
11.					
12.					