



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387
4/29/10

ADDENDUM # 1

RFQ # 7464391

BID TITLE: FIRE SPRINKLER AND FIRE ALARM UPGRADE PROJECT – DCYF

OPENING DATE AND TIME: 6/11/2013 @ 2:00 PM

PER THE ISSUANCE OF THIS ADDENDUM #1

(2 PAGES INCLUDING THIS COVER SHEET)

**CHERYL MCGURN
BUYER II**

Hughes Associates, Inc.
New England Office
117 Metro Center Boulevard, Suite 1002
Warwick, RI 02886
Tel: 401-736-8992
Fax: 401-736-8929

Addendum #1

To: All Bidders

CC: Wade Palazini – State Fire Marshal's Office

From: Mark J. Blackburn, P.E., CFPS

Date: January 30, 2013

Subject: ACE Building, 220 New London Avenue, Cranston, RI
Automatic Fire Sprinkler and Fire Alarm System
Addendum #1

Project No. 1MJB00220.000

Bidders,

Please allow this memorandum to serve as Addendum #1 for the fire sprinkler and fire alarm system installation project at the ACE Building located at 220 New London Avenue in Cranston, RI.

The Contractor shall include all labor, materials, programming and testing to install the following:

1. One (1) addressable smoke detector in the main entrance lobby in the immediate vicinity of the fire alarm control unit.
2. One (1) mini-horn notification appliance in the dorm room in the south wing adjacent to the bathroom.
3. One (1) addressable smoke detector in the day room.

All bidders must acknowledge receipt and compliance with this addendum in their bid.