STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

May 29, 2013

ADDENDUM NUMBER ONE
RFQ # 7467366

TITLE: Purchase and Install Generator and Transfer Switch-Quonset Point

Closing Date and Time: 6/7/13 at 10:00AM

Per the issuance of this ADDENDUM #1
(Total 3 pages)

[X] **Specification Change /Addition / Clarification**

Attached is sign in sheet from Mandatory pre bid held 5/29/13 at 9am.

Attached is bollard specification. Total of three (3) will be required.

All vendor employees/representatives must be cleared through a BCI check before being authorized to work in the building. All BCIs to be performed at the vendor's expense.

Awarded vendor will be required to notify agency 24 hours prior to working on site to insure representative of agency is present.

Vendor will give agency 24 hour notice prior to shutting down any power in order to connect/disconnect service.

Permits will be required. Contractor is responsible for complying with all federal and state codes.

Annunciator is Generac model 5465.

STANDARD DETAILS & SPECIFICATIONS

SUBJECT: Specifications for the installation of bollards for private fire protection equipment, generators, and fuel tanks

BOLLARD DETAIL



HYDRANT POST LOCATIONS

Bollards shall be three (3) feet minimum from the face of fire hydrant. All orifices shall be unobstructed.



GENERATOR/FUEL TANK POST LOCATIONS

Bollards shall be five (5) feet minimum from the face of fire hydrant.



3000 PSI concrete will be used; bollards will be covered with safety yellow bollard sleeves. Due to location restrains on-site modification to specifications can be authorized by the construction supervisor

State of Rhode Island
Division of Purchases
One Capitol Hill
Providence, RI 02908

"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

Purchasing Representative: CADORET
Mandatory Pre-bid START TIME: 9:03
Mandatory Pre-bid END TIME: 9:30

BID NUMBER: 7467366
BID TITLE: PURCHASE AND INSTALL GENERATOR x TRANSFER SWITCH - QUONSET PT
PRE-BID DATE AND TIME: 5/29/13 9AM

	COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
1	Allied	A. Giuliano	528 Charles St. Riv RI	andrew@alliedectrealgroup.com	401-413-3757	401-351-8811	
2	CALSON CORP.	STEVE CAPOZZOLI	34 OAKDALE AVE JOHNSON	STEVEC@CALSONCORP.COM	401-272-1100	401-272-0035	
3	Nolin Elec	Joe Therien	62A Danielson Pk	joe@nolinelectrical.com			
4	FALL RIVER ELECTRICAL ASSOCIATES CO. INC	ALFRED D. MYETE	74 CORNEAU ST FALL RIVER MA	almyette@trea.biz	401-640-0548 508 675-0523	(508) 674-2824	
5	CACI Hyllested	MYRA A. STATE					
6	PURCHASING	DAVID CADORET					
7							
8							
9							
10							
11							
12							
13							

Updated 4/30/13

** VENDOR: PLEASE SUBMIT A BUSINESS CARD IF AVAILABLE