Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
ONE CAPITOL HILL
PROVIDENCE RI 02908

CREATION DATE : 01-OCT-13
BID NUMBER: 7517365
TITLE: WELL PUMP-CONTROL PANEL UPGRADE-COVENTRY NATIONAL GUARD STATION

BID CLOSING DATE AND TIME:14-NOV-2013 10:30:00

BUYER: Cadoret, David
PHONE #: N/A

BILL TO
DOA CONTROLLER
ONE CAPITOL HILL, 4TH FLOOR
SMITH ST
PROVIDENCE, RI 02908
US

SHIP TO
MS-ANG ORGANIZATIONAL MAINTENANCE SHOP #1
READ SCHOOLHOUSE RD
COVENTRY, RI 02816
US

Requistion Number: 1338149
Note to Bidders: THERE WILL BE A MANDATORY PRE BID CONFERENCE AS INDICATED ON ATTACHED PAGE.

Line	Description	Quantity	Unit	Unit Price	Total
1	Coventry - Well Pump Control Panel Upgrade as per attached specifications	1.00	Each		

Delivery: _____

Terms of Payment: _____

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer

State of Rhode Island

Department of Administration
Division of Purchases
One Capitol Hill
Providence, RI 02908

REQUEST FOR QUOTE (RFQ) – BID# 7517365

WELL PUMP-CONTROL PANEL UPGRADE-COVENTRY NATIONAL GUARD STATION

SUBMISSION DEADLINE: Wednesday, November 14, 2103 at 10:30 AM (ET)

PRE-BID CONFERENCE: ☐ **NO**
☒ **YES** **Thursday, November 07, 2013 at 9:00 AM (ET)**

Mandatory: ☐ **NO**
☒ **YES:** Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

Location: **Coventry National Guard Base**
570 Read Schoolhouse Rd.
Coventry, RI 02816
This is a secure military facility. Once we leave the gate area no additional vendors will be allowed to sign in.

Buyer Name: **David A. Cadoret**
Title: **Chief Buyer**

SURETY REQUIRED: **NO**

BOND REQUIRED: **NO**

PUBLIC COPY (R.I. Gen. Law 37-2-18(j): This requirement applies to all public works projects (vertical and horizontal) exceeding Five Hundred Thousand ($500,000) dollars and any combination of base bid plus all alternates.

DISK BASED BID: ☒ **NO**
☐ **YES:** See attached Disk Based Bidding Information

THIS IS NOT A BIDDER CERTIFICATION FORM

State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

BID SPECIFICATIONS 7517365
WELL PUMP-CONTROL PANEL UPGRADE-COVENTRY NATIONAL GUARD STATION

Scope of Work for Design and Refit of Well Pump Controls, Well Pump Replacement, and Analytical Testing

BACKROUND

Project Location: Coventry National Guard Base, 570 Read Schoolhouse Road, Coventry, RI.

The Rhode Island Army National Guard's Coventry Base operates a non-transient, non-community, public water system that provides potable water to multiple buildings on site. The system is comprised of four drilled wells, a 12,000 gallon fiberglass underground storage tank, corrosion control system (CCS), and associated distribution piping. Currently, the system is in need of upgrades with respect to: Well Pump Controls and Well #2 Pump. Existing controls are not set up appropriately and may be contributing to pump damage. Additionally, the pump in Well #2 is undersized and in need of replacement.

SCOPE of WORK

Project shall include the following:

1. Well Pumps Control- Design and Installation:
   A. Design and build pump control panel (PLC) to operate (4) well pumps and high and low water storage tank levels.
   B. Procure PLC control panel and water storage tank instrumentation.
   C. Provide delivery, installation, and start-up services.

2. Well #2 Pump Replacement:
   A. Remove existing submersible pump, pump wire and riser pipe.

   B. Replace submersible pump (and associated equip) with the following:

      - One (I) Goulds 5GSI 0422 submersible pump (or equivalent)
      - 300ft of 10/2 submersible pump wire.

State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

BID SPECIFICATIONS 7517365
WELL PUMP-CONTROL PANEL UPGRADE-COVENTRY NATIONAL GUARD STATION

Scope of Work for Design and Refit of Well Pump Controls, Well Pump Replacement, and Analytical Testing

- 300 ft of 1 1/4 inch polyethylene riser pipe.
- Installation parts, torque arrester, wire splice kits, clamps. Etc.

C. Installation of 1 1/4 inch polyethylene stilling tube for future well water level testing.

D. Supply onsite licensed operator and pump installation services.

E. Provide post-installation sanitization services followed sample collection for Coliform Bacteria testing.

3. Pre-Startup Required Analytical:

A. Total Coliform

B. Inorganic Compounds (IOCs)

C. Nitrate

D. Fluoride

E. VOCs

G. SOCs

4. NOVs or fines issued to RIARNG for failure to perform work within this scope will be responsibility of contractor.

5. This project may require confined space entry.

REQUEST FOR QUOTE #7517365

RIVIP

IT IS THE VENDOR'S RESPONSIBILITY TO CHECK AND DOWNLOAD ANY AND ALL ADDENDA FROM RIVIP. THIS OFFER MAY NOT BE CONSIDERED UNLESS A SIGNED RIVIP GENERATED BIDDER CERTIFICATION COVER FORM IS ATTACHED AND THE UNIT PRICE COLUMN IS COMPLETE. THE SIGNED CERTIFICATION COVER FORM MUST BE ATTACHED TO THE FRONT OF THE OFFER. WHEN DELIVERING OFFERS IN PERSON TO ONE CAPITOL HILL, VENDORS ARE ADVISED TO ALLOW AT LEAST ONE HOUR ADDITIONAL TIME FOR CLEARANCE THROUGH SECURITY CHECKPOINTS.

THIS OFFER MAY NOT BE CONSIDERED UNLESS BIDDER CERTIFICATION COVER FORM IS ATTACHED AND THE UNIT PRICE COLUMN IS COMPLETED. THE SIGNED CERTIFICATION COVER FORM MUST BE ATTACHED TO THE FRONT OF THE OFFER. WHEN DELIVERED OFFERS ON PERSON TO ONE CAPITOL HILL, VENDORS ARE ADVISED TO ALLOW AT LEAST ONE HOUR ADDITIONAL TIME FOR CLEARANCE THROUGH SECURITY CHECKPOINTS.

VENDOR SPEC

ALL VENDORS MUST INCLUDE SPECIFICATIONS WITH BID PROPOSAL (EVEN THOSE BIDDING BRAND SPECIFIED). FAILURE TO SUBMIT SPECIFICATIONS WITH BID PROPOSAL MAY RESULT IN DISQUALIFICATION OF BID. ITEMS IN CATALOGS MUST BE CLEARLY MARKED AND PAGES TABBED.

AWARD

THE STATE, AT ITS SOLE DISCRETION, SHALL RESERVE THE RIGHT TO MAKE ONE OR MULTIPLE AWARDS FOR THIS REQUIREMENT AND/OR TO REJECT ANY OR ALL BIDS.

DELIVERY

DELIVERY OF GOODS OR SERVICES AS REQUESTED BY AGENCY.

INSURANCE

AN INSURANCE CERTIFICATE IN COMPLIANCE WITH PROVISIONS OF ITEM 31 (INSURANCE) OF THE GENERAL CONDITIONS OF PURCHASE IS REQUIRED FOR COMPREHENSIVE GENERAL LIABILITY, AUTOMOBILE LIABILITY, AND WORKERS' COMPENSATION AND MUST BE SUBMITTED BY THE SUCCESSFUL BIDDER(S) TO THE DIVISION OF PURCHASES PRIOR TO AWARD. THE INSURANCE CERTIFICATE MUST NAME THE STATE OF RHODE ISLAND AS CERTIFICATE HOLDER AND AS AN ADDITIONAL INSURED. FAILURE TO COMPLY WITH THESE PROVISIONS MAY RESULT IN REJECTION OF THE OFFEROR'S BID. ANNUAL RENEWAL CERTIFICATES MUST BE SUBMITTED TO THE AGENCY IDENTIFIED ON THE PURCHASE ORDER. FAILURE TO DO SO MAY BE GROUNDS FOR CANCELLATION OF CONTRACT.

FISCAL YEAR

AWARDS EXTENDING BEYOND JUNE 30TH ARE SUBJECT TO AVAILABILITY OF FUNDS. CONTINUATION OF THE CONTRACT BEYOND THE INITIAL FISCAL YEAR WILL BE AT THE DISCRETION OF THE STATE. TERMINATION MAY BE EFFECTED BY THE STATE BASED UPON DETERMINING FACTORS SUCH AS UNSATISFACTORY PERFORMANCE OR THE DETERMINATION BY THE STATE TO DISCONTINUE THE GOODS/SERVICES, OR TO REVISE THE SCOPE AND NEED FOR THE TYPE OF GOODS/SERVICES; ALSO MANAGEMENT OWNER DETERMINATIONS THAT MAY PRECLUDE THE NEED FOR GOODS/SERVICES.

WAGE

BIDDERS ARE ADVISED THAT ALL PROVISIONS OF TITLE 37 CHAPTER 13 OF THE GENERAL LAWS OF RHODE ISLAND APPLY TO THE WORK COVERED BY THIS REQUEST, AND THAT PAYMENT OF THE GENERAL PREVAILING RATE OF PER DIEM WAGES AND THE GENERAL PREVAILING RATE FOR REGULAR, OVERTIME, AND OTHER WORKING CONDITIONS EXISTING IN THE LOCALITY FOR EACH CRAFT, MECHANIC, TEAMSTER, OR TYPE OF WORKMAN NEEDED TO EXECUTE THIS WORK IS A REQUIREMENT FOR BOTH CONTRACTORS AND SUBCONTRACTORS. THE PREVAILING WAGE TABLE MAY BE OBTAINED AT THE RI DIVISION OF PURCHASES HOME PAGE BY INTERNET AT www.purchasing.state.ri.us . SELECT "INFORMATION' AND THEN SELECT "PREVAILING WAGE TABLE". THE STATE OF RHODE ISLAND USES THE GENERAL DECISION NUMBER R120030001. PRINTING THE ENTIRE DOCUMENT AVERAGES APPROXIMATELY ONE MINUTE PER PAGE. YOU MAY WANT TO PRINT ONLY THE PAGES APPLICABLE TO YOUR BID. BIDDERS NOTE: IN THE EVENT THIS BID SPECIFIES PRICE OFFERS ON A

TIME-AND-MATERIAL BASIS, ie., AN HOURLY RATE, ANY OR ALL BIDS SUBMITTED IN AN AMOUNT LESS THAN THE PREVAILING RATE IN EFFECT FOR WORK COVERED BY THIS REQUEST AS OF THE DATE OF BID ISSUANCE SHALL BE REJECTED BY THE DIVISION OF PURCHASES.

LICENSE

VENDOR (OWNER OF COMPANY) IS RESPONSIBLE TO COMPLY WITH ALL LICENSING OR STATE PERMITS REQUIRED FOR THIS TYPE OF SERVICE. A COPY OF LICENSE/PERMIT SHOULD BE SUBMITTED WITH THIS BID. IN ADDITION TO THESE LICENSE REQUIREMENTS, BIDDER, BY SUBMISSION OF THIS BID, CERTIFIES THAT ANY/ALL WORK RELATED TO THIS BID, AND ANY SUBSEQUENT AWARD WHICH REQUIRES A RHODE ISLAND LICENSE(S), SHALL BE PERFORMED BY AN INDIVIDUAL(S) HOLDING A VALID RHODE ISLAND LICENSE.