



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

November 15, 2013

ADDENDUM NUMBER ONE
RFQ # 7525365

TITLE: Pump Replacement at Fort Adams Mule Barn-DEM

Closing Date and Time: 11/27/13 at 11:00 AM

Per the issuance of this ADDENDUM #1 (total of 3 pages) the following is noted:

The sign in sheet from the non-mandatory pre bid conference held 11/15 at 10:30 am is attached.

Notes from meeting:

- Brackets to support pipe (in lift station) need to be replaced.
 - Pump will be connected to new power supply already in lift station.
 - All utilities in building are presently being shut down. Please be aware awarded vendor will be expected to return in the spring when the building is opened again to ensure installation is in working order.
 - The depth of the sump is approximately 10-12" below the pump.
 - The existing two steel covers will be replaced with one steel cover (3/8" thick), 68" long x 36" wide. The new plate will be anchored by ten (10) 3/8" bolts with appropriate anchors into the existing steel frame. Holes in plate will be beveled to allow heads to sit lower into plate. There will be a small hand hole cut into one end of the plate. The underside of this hole will have a cup welded to it to prevent water from draining into the lift station. There will be a piece of rod welded across this hand hold to allow cover to be lifted.
- DEM will be responsible for making sure the parking lot is even with new plate.
- The prevailing wage table may be obtained at the Rhode Island Division of Purchases home page by internet at www.purchasing.ri.gov. Select "Bidding Information", then "General Information" and then select "Prevailing Wage Table". The State of Rhode Island uses the general decision number ri20100001. Printing the entire document averages

November 15, 2013

ADDENDUM NUMBER ONE

RFQ # 7525365

TITLE: Pump Replacement at Fort Adams Mule Barn-DEM

Closing Date and Time: 11/27/13 at 10:00 AM

approximately one minute per page - you may want to print only the pages applicable to your bid. Bidders note: in the event this bid specifies price offers on a time-and-materials basis, i.e., an hourly rate, any or all bids submitted in an amount less than the prevailing rate in effect for the work covered by this request as of the date of bid issuance shall be rejected by the Division of Purchases.

NO FURTHER QUESTIONS WILL BE TAKEN.



State of Rhode Island
 Division of Purchases
 One Capitol Hill
 Providence, RI 02908

"NON-MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

BID NUMBER:	7525365
BID TITLE:	PUMP REPLACEMENT AT FORT ADAMS MULE BARRI-DEN
PRE-BID DATE AND TIME:	11/15/2013 AT 10:30AM

Purchasing Representative:	DCADORET
Pre-bid START TIME:	10:30
Pre-bid END TIME:	11:00

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
1 Delta Electro Pwr	Randy Reis	315 Niantic Ave P.O. Box 100 Cranston RI 02906	randy@delta.com	401-944-8350	401-944-8380	
2 THELSCH ENG.	JEFF GOUART	195 FRANCES AVE N-Kingswood Cranston RI 02906	jeffgouart@thielsh.com	401-632-7830	401-461-6006	
3 LIGHTSHIP GROUP	HARRY DELUCA	606 TEN LOD RD 37 William S Cranston RI 02906	LIGHTSHIP GROUP HARRY@LIGHTSHIP.COM	401-295-2416	401-295-5484	
4 F.R.S	Allyn Casvalho	37 William S Cranston RI 02906	Allyn@FRS.com	401-419-6708	-	
5 DEM. BNR	CARMIND PELICHA					
6 DEM PR	BRUCE THOMPSON	80 E. A. DR.				
7 STATE PURCHASING	DAN CARNEY					
8						
9						
10						
11						
12						
13						
14						
15						