



State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387

**March 14, 2014**

**Addendum Number Two**

**RFQ: 7548502**

**Emergency Culvert Repair/Replacement Fish Hill Road,  
Coventry, RI, DOA**

**Closing Date and Time: March 24, 2014 at 2:00 PM**

**This Addendum #2 is (4) pages, including this cover sheet.**

### **Specification Change/Addition/Clarification**

Notes from the Pre bid conference:

These items (as they pertain to the bid process) were discussed by purchasing representative at the pre bid conference:

- This was a non-mandatory pre bid conference.
- Questions were being accepted on line. Date/time and address are specified in bid form.
- Bid bond is required. Payment and Performance bond is required.
- The public copy requirements were explained.
- Vendors were advised to review the seven page Public Works Bid Clauses.
- Vendors were advised that this was a prevailing wage job and the requirement to submit the prevailing wage certification.
- Vendors were advised of the Bid Preparation Checklist and that it is not a substitute for a thorough review of the bid proposal by the vendor.
- Vendors were asked to submit a W-9 with their bid proposal.

Romeo Mendes gave the scope of work to be performed.



**State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387**

-State will secure all necessary permits and will coordinate closing of required section of Fish Hill Rd with Town of Coventry officials (Town Engineer, Public Works, Police and Fire). The contractor will be responsible for obtaining and installing all detour and warning signs.

-For bidding purposes assume the following. Award will go to low bidder.

1. Precast Single Barrel Culvert measuring 24" x 48" x 240".
2. Pavement replacement will measure 8' x 20'.
3. Total of 100' of guard rail including 4 end treatments to be installed.

-Average and max flows observed in the brook are 7.23 cfs and 17.7 cfs respectively. Bypass may not need to be done depending on the flow.

-Awarded vendor to provide schematic showing preliminary design elements including but not limited to culvert sizing and installation details, length of guardrail and asphalt replacement at beginning of project. Lump sum cost to complete the project must accompany the schematic and will be the basis for the Purchase order to be issued by the State. A set of as-builts stamped by an engineer registered in the State of Rhode Island is required to be provided at end of project.

-Follow RIDOT Bluebook standards regarding culvert replacement/installation.

-Project should be completed by 5/30/14 to allow for processing of payment before fiscal year end close of 6/30/14.

-Following question was submitted on line:

Q. You indicate repair an option to fix Fish Hill Road, in specs you only call for full culvert replacement. New York State DOT has approved a fiberglass UV Cured CIPP for storm culvert rehabilitation that DOES Not have any impact on environmentally sensitive areas and does not need a full dig and replace. I would like to bid this project with this option and want to make sure it will be accepted against replacement.

A. Pipe replacement and/or lining would only address part of the problem that is why the WRB specified installation of a culvert structure. The culvert option allows all issues to be taken care of in one project effort. So the answer is no, the cured CIPP would not be accepted in lieu of replacement.

Attached is a copy of the sign-in sheets from the conference.



State of Rhode Island  
 Division of Purchases  
 One Capitol Hill  
 Providence, RI 02908

**"NON-MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET**

<b>BID NUMBER:</b>	75-48502
<b>BID TITLE:</b>	EMERGENCY CULTVERT REPAIR/REPLACEMENT FISH HILL RD., COVENTRY, RI-DOA
<b>PRE-BID DATE AND TIME:</b>	3/11/2014 AT 2:00PM

<b>Purchasing Representative:</b>	DCADORET
<b>Pre-bid START TIME:</b>	2:00
<b>Pre-bid END TIME:</b>	2:30

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT EMAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED FOR Purchasing Job (City)
SumCo Eto Cont.	Domingos Roda	16 Front St Salem, MA 01970	AradaCSomcoe.com	978-744-1515	815-572-5022	
BETA Group, Inc	KEVIN AGUIAR	4 Blackstone Valley Lincoln RI 02861	Kagovic beta-inc. car	401-258-9331	401-333-1982	
Noraspac Imp. Co.	Sosh Carr	223 Allens Ave Prov. RI 02903	scarremerican.com	401 331 - 7420	401 331 - 6444	
PRECISION TRO	MIKE APP	1710 ERIE BLVD SHEWANMINN MN	MARPO PIM-INL.COM	315 715 1273	518 346 5800	
NEBB	Peter Donatelli	14 B 6th Ind Parkway Riverside	Pdonatelli@nebb.com	401-830-5774	401-830-5776	
CONCRETE	Lee Taylor	500 Signon Ave Woonsocket RI 02895	L.Taylor@concrete.com	401-737-1300	401 732-7725	

