



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 2

3/10/14
Solicitation #7548536

Title: Furnish and Install One Standby Generator @ D.O.T. Middletown Facility

Submission Deadline: March 27, 2014 @ 2:00 PM (ET)

Per the issuance of ADDENDUM # 2 the following are noted:

Revision: (See Attached)

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.


Lisa Hill
Chief Buyer

**Rhode Island Department of Transportation
Division of Highway and Bridge Maintenance
Middletown Facility
Town of Middletown
Standby Generator**

Contract Addendum 2

Revision:

1. Revise generator size from 60kw/75kva 120/240V single phase to 45kw/56kva 120/240 single phase. Circuit breaker size at generator will be 200A/2P.
2. Remove main bonding jumper, and separate ground from neutrals in existing main panel per NEC article 250.24.
3. Revise ground wire from #6 AWG to #4 AWG.
4. Furnish and install a nameplate on main switch indicating alternate power source from generator.
5. Furnish and install a monitor module installed on the existing fire alarm system to indicate generator run status. Run status to be programmed as a supervisory signal only. Provided all required appurtenances required for a complete and operational system. Furnish and install ½" conduit from the automatic transfer switch to monitor module/fire alarm control panel. Include in the bid, cost for a factory representative for final tie in and any required programming.