



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

June 2, 2014

**ADDENDUM NUMBER THREE**

**RFQ # 7548703**

**TITLE: Renovations to Floors 4, 5 and 6 and Heating System Upgrades at Regan Building**

**Closing Date and Time: 6/10/14 at 2pm**

**Per the issuance of this ADDENDUM #1 ( 1 page) the following is noted:**

On drawing A2.1 – A2.3, Door note 5C states to reuse existing hardware in new doors but note 2.05 – A in Specification Section 087100 states to provide all new locksets at all patient room doors.

CLARIFICATION: Note 5C on drawings A2.1 through A2.3 shall be revised as follows: “Existing hardware shall be removed and reinstalled on new doors, including hinges, door stops, closers and other miscellaneous hardware that may exist. New locksets shall be installed on new doors in accordance with the specifications. Contractor shall fill and patch holes from abandoned or relocated hardware.”

**END OF QUESTIONS**