



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

**June 26, 2014**  
**ADDENDUM NUMBER TWO**  
**RFQ # 7548764**

**TITLE: Replace Existing Door Control/Intercom System at Women's Gloria MacDonald Facility**  
**Closing Date and Time: 7/3/14 at 10:30AM**

**Per the issuance of this ADDENDUM #2 (4 pages) the following is noted:**

- This addendum posts the sign in sheet from the second mandatory pre bid conference held 6/24/14 at 10am.
- Buyer went over the following:
  - This was a mandatory pre bid.
  - Bid surety is required. The awarded vendor will have to provide a 100% payment and performance bond.
  - This is a public works project and requires a public copy as outlined in bid specifications.
  - Note bid clauses as they pertain to public works projects.
  - Note requirements as they pertain to working in a correctional facility.
  - This is a prevailing wage project. Certification form in bid package acknowledging prevailing wage should be submitted with bid proposal.
  - Please submit updated W-9 (included in bid package).
- Attached is form to submit with bid for alternate pricing for an additional PLC touchscreen. This form must be submitted with bid proposal or your bid may be deemed non-responsive.
- Attached is acknowledgement of addendum (a) form. This form must be submitted with your bid proposal or your bid may be deemed non-responsive.

**STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS**

**Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855**

**June 26, 2014  
ADDENDUM NUMBER ONE  
RFQ # 7548764**

**TITLE: Replace Existing Door Control/Intercom System at Women's Gloria MacDonald Facility**

-These questions were submitted on line.

Q. Are network switches required to support the new PLC touchscreen control stations and PLC controllers? If so, please provide a recommended manufacture and model number.

A. Network Equipment

a. Core Switch

i. Provide a layer 3, core network switch as required for all edge switches. The switch shall be configured to support twenty (20) PoE 10/100/1000 ports and twelve (12) fiber SFP ports. Each fiber port shall support 1000GB.

ii. The switch shall be rack mounted in the main security closet.

iii. The switch shall support redundant power supplies.

iv. Provide HP 5400 series or approved equal. Provide fiber

GBIC cards as required to support each IDF and/or security closet.

b. Edge switch

i. Provide a 24-port PoE, rack mounted, network switch as required.

ii. Provide a fiber GBIC card for each edge switch.

iii. Provide HP 2600 series or approved equal.

2. Other than central control, please confirm if PLC touchscreen control stations are required at any other area of the facility.

A. See attached bid alternate sheet.

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

June 26, 2014  
ADDENDUM NUMBER TWO  
RFQ # 7548764

**TITLE: Replace Existing Door Control/Intercom System at Women's Gloria MacDonald Facility**

**ALTERNATE: (Additions/Subtractions to Base Bid Price)**

The Bidder offers to : (i) perform the work described in these Alternates as selected by the State in the order of the priority specified below, based on the availability of funds and the best interest of the State: and (ii) increase or reduce the Base Bid price by the amount set forth below for each Alternate selected.

Check "add" or "Subtract"

\_\_\_\_ Add \_\_\_\_ Subtract     Alternate 1: Furnish and install one (1) PLC touchscreen control station. It will not be more than 1000' feet from control center.

\_\_\_\_\_  
(Amount *in figures* printed electronically, typed, or handwritten legibly in ink)

\_\_\_\_\_  
(Amount *in words* printed electronically, typed, or handwritten legibly in ink)

**ACKNOWLEDGEMENT OF ADDENDUM(A):**

I have received and reviewed the following addendum(a) that pertain to this bid.

Addendum Number \_\_\_\_\_ Dated \_\_\_\_\_

Addendum Number \_\_\_\_\_ Dated \_\_\_\_\_

Signed \_\_\_\_\_ Dated \_\_\_\_\_

Title \_\_\_\_\_

**This sheet must be submitted with your bid proposal. Failure to do so may result in your bid being considered NON-RESPONSIVE.**



**"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET**

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

BID NUMBER	7548764
BID TITLE	Replace Existing Door/Intercom System at Women's Gloria MacDonald Facility
PRE-BID DATE AND TIME	June 24, 2014 at 10am

Purchasing Representative	Deadoret
Mandatory Pre-bid START TIME	10:00
Mandatory Pre-bid END TIME	10:05

	COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
1	STATE PURCHASING	David Cadoret					
2	PASADAN	Bill Salisbury		pasadan services@yahoo.com	401 935-6919		
3	Signet Electronics	Jason Bianco		<del>pasadan services@yahoo.com</del>			
4	<del>Anthony</del> DOC	Anthony Fella			402-3006		
5	DOC	Dena Scarfos			402-3006		
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							