



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #1

RFQ# 7549040

TITLE: EXTERIOR BLOCK WALL REPAIRS/OFFICE COATINGS – DOT MIDSTATE FACILITY

SUBMISSION DEADLINE: 10/23/14 – 10:30 A.M.

Prospective bidders and all concerned are hereby advised of the following changes/modifications in the Contract Documents for the above referenced Contract and are hereby requested to change their copies accordingly. Delete the third page of the contract in its entirety and replace it with the attached new page.

THIS ADDENDUM INCLUDES:

- **ONE (1) PAGE OF THE CONTRACT CONSTRUCTION METHODS. THE ADDENDUM REVISES THE CONSTRUCTION METHODS THAT ARE ADDITIONS TO BE ADDED TO THE SECTION ON THE THIRD PAGE OF THE CONTRACT. SEE ATTACHED.**
- **MANDATORY PRE-BID CONFERENCE ATTENDANCE SHEET**

A handwritten signature in black ink, appearing to read "Lisa Hill".

Lisa Hill
Chief Buyer

Bidders must include a signed copy of this addendum with their proposal submission as acknowledgement.

Company Name (print)

Signature of Authorized Representative

Mid-State Maintenance Facility

2400 New London Turnpike, East Greenwich RI

CONSTRUCTION METHODS

Sealant Repair

1. All Dissimilar Materials to be caulked with with bead, up to 3/4" wide including steel columns to CMU block joints, use Sikaflex 2C NS
2. Cracks repairs in block - cracks <1/16" wide to be vee sawcut and caulked with flush tooling, use Sikaflex 2C NS

Block Protective Coating

3. Detail cracks and joints and coat exterior block walls with Sikagard 550W. Color to be selected by owner , use Sikagard 550W, 2 coats @ 100sf/gal/coat. At exterior walls that were previously coated, only one coat is required per technical data sheet.

Steel Coating

4. Pigmented Protective Coating on exterior exposed steel to be Rustoleum or an approved equal. Color to be selected by owner. Use primer and, 2 finish coats of commercial grade steel coating.

Epoxy Coating

5. Epoxy Broadcast System on interior office floors as outlined by owner. Remove existing coating(s), Mechanically prep floor and apply Hi-build epoxy. Hi-build epoxy system, use Sikagard 62 Epoxy Broadcast System.

ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.

Remove and Replace cove base at perimeter walls of rooms to be coated with new epoxy floor coating. Cove to match existing in color and material.

All work shall be in conformance with the manufactures specifications.

Solicitation #7549040 Addendum No. 1

Page 2 of 2



State of Rhode Island
Division of Purchases
One Capitol Hill
Providence, RI 02908

"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its representative attend this mandatory prebid conference, sign, and complete all required information on this Sign-in Sheet. Failure to comply with this requirement will result in the rejection of any bid proposal.

BID NUMBER: 7549040

BID TITLE: Exterior Block Wall Repairs

PRE-BID DATE AND TIME: 10/8/14 - 9:00 a.m.

Purchasing Representative: *JK*

9:05 AM

Mandatory Pre-bid START TIME:

Mandatory Pre-bid END TIME:

9:35

COMPANY NAME	COMPANY REPRESENTATIVE	SIGNATURE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER AND FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
IRON CONSTRUCTION	Abdell Elsamabi	<i>[Signature]</i>	875 Centerville Rd Warwick	AME@ICGRI.com	401-481-8890	
CGRT	Nick	<i>[Signature]</i>	5 th Greenapple	Mick@efodonnell.com	401-349-2409	
DIAMARCO TRONS GOSMA CONST.	Dave Wildcare	<i>[Signature]</i>	46 GARDNER WARWICK RI	hdwildcare@gmail.com	401-232-0562	
DERZ LIMAT	Tom PACUJA	<i>[Signature]</i>	1002 CHOWS ST N. PAN. RI 02904	ADP@GOSAL @AOL.COM	732-1770 617-368-0000 401-725 9020	
Brad Doyle	Packhem Painting	<i>[Signature]</i>		663-4249		
Corner Stone Restoration Inc	Brad Doyle	<i>[Signature]</i>	24 Lisade Ln Burrington Pt	Corner Stone Restoration @ Cox.net	401-247-8000	
E.F. O'Donnell & Sons	Nick Deschones	<i>[Signature]</i>	75 Dike St PROV, RI 02909	mick@efodonnell.com	401 351-8503 621-9710	
WARWICK PAINTING Co.	Bob Vaughn	<i>[Signature]</i>	63 MARIOW ST WARWICK, RI 02908	TRAVAGNAC WARWICKPAINTING.COM	401-789 3443 401 339 3547	
ALPHA OMEGA Const	Fred of the Tequila	<i>[Signature]</i>	PO Box 14193 FA - Prov. RI 02914	Fred@AlphaGroup.net	401 486-4437 502 399-7345	
Tower Construction	Carl Nordstrom	<i>[Signature]</i>	288 LINCOLN AVE WARWICK RI 02988	sa@towerconstruction.com	401-943-0110 401-944-4041	
SIKA CORP	DAVID CLANK	<i>[Signature]</i>		CLANK.E.PAVID @US.SIKA.COM	401 952-323	