



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

January 29, 2015

ADDENDUM 1

RFQ # 7549256: MAINTENANCE & BATTERY REPLACEMENT

Vendor Questions / State Responses

1) Question

Please provide serial numbers of all units in the State of Rhode Island.

Response: Serial numbers of all units:
Serial #'s 1PNK06009, 1PNK06008, 1PNK09002 & 1PNK09004

2) Question

Can someone provide the battery part number?

Response: Battery part number is not available

3) Question

Is the battery replacement normal business hour or is it off hours.

Response: Normal business hours

4) Question

What is the KVA for each of the UPS units provided in the bid.

Response: Two of the units are 80 KVA and two of the units are 40 KVA