



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

February 16, 2015

ADDENDUM NUMBER ONE

RFQ # 7549306

TITLE: Renovations to the Blind Facility at the Shepard Building, Prov., RI

Closing Date and Time: 3/4/15 at 2:00 PM

Per the issuance of this **ADDENDUM #1** (2) pages, including this cover sheet)



Specification Change / Addition / Clarifications

Listed below are the questions with the answers we received from vendors to this date.

1. Are there any allowances for the project?
 - **No.**
2. Documents indicate that the "bidder must have documented experience with Kitchen/Restaurant projects of similar scope and value". Is there a qualification form that should be filled out and submitted with bid?
 - **Narratives are to be provided by the bidding contractors stating their experience with similar past projects. Please list the project, a reference phone number and the total value of the individual project.**
3. Will signage be installed by the GC?
 - **No. Signage is noted on the interior elevations as provided and installed by Services for the Blind and Visually Impaired.**
4. Detail #4 on page 3 shows a section line relating to Detail 4B on page 4. There does not appear to be a detail 4B on page 4. Please advise.
 - **Detail 4B is similar to that of Detail 4A. Information relevant to Detail 4B is noted in Detail 4A.**



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

5. Elevations noted on "Large Scale Island Plan" (Page #4/Detail #2) appear to be wrong. Please advise.
 - **The author of this question has incorrectly noted the drawing reference numbers. The author has reversed the referencing numbers by noting (Page #4/Detail #2). The correct referencing for the drawing is explained in the "Legend" on the drawings.**
 - **There are no omissions of information. All necessary information is provided on the drawings; however, the elevation symbols shown on the "Large Scale Island Plan" (Drawing 4, Sheet 2) should read as follows:**
 - **The reference symbol pointing to the right should read: Drawing 14, Sheet 3**
 - **The reference symbol pointing to the up should read: Drawing 15, Sheet 3**
 - **The reference symbol pointing to the left should read: Drawing 16, Sheet 3**
 - **The reference symbol pointing to the down should read: Drawing 17, Sheet 3**
6. Sections noted on Detail 14 and 16 on Page 3 appear to be wrong. Please advise.
 - **There are no omissions of information; however, the section symbols shown on Details 14 and 16 on Page 3 read Detail #2, Page #4, which is incorrect. The correct reference for those sections is Detail #9 on Page #4.**
7. Are shelves in Janitors closet to be new?
 - **No. The existing shelves are to be removed and reinstalled (reused).**