



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

4/30/15

Solicitation RFQ #7549469

Title: Lighting Fixture for the Theater, Community College of Rhode Island

Submission Deadline: May 13, 2015 @ 10:00 AM


Per the issuance of ADDENDUM #1 the following are noted:

Vendor Questions (attached)

Prospective bidders and all concerned are hereby advised of the attached changes/modifications for the above referenced RFQ and are hereby requested to change their copies accordingly.

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

**Gary P. Mosca,
Senior Buyer**



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website:
www.purchasing.ri.gov

Vendor Request for Information on RFQ# 7549469
Lighting Fixture for the Theater, Community College of Rhode Island

1) Question: Line #7- Please verify if the fixture being requested is the Altman 175Q?

Response: Fixture is the Altman 175Q

2) Question: Line #8- Please verify whether the fixture being requested is the ETC 7" Fresnel, or the Altman 175Q

Response: Fixture is ETC 7" Fresnel

3) Question: Line #10- City Theatrical part number 2840 is a 6.25" Full Stacker Top Hat. There is no 8.25" Stacker available. Shall we quote the 6.25"

Response: Yes. That should be 6.25" NOT 8.25"

4) Question: Line #19- FYI, this is a discontinued item. There may be remaining inventory when ordered.

Response: Please replace item with Rosco Revo Dual Indexing Gobo Rotator instead.

5) Question: Line #20- Please provide more information on the DDS6000+. What power outputs are you requesting?

Response: I am looking for 120VAC/20 2P&G outlets. Please assure model with 5pin dmx control.

End.