



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

5/12/15

Solicitation RFQ #7549531

*Title: Fiber Optic Backbone Cabling Infrastructure – Community College
of Rhode Island*

Submission Deadline: May 22, 2015 @ 10:00 AM

Per the issuance of ADDENDUM #1 the following are noted:

- Pre-Bid Meeting Notes / Vendor Questions (attached)
- Pre-Bid attendance sheet

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

Handwritten signature of Gary P. Mosca in cursive.

**Gary P. Mosca,
Senior Buyer**



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website:
www.purchasing.ri.gov

May 12, 2015
Addendum No. 1

PreBid Meeting Notes

Solicitation # 7549531: Fiber Optic Backbone Cabling Infrastructure

RFP Deadline: 5/22/15 10am

Questions due 5/8/15 by 5pm to email address notes on solicitation cover sheet

*Public works project – electronic bid submission required (Gary to discuss with DLT and come back to CCRI on this. Project is not construction based; need clarification on public works issue).

****Response to Prevailing Wage:** The project is a public works contract valued over \$1,000 which includes construction and the owner of the property is the State of RI. The project would be classified as prevailing wage.

Vendors should bid a total cost for the project, prevailing wage (reference above).

Page 3 Sec 1.3 G

The Spec says to give pricing for both plenum and riser cable. Armored riser rated cable can be used for everywhere except Sec 1.3 K (the Field House run) or where Code dictates the need for plenum rated cable because the space the cable is passing thru is a plenum space.

The Spec says everything is in inner-duct. Armored cable will be a preferred substitute for the inner-duct.

Page 3 Sec 1.3 H

The Multimode fiber, 50 microns will be OM3

Page 3 Sec 1.3 K

The specs say to terminate the outdoor rated cable in the basement closet to transition from an outdoor cable to an indoor cable.

For this entire run single 24 strand single mode plenum rated armor jacketed indoor/outdoor cable will be the cable. That connects the Field room 8210 to the MDF room 2098.

Page 6 Sec 1.6 D 2.

BICSI certified technicians as permanent staff members is not a requirement.

Page 7 Sec 1.7 A 3 and 4.

BICSI certified technicians as permanent staff members is not a requirement.

Page 11 Sec 2.6 C.

There may be a need to put an extension in from the 4" sleeve to the tray system for some closets. EMT can be used in the situations where conduit is needed to extend to the tray system.

Core drilling to take place after hours, 3rd shift and/or weekends (3rd shift 11pm to 7am)

CCRI Campus Police on-site 24/7, vendor staff on-site are required to check in with Campus Police every time they're on campus.

BCI checks required must be done through the RI Attorney General's office. (applies to the awarded vendor).

Vendor submitted question:

Question: Is there a specification sheet for the materials to be used for this Bid?

Response: There is no list sheet of itemized materials. Vendors are to read the bid package and determine the materials needed. It is the vendor responsible to come up with the materials needed.

End.



State of Rhode Island
 Division of Purchases
 One Capitol Hill
 Providence, RI 02908

"NON-MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

BID NUMBER: 7549531
 BID TITLE: Fiber Optic Backbone Infrastructure - Community College of Rhode Island
 PRE-BID DATE AND TIME: 5/6/2015 - 9:00 A.M.

Purchasing Representative:
 Gary P. Mosca
 Pre-bid START TIME:
 9:00 AM
 Pre-bid END TIME:
 10:30 AM

| COMPANY NAME | COMPANY REPRESENTATIVE | ADDRESS | CONTACT E-MAIL | CONTACT PHONE NUMBER | CONTACT FAX NUMBER | PROPOSAL SUBMITTED (For Purchasing Use Only) |
|-------------------------------|--------------------------|---|--|-------------------------|-------------------------|--|
| State of RI | GARY P. MOSCA | One Capitol Hill, Prov. | gmosca@purchasing.ri.gov | 401-574-1124 | | |
| SYNET | JAY PETERS | 205 HAYLENE RD W. WARWICK | JPETERS@SYNETINC.COM | 401-862-1326 | 401-736-6455 | |
| ARL | WILL FORTUS | 400 East Ave | Wfortus@ccri.edu | 825-8444 | 825-8528 | |
| CCRI | Bill Ferland | ' ' | wferland@ccri.edu | 825-1210 | | |
| CCRI | Manny Corrao | ' ' | corrao@ccri.edu | 825-1143 | | |
| AZ Corp. | Bob NAULT | 1 RESEARCH DRIVE WESTBOROUGH MA 01581 | RNAULT@AZ-CORP.COM | 781-223-1069 | | |
| AZ Corp | Paul Schmitz | Research Laboratory N. Stonington CT | pschmitz@az-corp.com | 860-445-3172 | 860-445-3572 | |
| Rossi Elec. | Scott Malone | 65 Westford Ind. Dr Cranston, RI 02901 | smalone@rossi-electric.com | 401-946-8866 | 946-8836 | |
| Computer Telephone | David Resnick | 60 Alhambra Rd | dresnick@computer-telephone.biz | 401-737-5500 | 401-737-5307 | |
| Computer Telephone | David Resnick | 60 Alhambra Rd | dresnick@computer-telephone.biz | 401-737-5500 | 401-737-5307 | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |