



Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
ONE CAPITOL HILL
PROVIDENCE RI 02908

CREATION DATE : 25-JUN-15
BID NUMBER: 7549567,3
TITLE: PROVIDE EQUIP., MATERIALS & LABOR TO REPLACE EMERGENCY GENERATOR AT GROUP HOME

BLANKET START : 01-JUL-15
BLANKET END : 31-DEC-15
BID CLOSING DATE AND TIME:13-JUL-2015 02:00:00

BUYER: Cadoret, David
PHONE #: N/A

B
I
L
L
T
O
DOA CONTROLLER
ONE CAPITOL HILL, 4TH FLOOR
SMITH ST
PROVIDENCE, RI 02908
US

S
H
I
P
T
O
BHDDH - FOR DESTINATION
SEE BELOW
SEE BELOW, RI N/A
US

Requisition Number: 1405553

Amendment Description: THIS ADDENDUM CHANGES BID CLOSING DATE AND TIME.
THIS ADDENDUM POSTS CHANGE TO GENERATOR SIZE AND ISSUES SOME ADDITIONAL CLARIFICATIONS.
THIS ADDENDUM POSTS ACKNOWLEDGEMENT OF ADDENDUM SHEET.

Line	Description	Quantity	Unit	Unit Price	Total
1	PROVIDE EQUIPMENT, MATERIALS AND LABOR TO REPLACE EMERGENCY GENERATOR AS PER SPECIFICATIONS ATTACHED	1.00	Each		

Delivery: _____

Terms of Payment: _____

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 25, 2015

ADDENDUM NUMBER THREE

RFQ # 7549567

TITLE: Provide Equipment, Materials and Labor to Replace Emergency Generator at Group Home

Closing Date and Time: 7/13/15 at 2:00 PM (Note Change)

Per the issuance of this ADDENDUM #3 (3 pages) the following is noted:

Bid Closing Date and Time has been changed from:
6/30/15 at 2PM to
7/13/15 at 2PM

This addendum posts change to generator size and issues some additional clarifications.
This addendum posts Acknowledgement of Addendum(a) sheet.

END OF QUESTIONS

Date: June 23, 2015

To: Steven Denoyelle Deputy Chief
Division of Facilities Management
Department of Behavioral Healthcare, Developmental Disabilities and
Hospitals

From: Dennis Blais

Subject: 15 Baker Pines Road Group Home
Addendum

Steve as discussed the following are items that I want to include as an addendum.

1. Replace the existing Generac diesel generator with a new generator 30Kw/37.5Kva, 208/120V, 3-Phase with a fuel base tank. Utilize the existing conductors and routing as indicated on the contract documents.
2. Remove main bonding jumper, and separate ground from neutrals in existing main panel per NEC article 250.24.
4. Furnish and install a nameplate on main switch indicating alternate power source form generator.
5. Replace existing Generac remote annunciator with new generator annunciator in existing security monitoring room. Utilize existing conduit and wiring.
6. Furnish and Install a monitor module installed in the existing fire alarm control panel in vestibule to indicate generator run status. Run status to be programmed as a supervisory signal only. Provided all required appurtenances required for a complete and operational system. Furnish and install ½" conduit from the automatic transfer switch to monitor module/fire alarm control panel. Include in the bid, cost for a factory representative for final tie in and any required programming.



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

**BID 7549567
Provide Equipment, Materials & Labor to Replace Emergency Generator at Group Home
(Richmond)**

Acknowledgement of addendum(a):

I have received and reviewed the following addendum(a) that pertain to this bid. This sheet must be submitted with your bid proposal. Failure to do so may result in your bid being considered NON-RESPONSIVE.

Addendum Number _____ **Dated** _____

Signed _____ **Dated** _____

Title _____