



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

June 3, 2015

**ADDENDUM NUMBER ONE**

**RFQ # 7549569**

**TITLE: Provide Equipment, Materials and Labor to Replace Emergency Generator at Group Homes**

**Closing Date and Time: 6/23/15 at 11:00 AM (NOTE CHANGE)**

**Per the issuance of this ADDENDUM #1 (5 pages, including a PDF file) the following is noted:**

**Closing date and time has been changed from:**

**6/9/15 at 10am**

**To**

**6/23/15 at 11am**

This addendum changes closing date and time.

This addendum posts schematic drawings omitted on original bid posting.

This addendum posts sign in sheets from mandatory pre bid conferences held at 10am on 5/28/15 in Foster then moved to Woonsocket.

This addendum posts Memorandum from Dennis Blais at Jacob's to Steve Denoyelle at BHDDH.

As noted by buyer at pre bid conference:

-This is a mandatory pre bid conference

Only those vendors on the sign in sheet will be allowed to submit proposals.

-Make sure that the name you sign in with is the same name that you submit your bid under. You will need to sign in at both locations.

-Questions are being accepted on line until 5/29/15 at 5pm The address and instructions how to submit questions is on the bid proposal.

-Bid bond is required

-Performance bond is required

-Specifications and plans are posted on the website.

-This is a public works project and as such requires a CD be submitted along with the paper copy of your bid. Instructions on how to do that are included in the bid package.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

**June 3, 2015**  
**ADDENDUM NUMBER ONE**  
**RFQ # 7549569**

**TITLE: Provide Equipment, Materials and Labor to Replace Emergency Generator at Group Homes**

- Please note the clauses that pertain to public works projects.
- This is a prevailing wage project. Please note the certification within the bid package that acknowledges you are aware of your obligations as they pertain to prevailing wage.
- Included is a bid preparation check list to help you. It is not a substitute for a thorough review of the instructions to bidders.
- We are also asking that you submit a new w-9.

Foster location:

Feed from pole to remain. Not touching overhead service.

Question sent in on line:

1) Assuming all specifications and criteria are met, would the state accept a generator set branded Superior Power Systems?

Answer: Yes, this is an acceptable substitute.

Please monitor this site for additional information.



State of Rhode Island  
Division of Purchases  
One Capitol Hill  
Providence, RI 02908

**"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET**

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

BID NUMBER: **7549569**  
 BID TITLE: **REPLACE EMERGENCY GENERATOR AT BHDDH GROUP HOME HOME**  
 PRE-BID DATE AND TIME: **5/28/15 AT 10AM**  
 PURCHASING REPRESENTATIVE: **DCADORET**  
 MANDATORY PRE-BID START TIME: **10:00**  
 MANDATORY PRE-BID END TIME: **15:30**

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
94 EAST KILLINGLY RD. FOSTER RI					
1 SPARK PUNCHING	AND CARNEY				
2 BHDDH	STEVE DENOYE/LE				
3 CALSON CORP.	STONE CAROZZI				
4 KELLY GRAPHIC	RILAN KELLY				
5 DENNIS BLAIS	JACOB				
6 kelectric	Corey Fontaine				
7 C+K Electric	Robert Kelman				
8 Nolin Electric	Andrew Terlou				
9 ELECTRIC CONSTRUCTION	FRANK BLANCO				
10 TAC HAFFERTY	KRAFT POWER				
11					
12					
13					
14					
15					



State of Rhode Island  
Division of Purchases  
One Capitol Hill  
Providence, RI 02908

**"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET**

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

BID NUMBER	7549569	7549569	7549369
BID TITLE	REPLACE EMERGENCY GENERATOR AT BHDDH GROUP HOME HOME		
PRE-BID DATE AND TIME	5/28/15 AT 10AM		

Purchasing Representative	DCADORET
Mandatory Pre-bid START TIME	11:20
Mandatory Pre-bid END TIME	11:35

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (for Purchasing Use Only)
1 111 BERTHENS HAW RD. WOONSOCKET, RI						
2 STATE PURCHASING	PAUL CADORET					
3 CALSON CORP.	STEVE SAOZZOLI					
4 CTK Electric	Robert Kelman					
5 Kelectra	Cocoy Portaine					
6 Kelly Electric	Brian Kelly					
7 <del>XXXXXXXXXX</del>						
8 Nolin Electric	Andrew Tetlow					
9 BHDDH	STEVE DENYARD					
10 JACOBS	DENNIS BLAIS					
11 COMMONWEALTH	FRANK BEAN CO					
12						
13						
14						
15						

166 Valley Street  
Building 6M, Suite 101  
Providence, Rhode Island 02909-2400 USA  
1.401.272.1969 Fax 1.401.272.2045

---

**Date:** February 28, 2014

**To:** Steven Denoyelle Deputy Chief  
Division of Facilities Management  
Department of Behavioral Healthcare, Developmental Disabilities and  
Hospitals

**From:** Dennis Blais

**Subject:** Bertenshaw, East Killingly, Pound Hill and Sayles Hill Group Homes  
Addendum 1

---

Steve as discussed the following are items from the State Electrical Inspector Comments that I want to include as addendum 1.

1. Reduce circuit breaker size at generator from 225A/2P to 200A/2P.
2. Remove main bonding jumper, and separate ground from neutrals in existing main panel per NEC article 250.24.
3. Revise ground wire from #6 AWG to #4 AWG.
4. Furnish and install a nameplate on main switch indicating alternate power source form generator.
5. Furnish and Install a monitor module installed on the existing fire alarm system to indicate generator run status. Run status to be programmed as a supervisory signal only. Provided all required appurtenances required for a complete and operational system. Furnish and install ½" conduit from the automatic transfer switch to monitor module/fire alarm control panel. Include in the bid, cost for a factory representative for final tie in and any required programming.

Please do not hesitate to call with any questions or additional information.