



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

October 27, 2015

ADDENDUM NUMBER TWO

RFQ #7549583

TITLE: Security Camera System for Maximum Security

Closing Date and Time: 11/23/15 at 10:00 AM (Note Change)

Per the issuance of this ADDENDUM #2 (7 pages) the following change is noted:

Please be advised the Bid Closing Date and Time has been extended:

From: 11/2/15 at 10:00 AM

To: 11/23/15 at 10:00 AM

This addendum posts revised bid form.

This addendum answers questions from mandatory pre bid conference.

This addendum re-opens on line question period. Questions concerning this solicitation may be e-mailed to the Division of Purchases at doa.purbidinfo@purchasing.ri.gov no later than November 6, 2015 at 5pm (EST). Please reference the RFQ number on all correspondence. Questions should be submitted in a Microsoft word attachment. Answers to questions received, if any, will be posted on the internet as an addendum to this solicitation (www.purchasing.ri.gov). It is the responsibility of all interested parties to download this information.

A non-mandatory walk through of the prison will be conducted November 4, 2015 at 10am. All parties will meet at the Facilities and Maintenance Office, 10 Garvey Rd., Cranston, RI. This walk through will be only for those vendors who attended the mandatory pre bid conference on 10/2/15.

Solicitation #:7549583
Solicitation Title: Security Camera System for Maximum Security

BID FORM-Revised 10/27/15

To: The State of Rhode Island Department of Administration
Division of Purchases, 2nd Floor
One Capitol Hill, Providence, RI 02908-5855

Bidder: _____
Legal name of entity

Address (street/city/state/zip)

Contact name Contact email

Contact telephone Contact fax

1. BASE BID PRICE

The Bidder submits this bid proposal to perform all of the work (including labor and materials) described in the solicitation for this Base Bid Price (*including the costs for all Allowances, Bonds, and Addenda*):

\$ _____
(base bid price *in figures* printed electronically, typed, or handwritten legibly in ink)

(base bid price *in words* printed electronically, typed, or handwritten legibly in ink)

• **Bonds**

The Base Bid Price ***includes*** the costs for all Bid and Payment and Performance Bonds required by the solicitation.

• **Addenda**

The Bidder has examined the entire solicitation (including the following Addenda), and the Base Bid Price ***includes*** the costs of any modifications required by the Addenda.

All Addenda must be acknowledged.

Addendum No. 1 dated: _____
Addendum No. 2 dated: _____

Solicitation #:7549583

Solicitation Title: Security Camera System for Maximum Security

Addendum No. 3 dated: _____

Addendum No. 4 dated: _____

Addendum No. 5 dated: _____

Addendum No. 6 dated: _____

2. **ALTERNATES** (Additions/Subtractions to Base Bid Price)

The Bidder offers to: (i) perform the work described in these Alternates as selected by the State in the order of priority specified below, based on the availability of funds and the best interest of the State; and (ii) increase or reduce the Base Bid Price by the amount set forth below for each Alternate selected.

Check "Add" or "Subtract."

____ Add ____ Subtract Alternate No. 1: Provide (3) runs of fiber optic cables from the Maximum Security Head End Server Room to the (3) Industry Buildings as described on drawing ES-2

\$ _____
(amount in figures printed electronically, typed, or handwritten legibly in ink)

(amount in words printed electronically, typed, or handwritten legibly in ink)

____ Add ____ Subtract Alternate No. 2: Provide 24 strands of loose tube multi-mode fiber from the maximum security head-end server room to the intake facility via the existing manhole and underground conduit system. The contractor is responsible to provide 19" floor mounted racks and fiber patch panels to terminate the fiber at each end. The contractor shall test each strand of fiber to ensure the fiber is not damaged. Provide test results to the engineer.

\$ _____
(amount in figures printed electronically, typed, or handwritten legibly in ink)

(amount in words printed electronically, typed, or handwritten legibly in ink)

Solicitation #:7549583
Solicitation Title: Security Camera System for Maximum Security

____Add____ Subtract Alternate No. 3: _____

\$ _____
(alternate amount *in figures* printed electronically, typed, or handwritten legibly in ink)

(alternate amount *in words* printed electronically, typed, or handwritten legibly in ink)

3. UNIT PRICES

The Bidder submits these predetermined Unit Prices as the basis for any change orders approved in advance by the State. These Unit Prices include **all** costs, including labor, materials, services, regulatory compliance, overhead, and profit.

Unit Price No. 1: _____ \$ _____

Unit Price No. 2: _____ \$ _____

Unit Price No. 3: _____ \$ _____

4. CONTRACT TIME

The Bidder offers to perform the work in accordance with the timeline specified below:

- Start of construction: _____
- Substantial completion: _____
- Final completion: _____

5. LIQUIDATED DAMAGES

The successful bidder awarded a contract pursuant to this solicitation shall be liable for and pay the State, as liquidated damages and not as a penalty, the following amount for each calendar day of delay beyond the date for substantial completion, as determined in the sole discretion of the State: \$ _____.

Solicitation #:7549583

Solicitation Title: Security Camera System for Maximum Security

This bid proposal is irrevocable for 60 days from the bid proposal submission deadline.

If the Bidder is determined to be the successful bidder pursuant to this solicitation, the Bidder will promptly: (i) comply with each of the requirements of the Tentative Letter of Award; and (ii) commence and diligently pursue the work upon issuance and receipt of the purchase order from the State and authorization from the user agency.

The person signing below certifies that he or she has been duly authorized to execute and submit this bid proposal on behalf of the Bidder.

BIDDER

Date: _____

Name of Bidder

Signature in ink

Printed name and title of person signing on behalf of Bidder
#

Bidder's Contractor Registration Number

RHODE ISLAND
195 FRANCES AVENUE, BUILDING 2
CRANSTON, RHODE ISLAND 02910
P: 401-438-7733
F: 401-438-7620



www.cec-engineering.com

MASSACHUSETTS
120 MAPLE STREET, SUITE 304
SPRINGFIELD, MASSACHUSETTS 01103
P: 413-519-7542
F: 413-736-1294

October 20, 2015

Mr. David Cadoret
Chief Buyer
1 Capitol Hill, 2nd Floor
Providence, RI 02908

RE: Maximum Security Camera Upgrades
Solicitation #7549583
CEC Project No. 20140149

Dear Mr. Cadoret:

Please include the following items in your next addendum related to the above referenced project:

Drawings:

Drawing E2.1

- Item #1: In the block that reads, "Existing perimeter detection system 30 perimeter zones". Change the number from 30 to 40.
- Item #2: From the "New UTP Patch Panels" to the existing M.T.I. PLC System, which is located in the main guard station, provide a Cat. 6 cable in a ¾" conduit.

Specifications:

- Item #1: Bid form: The contractor shall utilize the attached bid form, which includes (2) alternates the contractor is to identify the dollar amount to provide labor and material to complete the work listed in the following add alternate descriptions.

Alternate #1: Provide (3) runs of fiber optic cable from the maximum security head-end server room to the (3) industry buildings as described on drawing ES-2.

Alternate #2: Provide 24 strands of loose tube multi-mode fiber from the maximum security head-end server room to the intake facility via the existing manhole and underground conduit system. The contractor is responsible to provide 19" floor mounted racks and fiber patch panels to terminate the fiber at each end. The contractor shall test each strand of fiber to ensure the fiber is not damaged. Provide test results to the engineer.

- Item #2: Summary of work – Section 01010 is modified per the following items:
 - Page 2 paragraph 2.M. delete and replace with, "Shall support system redundancy by allowing to switch over a current system to a standby system.
 - Page 2 paragraphs 2.O and 2.P. delete in their entirety.
 - Page 8 paragraph 1.4.A. Second line change "TCDD" to "Submit RCDD certificate"

Creative Environment Corp, Consulting Engineers
HVAC • ELECTRICAL • PLUMBING • FIRE PROTECTION
A Subsidiary of Thielsch Engineering, Inc.

Mr.
Job Title
RE:
Date
Page 2

- Page 8 paragraph 1.4.C. first line delete“(or alternate)”.
- Page 8 paragraph 1.4.D and 1.4.E. delete in their entirety.
- Page 8 paragraph 1.4.F. delete and replace with, “The bidding contractor shall be Genetic Omnicast certified. Provide company certified with the specified I.P. CCTV operating platform.
- Page 8 paragraph 1.4.H.2. Delete and replace with, “Submit a valid certificate from the manufacturer indicating the IP CCTV contractor is an authorized distributor for the system being submitted”.

Item #3: IP CCTV System – Section 16785

1. Page 1, paragraph A.1.g. change “18 frames per second” to “15 frames per second”.
2. Page 2, delete paragraph 2. 1. 8 in its entirety.
3. Page 2, paragraph 4. d. delete “24 hours of activity and add, “All cameras shall be configured to record upon motion. Base motion on 6 hours per day and record continuously for the remaining 18 hours per day.”
4. Page 2, paragraph 4.e. delete “50% motion activity and add “Band width camera will be based upon 50% pixel change and maximum/best quality setting.” Also in the paragraph after paragraph 4.e. change, “Estimated storage size based on above parameters is approximately 100 TB,” to be “Estimated storage size based on above parameters in approximately 300 TB.”
5. Add – 4.f. Provide a minimum storage of 30 days.
6. Add on page 3, in paragraph 2.1 A “Item 11. Perimeter detection integration, provide GSC-IPS WM.
7. Page 4, paragraph c.1: Change the first sentence to read, “Provide nine (9) rack mounted IP video archiver servers with Genetic Security Center.
8. Page 5, Paragraph E.1.b. delete and provide the following, “Quad Core Intel Xeon E5640 2.66 GHZ or better”.
9. Page 5, paragraph E.1.e delete and provide “16 GB or ram or better”.
10. Page 5, paragraph E.1.e. delete and provide “NVIDIAQUADRO VCQK620-PB.
11. Add “H.1.b. Provide 10% spare capacity per switch”.
12. Page 7, paragraph 1.4.a. change “AXIS P3367-V” to “Provide AXIS P3367-VE.”
13. Page 7, paragraph J.1.a. change “AXIS Q6035-E” to “Provide AXIS Q6045E”.
14. Page 7, paragraph J.2.a. change “AXIS Q6035-E” to “Provide AXIS Q6045E”.
15. Page 8, paragraph I.7.b. delete and provide instead, “Provide AXIS P8221 or approved equal”.

Very truly yours,
Creative Environment Corp.



Greg Driggers
Senior Project Manager

