



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

6/11/15

Solicitation RFQ #7549591

*Title: Renovations to Clarke Science Bio-Chemistry Lab Room 106 –
Rhode Island College*

Submission Deadline: June 24, 2015 @ 10:00 AM

Per the issuance of ADDENDUM #1 the following are noted:

Addendum #1 (attached)

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

A handwritten signature in cursive script that reads "Gary P. Mosca".

**Gary P. Mosca,
Senior Buyer**

TO ALL BIDDERS OF RECORD:

This Addendum forms a part of the Contract Documents and modifies the Drawings and Project Manual as hereinafter indicated.

PROJECT MANUAL

SECTION 116100 LABORATORY FUME HOODS: Page 8, U. Fume Hood Liners: Change paragraph to read: Epoxy Resin Lining or Poly Resin Lining is acceptable. Flame spread of material as measured by ASTM E84 shall be 6.2 or less.

SECTION 123500 WOOD CASEWORK:

1. Page 2, B.: Modify the third sentence to read: Written request for substitution in materials and/ or construction, along with product technical information, must be submitted to RI State Purchasing by Monday, June 15, 0215 4:00pm. Provide a narrative identifying the difference in materials and/ or construction along with the written request. Technical information to be submitted includes: data indicating casework is in compliance with SEFA 8 Standard, independent test lab certification that the furniture finish meets the performance requirements described in section 2.03 of these specifications, and construction details.
2. Page 6, 2.00: Change 2.00 to 2.03 FINISH AND PERFORMANCE REQUIREMENTS
3. Page 8, 2.01: Change 2.01 to 2.04 WORKSURFACES
4. Page 8, 2.02: Change 2.02 to 2.05 SINKS, CUPSINKS, AND DRAINS

DRAWINGS

COVER: Under LIST OF DRAWINGS add "S101 NEW SUPPORT FOR ROOF EXHAUST UNITS"

A701, Elevation 3: Provide a finished removable metal panel at the knee space below the fumehood to match the fumehood and casework below.

Sheet E200: In the light fixture schedule, include a type "X" exit light. The exit light shall be an Evenlite #TLXEMRUW.

Vendor Submitted Questions:
Solicitation No. 7549591

RFI #1- We would like to quote Wood-Metal Industries(www.wood-metal.com) wood casework who can meet and exceed the specifications in Section 123000. We would like to quote them as an alternate acceptable manufacturer. Kewaunee Scientific is the only manufacturer specified. Per 012500, it states substitutions should be submitted (15) days after work commences. Should we wait to submit a substitution request or send in before the bid for approval. If so, who should I send this to?

Response to RFI #1: Refer to modifications to Section 123500 noted in this Addendum.

RFI #2- In addition, we would like to quote to the other general contractors. Can you send me a list of the bidders?

Response to RFI #2: Refer to attached list of attendees at the mandatory pre-bid meeting.

END OF ADDENDUM NO. 1



State of Rhode Island
Division of Purchases
One Capitol Hill
Providence, RI 02908

"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its representative attend this mandatory prebid conference, sign, and complete all required information on this Sign-In Sheet. Failure to comply with this requirement will result in the rejection of any bid proposal.

BID NUMBER 7549591
BID TITLE Renovations to Clarke Science Bio-Chemistry Lab Room
 106 - Rhode Island College
PRE-BID DATE AND TIME June 9, 2015 @ 9:00 am

Purchasing Representative
 Gary P. Mosca
Mandatory Pre-bid START TIME
 9:00 AM
Mandatory Pre-bid END TIME

COMPANY NAME	COMPANY REPRESENTATIVE	SIGNATURE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER AND FAX NUMBER	PROPOSAL SUBMITTED FOR PURCHASING USE ONLY
1 State of RI	GARY P. MOSCA		ONE CAP. HILL PROV. RI 02908	g.p.mosca@proc.state.ri.us	401-943-0110 Call P. Com	
2 Tassel Construction Group	Sai T. Srigessa		285 LINCOLN AVE WARWICK, RI	ESTIMATE@TASSELCONSTRUCTION.COM	401-580-2062	
3 Iron Construction Group	Justin DePasquale		875 CENTVILLE RD WARWICK, RI	estimating@icgri.com	401-580-2062	
4 Chirico Const.	SCOTT SMITH		51 JOHNSON RD WARWICK	chiricoconstruction@cox.net	823-5399 FNO	
5 EW Burman	Bob Dandereaux		33 Vermont Ave. Warwick RI	estimating@ewburman.com	401-738-5400	
6 MPT Const. Co. Inc	Kassie VEBERT		2000 POST RD WARWICK	REVISIT@MPTCONTRACTING.COM	401-272-4774	
7 Care Technology LLC	Belinda Wong		4-2 Moshassuck Rd Lincoln RI 02865	mandy@caretechnology.biz	401-728-3235	
8 Bentley Builders	Dawn Filler		250 Scalyhollow Pk. RI 02852	Ptiernery@BentleyBuildsllc.com	401-223-6499	
9 Cytha Contracting	Eileen Coletta		83 Power Rd Rt 10306 RIS	Justin@colettacontracting.com	401-727-1757	
10 AACBARR CONST	TIM RAVITT		21 COTTAGE HILL WARWICK RI	TNAVR@AACBARR.COM	401-681-4949	
11 Bahny Building Co.	Luke Bahny		26 NYE ST. East Providence, RI	LB@bahnybuilding.com	774-229-2134 (cost)	
12 DELTA MESH LLC	GARY RIVANA		44 MICHIGAN ST WARWICK RI	G.RIVANA@DELTA MESHLLC.COM	508-557-1784 (FAX)	
13 CINDY GERLACH	STUDIO 401 ARCHITECTURE		5600 POST RD WARWICK RI	cindy@401architectur.com	401-602-6616	
14						
15						