



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

August 18, 2015

ADDENDUM NUMBER THREE

RFQ # 7549737

TITLE: HVAC/Electrical Upgrades at Barry & Simpson Halls, DOA

Closing Date and Time: 8/24/15 at 2:00 PM

Per the issuance of this ADDENDUM # (3), 2 pages, including this cover sheet.

Specification Change /Addition / Clarifications

Listed below are the questions along with the answers that we have received regarding this Request for Quote.

RFI Responses:

1. IEC and Williams were listed as approved equals. Are IEC and Williams the only acceptable manufacturers?

Response: Temspac & Airtherm will be considered if they meet the specifications.

2. The questions regarding the underground steam piping and abatement were not answered as part of this addendum.

Response: RFI responses #8 & #9 addressed these items.

3. Re: Mech. Requirements 15500 Pg. 16 Par. 2.8 B 1b.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

What are Interior Ventilated/Untempered ducts? Also R – Value 12.0 is not available in flexible, foil faced, noncombustible blanket.

Response: Interior Ventilated/Untempered refers to ducts located outside the building. This doesn't apply to this project.

4. What is the scope of HVAC demolition?

Response: Refer to drawings MD-1 & MD-2.

End of Responses