



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

December 16, 2015

**ADDENDUM NUMBER ONE**

**RFQ # 7550073**

**TITLE: Fire Protection Systems Inspections, Testing & Service, URI, CCE**

**Closing Date and Time: 12/23/15 at 11:00 AM**

**Per the issuance of this ADDENDUM # (1), (82) pages, including this cover sheet.**

**Specification Change /Addition / Clarifications**

**Listed below are the Questions and the Answers we received regarding this Invitation to Bid.**

1. Q. Page 8 of 10 in the Instructions to Bidders states “Environmental Impairment” “Pollution Control” Insurance as a requirement of successful bidder. Is this coverage required for this contract?  
A. No it is not a requirement of this bid.

2. Q. Can the results of the last time this location was out to bid be provided?

A. Go to our website at [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

Click on Solicitation Opportunities

Click State Agency Solicitation

Click search every bid status

Type in the bid #7457863

Click search

Click OK

Click 7457863

Click 7457863 Awarded



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

3. Q. Can you please provide accurate fire alarm test reports with device counts? If the fire alarm reports were submitted correctly, all device counts in the building should be provided on the quarterly test reports.

A. See attached pages.

Attached is a copy of the Mandatory Pre-Bid Sign-In sheet.



State of Rhode Island  
Division of Purchases  
One Capitol Hill  
Providence, RI 02908

**"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET**

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its representative attend this mandatory prebid conference, sign, and complete all required information on this Sign-In Sheet. Failure to comply with this requirement will result in the rejection of any bid proposal.

**BID NUMBER:** 7550073  
**BID TITLE:** Fire Protection Systems Inspections, Testing & Service,  
URI, CCE  
**PRE-BID DATE AND TIME:** 12/11/15 at 9:30 AM

**Purchasing Representative:**  
John F. O'Hara II  
**Mandatory Pre-bid START TIME:**  
9:30 AM  
**Mandatory Pre-bid END TIME:**

COMPANY NAME	COMPANY REPRESENTATIVE	SIGNATURE	ADDRESS	CONTACT EMAIL	CONTACT PHONE NUMBER AND FAX NUMBER	PROPOSAL SUBMITTED (for Purchasing Use Only)
1 ELECTRONIC ALARMS	Brian Peters		255 WEST STREET WARWICK RI	B.Peters@ELECTRONICALARMS.COM	(401) 737-2221 FAX (401) 737-2585	
2 ARDEN	KEN GIVIENS		Llacoia	K.givens@ardensystems.com	727-3381	
3 Allstate Fire	FRANK MARTELLI		2410 CHESTNUT ST WARWICK RI 02888	fmartelli@allstatefire.net	725-2662	
4 AFA	Sten Lomborn		43 South Main St ASSISTANCE	stlomborn@afafire.com	401-255-8689	
5 PES	John Medeiros		93 South Main St ASSISTANCE	jmedeiros@pesfire.com	582-644-3110	
6 Simcox Ginnell	MATT PANNMELL		601 WASHINGTON ST Paw Paw	mpannell@simcoxginnell.com	(401) 228-4746	
7 Simplex Ginnell	Peter Corse		690 METACALFE ST PAW PAW	pcorse@simplexginnell.com	401-834-6195	
8 Engine Fire Protection	Kristen Adams		74 LOCUST ST FAIRFIELD	kadams@enginefireprotection.com	603-201-9999	
9 U.R.I	Ed Coppola		304 PINE ST FAIRFIELD	ecoppola@uri.edu	401-271-5179	
10 URT	MIKE SURRANI		197 Plains Rd Fairfield	mikesurranibob@uri.edu	639-2268	
11 Redhawk	Tony Pimental		37 Young St Narragansett, RI	tonyp@redhawkus.com	774-504-4072	
12 Red Hawk	Rob LaChance		201 Pomeroy Rd ST BARTHOLOMEW	Rob.LaChance@redhawkus.com	774-265-8320	
13 A P Fire Systems	Alan Coate		551 Water Street E. PROV. RI	APFireSystems@gmail.com	401-640-1962	
14						
15						

2014-20 Date 5/9/2014 \*\* VENDOR: PLEASE SUBMIT A BUSINESS CARD IF AVAILABLE \*\*

URI CCE points list 11-2013 (002)

-----  
 SHEPARD'S BUILDING GENERAL INFORMATION Page 1  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

4100 Fire Alarm System GENERAL  
 Simplex Time Recorder Co. INFO

Node Number: 1  
 System Type: 4100+

Job Filename : 9520019D  
 Job Title : SHEPARD'S BUILDING  
 Order Number : 1435579  
 Customer :  
 Customer Contact :  
 Contractor : AUDET E W & SONS, INC.  
 Salesperson : MARK LORD  
 Branch Number : 149  
 Branch Location : PROVIDENCE, RI  
 Programmed by : BRYAN LYNCH  
 Agency Approval : UL  
 NFPA Standard : 72A  
 Standby Generator? : NO  
 Hours of Standby Battery : 60

Comments :  
 :

Job Rev : 16  
 Built Rev : 15  
 Built Date : 26-Jun-13 12:19

	Current	As Built
	-----	-----
Programmer Rev :	9.02.22	8.05
System Defaults Rev :	99	80
Database (DBF) Format :	99	81
CFG Format :	0	0

♀

-----  
 SHEPARD'S BUILDING SYSTEM OPERATION Page 2  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

OPTIONS  
 SUMMARY

Standard System Operations	Enabled?	Settings
-----	-----	-----
Alarm Silence Inhibit.....	NO	
Time Limit Signal Control...	NO	
System Trouble Reminder.....	NO	
Dedicated waterflow signals.	NO	
Sprinkler Supv. Operation...	NO	
Alarm Verification Setup...	NO	
Individual Acknowledge .....	NO	GLOBAL
Elevator Recall Operation...	YES	*
Non-Steady Audible Evac Sig.	NO	
Non-Steady Visual Evac Sig.	YES	MARCH TIME
Door Holder Operation.....	YES	*
Display First Alarm.....	NO	

Expanded System Operations	URI CCE points Enabled?	list 11-2013 (002) Settings
24-Hr Time/Date Format.....	NO	12 HOUR
Coding Group Configuration..	NO	
Audio Coding Configuration..	NO	
Audio Option Configuration..	YES	*
Walk Test by Group.....	NO	
Non-General Alarm Operation.	NO	
Pre-Programmed User Lists...	YES	*
Temperature in Centigrade...	NO	FAHRENHEIT
Default Local Mode.....	YES	
Paging Channel Selection....	YES	Paging Channel: 1

Other selections	Enabled?	Settings
Access Levels		*
Non-Default Passcodes	YES	
City Connect		Local Energy Masterbox
Custom Control	YES	Program: 3, 4, 5, 6

\* Operation ENABLED. See Options Detail Report for full description.

♀

SHEPARD'S BUILDING CARD SUMMARY BY LOCATION Page 3  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD LOCATION LISTING: CARD LOCATION

LOCAL CONTROLLER UNIT:

DAUGHTER CARDS:

Card	Card Type	Zone Range
0	(7003) 4100+ Master Controller	
1	(0113) 2120/RS232 Interface	
2	(6005) Power Supply/Charger	
3	(4331) 3 Input Class A Signal	SIG3-8
4	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX3-6
6	(0210) Audio Controller	
7	(0110) MAPNET Interface	M1-1 - 48
8	(0304) Remote Unit Interface (RUI)	RUI 1
9	(4011) 2 Ckt Class A Signal (IAC)	SIG9-14
35	(3003) 8 Pt, 3 Amp Relay w/ Feedback	AUX27-34

ANNUNCIATORS:

Annun Card	Card Type	Zone Range
0	64 LED / 64 Sw Controller	
5	(0301) 64 LED / 64 Sw Controller	

REMOTE UNIT INTERFACE 1 (RUI 1):

Type Unit	Card	Card Type	Zone Range
Ann	1	10 (6005) Power Supply/Charger (Audio)	
Ann	1	11 (0110) MAPNET Interface	M2-1 - 127
Ann	1	12 (3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX7-10
Ann	1	13 (4011) 2 Ckt Class A Signal (IAC)	SIG15-20

URI CCE points list 11-2013 (002)

Ann	1	14	(4331)	3 Input Class A Signal	SIG21-26
Ann	2	15	(4331)	3 Input Class A Signal	SIG27-32
Ann	2	16	(6005)	Power Supply/Charger (Audio)	
Ann	2	17	(0110)	MAPNET Interface	M3-1 - 127
Ann	2	18	(3002)	4 Pt, 10 Amp Relay w/ Feedback	AUX11-14
Ann	2	19	(4031)	6 Ckt Class A Signal (IAC)	SIG33-38
Ann	3	20	(4331)	3 Input Class A Signal	SIG39-44
Ann	3	21	(6005)	Power Supply/Charger (Audio)	
Ann	3	22	(0110)	MAPNET Interface	M4-1 - 127
Ann	3	23	(3002)	4 Pt, 10 Amp Relay w/ Feedback	AUX15-18
Ann	3	24	(4011)	2 Ckt Class A Signal (IAC)	SIG45-50
Ann	4	25	(4331)	3 Input Class A Signal	SIG51-56
Ann	4	26	(6005)	Power Supply/Charger (Audio)	
Ann	4	27	(0110)	MAPNET Interface	M5-1 - 127
Ann	4	28	(3002)	4 Pt, 10 Amp Relay w/ Feedback	AUX19-22
Ann	4	29	(4031)	6 Ckt Class A Signal (IAC)	SIG57-62

SHEPARD'S BUILDING CARD SUMMARY BY LOCATION Page 4  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD LOCATION LISTING:

CARD LOCATION continued

REMOTE UNIT INTERFACE 1 (RUI 1):

Type	Unit	Card	Card Type	Zone Range
Ann	4	36	(0304) Remote Unit Interface (RUI)	
Ann	5	30	(4331) 3 Input Class A Signal	SIG63-68
Ann	5	31	(6005) Power Supply/Charger (Audio)	
Ann	5	32	(0110) MAPNET Interface	M6-1 - 127
Ann	5	33	(3002) 4 Pt, 10 Amp Relay w/ Feedback	AUX23-26
Ann	5	34	(4011) 2 Ckt Class A Signal (IAC)	SIG69-74
Ann	6	37	(4603-9101) LCD Annunciator	

REMOTE UNIT INTERFACE 2 (RUI 2):

Type	Unit	Card	Card Type	Zone Range
no remote units				

SHEPARD'S BUILDING SYSTEM POINT SUMMARY Page 5  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY ZONE

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL	
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL	
SIG5	SPARE	SIG5	SSIGNAL	
SIG6	SPARE	SIG6	SSIGNAL	
SIG7	SPARE	SIG7	SSIGNAL	
SIG8	SPARE	SIG8	SSIGNAL	
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER	
SIG10	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL	

URI CCE points list 11-2013 (002)

SIG11	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG12	SPARE	SIG12 SPEAKER
SIG13	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG14	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15 SPEAKER
SIG16	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG17	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18 SPEAKER
SIG19	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG20	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21 SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22 SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23 SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24 SSIGNAL
SIG25	SPARE	SIG25 SSIGNAL
SIG26	SPARE	SIG26 SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27 SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28 SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29 SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30 SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31 SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32 SSIGNAL
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33 SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34 SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35 SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36 SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37 SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38 SPEAKER
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39 SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40 SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41 SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42 SSIGNAL
SIG43	SPARE	SIG43 SSIGNAL
SIG44	SPARE	SIG44 SSIGNAL
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45 SPEAKER
SIG46	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG47	*** SIGNAL CIRCUIT NOT AVAILABLE ***	SIGNAL
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48 SPEAKER

†

SHEPARD'S BUILDING SYSTEM POINT SUMMARY Page 6  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name): POINT SUMMARY  
 ZONE  
 continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
SIG49	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL	
SIG50	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL	
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL	
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL	
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL	
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL	
SIG55	SPARE	SIG55	SSIGNAL	
SIG56	SPARE	SIG56	SSIGNAL	
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER	
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER	
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER	
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER	
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER	
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER	

URI CCE points list 11-2013 (002)

SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG70	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG71	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER
SIG73	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG74	*** SIGNAL CIRCUIT NOT AVAILABLE ***		SIGNAL
SIG75	VIRTUAL NAC 1 - ALL APPLIANCE OUTPUTS	A/V	SIGNAL
SIG76	VIRTUAL NAC 2 - ALL AUDIBLE DEVICES	AUD	SSIGNAL
SIG78	VIRTUAL NAC 4 - ALL VISUAL DEVICES	VIS	RVISUAL
SIG79	VIRTUAL NAC 5 - ALL ISOLATOR DEVICES	A/V	RELAY
AUX3	LOWER LEVEL DOOR HOLDER CIRCUIT	AUX3	DHOLDER
AUX4	AUX RELAY POINT AUX4		RRELAY
AUX5	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX5	DHOLDER
AUX6	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX6	DHOLDER
AUX7	GROUND FLOOR NORTH DOOR HOLDER CIR	AUX7	DHOLDER
AUX8	SECOND FLOOR NORTH DOOR HOLDER CIR	AUX8	DHOLDER
AUX9	SPARE		RRELAY
AUX10	SPARE		RRELAY
AUX11	GROUND FLOOR SOUTH DOOR HOLDER CIR	AUX11	DHOLDER
AUX12	SECOND FLOOR SOUTH DOOR HOLDER CIR	AUX12	DHOLDER
AUX13	SPARE		RRELAY
AUX14	SPARE		RRELAY
AUX15	THIRD FLOOR DOOR HOLDER CIRCUIT	AUX15	DHOLDER
AUX16	FOURTH FLOOR DOOR HOLDER CIRCUIT	AUX16	DHOLDER
AUX17	SPARE		RRELAY
AUX18	SPARE		RRELAY

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

SYSTEM POINT SUMMARY

Page 7  
10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY  
ZONE  
continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
AUX19	THIRD FLOOR SOUTH DOOR HOLDER CIR	AUX19	DHOLDER	
AUX20	FOURTH FLOOR SOUTH DOOR HOLDER CIR	AUX20	DHOLDER	
AUX21	GAS VALVE SHUTDOWN	AUX21	RRELAY	
AUX22	SPARE		RRELAY	
AUX23	FIFTH FLOOR NORTH DOOR HOLDER CIR	AUX23	DHOLDER	
AUX24	SIXTH FLOOR NORTH DOOR HOLDER CIR	AUX24	DHOLDER	
AUX25	SPARE		RRELAY	
AUX26	SPARE		RRELAY	
AUX27	DOOR 104 MONITORS M2-41 IAM-ANN LT	AUX27	RELAY	
AUX28	DOOR 110 MONITORS M3-35 IAM-ANN LT	AUX28	RELAY	
AUX29	DOOR 113 MONITORS M2-43 IAM-ANN LT	AUX29	RELAY	
AUX30	DOOR 122 MONITORS M2-45 IAM-ANN LT	AUX30	RELAY	
AUX31	DOOR 128 MONITORS M2-47 IAM-ANN LT	AUX31	RELAY	
AUX32	AUX RELAY CARD 35 RELAY CKT	AUX32	RELAY	
AUX33	DOOR ALARM TROUBLE-ANN LT & PIEZO	AUX33	RELAY	
AUX34	DOOR ALARM ANNUNCIATOR PIEZO	AUX34	RELAY	
FB3	AUX RELAY FEEDBACK PT FB3		ONOFF	
FB4	AUX RELAY FEEDBACK PT FB4		ONOFF	
FB5	AUX RELAY FEEDBACK PT FB5		ONOFF	
FB6	AUX RELAY FEEDBACK PT FB6		ONOFF	

URI CCE points list 11-2013 (002)

FB7	AUX RELAY FEEDBACK PT FB7	ONOFF
FB8	AUX RELAY FEEDBACK PT FB8	ONOFF
FB9	AUX RELAY FEEDBACK PT FB9	ONOFF
FB10	AUX RELAY FEEDBACK PT FB10	ONOFF
FB11	AUX RELAY FEEDBACK PT FB11	ONOFF
FB12	AUX RELAY FEEDBACK PT FB12	ONOFF
FB13	AUX RELAY FEEDBACK PT FB13	ONOFF
FB14	AUX RELAY FEEDBACK PT FB14	ONOFF
FB15	AUX RELAY FEEDBACK PT FB15	ONOFF
FB16	AUX RELAY FEEDBACK PT FB16	ONOFF
FB17	AUX RELAY FEEDBACK PT FB17	ONOFF
FB18	AUX RELAY FEEDBACK PT FB18	ONOFF
FB19	AUX RELAY FEEDBACK PT FB19	ONOFF
FB20	AUX RELAY FEEDBACK PT FB20	ONOFF
FB21	AUX RELAY FEEDBACK PT FB21	ONOFF
FB22	AUX RELAY FEEDBACK PT FB22	ONOFF
FB23	AUX RELAY FEEDBACK PT FB23	ONOFF
FB24	AUX RELAY FEEDBACK PT FB24	ONOFF
FB25	AUX RELAY FEEDBACK PT FB25	ONOFF
FB26	AUX RELAY FEEDBACK PT FB26	ONOFF
FB27	AUX RELAY CARD 35 FEEDBACK PT FB27	ONOFF
FB28	AUX RELAY CARD 35 FEEDBACK PT FB28	ONOFF
FB29	AUX RELAY CARD 35 FEEDBACK PT FB29	ONOFF
FB30	AUX RELAY CARD 35 FEEDBACK PT FB30	ONOFF
FB31	AUX RELAY CARD 35 FEEDBACK PT FB31	ONOFF
FB32	AUX RELAY CARD 35 FEEDBACK PT FB32	ONOFF

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

SYSTEM POINT SUMMARY

Page 8  
10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY  
ZONE  
continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
FB33	AUX RELAY CARD 35 FEEDBACK PT FB33		ONOFF	
FB34	AUX RELAY CARD 35 FEEDBACK PT FB34		ONOFF	
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE	
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE	
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE	
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4 MAZAM	SO	
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE	
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE	
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE	
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE	
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9 MAZAM	SO	
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER	
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE	
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE	
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE	
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE	
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16 ADRPUL	PULL	
M1-17	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-17 MAZAM	SO	
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE	
M1-19	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-19 MAZAM	SO	
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE	
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE	
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE	
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23 ADRPUL	PULL	
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE	
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25 ADRPUL	PULL	

URI CCE points list 11-2013 (002)

M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27 ADRPUL PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM WATER
M1-32	ZN1 LOWER LEVEL SOUTH-TAMPER SW	M1-32 MAZAM SO
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM WATER
M1-34	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-34 MAZAM SO
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36 ADRPUL PULL
M1-37	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-37 MAZAM SO
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40 ADRPUL PULL
M1-41	ZN3 LOWER LEVEL SO-SPKLR PRESS SW	M1-41 MAZAM SO
M1-42	DRILL SWITCH DAYCARE CENTER GND FL	M1-42 GENIAM UTILITY
M1-43	DRILL SWITCH MET SCHOOL 4TH FL SO.	M1-43 GENIAM UTILITY
M1-44	REMOTE MICROPHONE ASTALK ON/OFF SW	M1-44 GENIAM UTILITY
M1-45	ALL EMERGENCY EXIT DOORS UNLOCK	M1-45 GENIAM UTILITY

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

SYSTEM POINT SUMMARY

Page 9  
10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY  
ZONE  
continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
M1-46	TURNSTILE RELSE SECURITY DESK2 ENT.	M1-46 RZAM	DHOLDER	
M1-48	ZN 4 GROUND FLOOR SECURITY OFFICE	M1-48 PHOTO	SMOKE	
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL	
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE	
M2-3	ZN4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE	
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE	
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE	
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE	
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE	
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE	
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL	
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE	
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL	
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE	
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE	
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE	
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE	
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE	
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE	
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE	
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL	
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE	
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE	
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE	
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL	
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE	
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE	
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE	
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE	
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE	
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL	
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE	

URI CCE points list 11-2013 (002)

M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31	ADRPUL	PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32	ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33	MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34	PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35	ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36	ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37	PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38	ADRPUL	PULL
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40	RZAM	RELAY
M2-41	GROUND FLR NORTH DOOR MON DR 104	M2-41	GENIAM	UTILITY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42	RZAM	RELAY
M2-43	DOOR MONITOR STR B GRD FL N DR 113	M2-43	GENIAM	UTILITY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44	RZAM	RELAY
M2-45	DOOR MON NEAR REST RM GRD FL DR122	M2-45	GENIAM	UTILITY

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

SYSTEM POINT SUMMARY

Page 10  
10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY  
ZONE  
continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY	
M2-47	DOOR MON NEAR ELECTRIC ROOM DR 128	M2-47 GENIAM	UTILITY	
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET	
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE	
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE	
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL	
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL	
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE	
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE	
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE	
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER	
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE	
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL	
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE	
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE	
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE	
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE	
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE	
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE	
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL	
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE	
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE	
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE	
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE	
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE	
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE	
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE	
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE	
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124 ADRPUL	PULL	
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE	
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE	
M3-1	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-1 ADRPUL	PULL	
M3-4	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-4 PHOTO	SMOKE	
M3-5	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-5 PHOTO	SMOKE	
M3-6	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-6 PHOTO	SMOKE	
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE	
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE	
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE	

URI CCE points list 11-2013 (002)

M3-10	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-10	ADRPUL	PULL
M3-11	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-11	PHOTO	SMOKE
M3-12	ZN5	GROUND	FLOOR	SOUTH-SPKLR FLOW	M3-12	MAZAM	WATER
M3-13	ZN5	GROUND	FLOOR	SOUTH-STAIR D	M3-13	PHOTO	SMOKE
M3-14	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-14	PHOTO	SMOKE
M3-15	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-15	PHOTO	SMOKE
M3-16	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-16	PHOTO	SMOKE
M3-17	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-17	PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

SYSTEM POINT SUMMARY

Page 11  
10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

POINT SUMMARY  
ZONE  
continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE	
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE	
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL	
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL	
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE	
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE	
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE	
M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25 ADRPUL	PULL	
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26 ADRPUL	PULL	
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE	
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE	
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE	
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL	
M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RZAM	RELAY	
M3-35	GROUND FLOOR DOOR MON DR 110	M3-35 GENIAM	UTILITY	
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE	
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE	
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE	
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE	
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE	
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE	
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE	
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE	
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE	
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE	
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE	
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE	
M3-114	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-114 ADRPUL	PULL	
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE	
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE	
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE	
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE	
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE	
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER	
M3-121	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-121 ADRPUL	PULL	
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE	
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE	
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE	
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE	
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE	
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE	
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE	
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL	
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE	

URI CCE points list 11-2013 (002)

M4-4 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-4 PHOTO SMOKE  
 M4-5 ZN8 THIRD FLOOR NORTH-CORRIDOR M4-5 PHOTO SMOKE

♀

-----  
 SHEPARD'S BUILDING SYSTEM POINT SUMMARY Page 12  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

System Point Summary (ascending by zone name): POINT SUMMARY  
 ZONE  
 continued

Zone Name	Custom Label	Device Type	Point Type	PNIS Code
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE	
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE	
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE	
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE	
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE	
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11 ADRPUL	PULL	
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE	
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE	
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE	
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE	
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL	
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER	
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE	
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE	
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE	
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE	
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE	
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL	
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE	
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE	
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE	
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER	
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL	
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE	
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE	
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE	
M4-119	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-119 ADRPUL	PULL	
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE	
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE	
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE	
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE	
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE	
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE	
M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126 PHOTO	SMOKE	
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-127 ADRPUL	PULL	
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE	
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE	
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE	
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE	
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE	
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-7 ADRPUL	PULL	
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER	
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE	
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10 PHOTO	SMOKE	
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11 PHOTO	SMOKE	
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12 PHOTO	SMOKE	

♀

-----  
 SHEPARD'S BUILDING SYSTEM POINT SUMMARY Page 13  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

URI CCE points list 11-2013 (002)

System Point Summary (ascending by zone name):

Zone Name Custom Label		Device Type	Point Type	PNIS Code
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-13 ADRPUL	PULL	
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14 PHOTO	SMOKE	
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15 PHOTO	SMOKE	
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16 PHOTO	SMOKE	
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17 PHOTO	SMOKE	
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE	
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE	
M5-108	GENERATOR RUNNING	M5-108 MAZAM	SUPERV	
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE	
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE	
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE	
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE	
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113 ADRPUL	PULL	
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE	
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115 PHOTO	SMOKE	
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116 PHOTO	SMOKE	
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117 PHOTO	SMOKE	
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE	
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE	
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE	
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER	
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122 ADRPUL	PULL	
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE	
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124 PHOTO	SMOKE	
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125 PHOTO	SMOKE	
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126 PHOTO	SMOKE	
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127 PHOTO	SMOKE	
M6-1	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-1 PHOTO	SMOKE	
M6-2	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-2 PHOTO	SMOKE	
M6-3	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-3 ADRPUL	PULL	
M6-5	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-5 ADRPUL	PULL	
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6 PHOTO	SMOKE	
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7 PHOTO	SMOKE	
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8 PHOTO	SMOKE	
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9 PHOTO	SMOKE	
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10 PHOTO	SMOKE	
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11 PHOTO	SMOKE	
M6-12	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-12 ADRPUL	PULL	
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13 PHOTO	SMOKE	
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14 PHOTO	SMOKE	
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE	
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE	
M6-17	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-17 ADRPUL	PULL	
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER	
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE	
M6-20	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-20 ADRPUL	PULL	

‡

SHEPARD'S BUILDING SYSTEM POINT SUMMARY Page 14  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

System Point Summary (ascending by zone name):

Zone Name Custom Label		Device Type	Point Type	PNIS Code
------------------------	--	-------------	------------	-----------

URI CCE points list 11-2013 (002)

M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21	PHOTO	SMOKE
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS	M6-93	RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS	M6-94	RZAM	CDAMPER
M6-96	ZN13 COMPUTER ROOM FM 200 TROUBLE	M6-96	MAZAM	TROUBLE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97	PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98	PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99	ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100	ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101	PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102	MAZAM	HEAT
M6-103	FREIGHT ELEV ALTERNATE RECALL	M6-103	RZAM	ALTERN
M6-104	FREIGHT ELEVATOR PRIMARY RECALL	M6-104	RZAM	PRIMARY
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105	PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106	HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107	PHOTO	SMOKE
M6-108	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-108	ADRPUL	PULL
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109	PHOTO	SMOKE
M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110	MAZAM	WATER
M6-111	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-111	ADRPUL	PULL
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112	PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113	PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114	PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115	PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116	PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117	PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118	PHOTO	SMOKE
M6-119	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119	HEAT	HEAT
M6-120	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120	HEAT	HEAT
M6-121	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121	HEAT	HEAT
M6-122	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-122	ADRPUL	PULL
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123	PHOTO	SMOKE
M6-124	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124	MAZAM	FIRE
M6-126	PASSENGER ELEV ALTERNATE RECALL	M6-126	RZAM	ALTERN
M6-127	PASSENGER ELEV PRIMARY RECALL	M6-127	RZAM	PRIMARY

♀

SHEPARD'S BUILDING                      DIGITAL PSEUDO POINT SUMMARY                      Page 15  
 9520019D node:1 rev:16                      10:27:30, TUE, 19-NOV-13

CARD No: 128                      DIGITAL SUMMARY  
 256 Point Digital Pseudo                      P0 - P45

Point	Custom Label	Type	PNIS Codes
P0	SYSTEM RESET KEY	UTILITY	
P1	ALARM SILENCE KEY	UTILITY	
P2	FRONT PANEL LAMPTEST CONTROL (ANNUNC. 0)	UTILITY	
P3	FIRE ALARM DETECT	UTILITY	
P4	GLOBAL ACKNOWLEDGE ENABLE	UTILITY	
P5	SET SERVICE PSEUDO VALUES	UTILITY	
P6	ALARM SILENCE	UTILITY	
P7	EXTRA CARD IN THE SYSTEM	TROUBLE	
P8	KEYPAD ACTIVE	UTILITY	
P9	SYSTEM OUT OF CQB'S	TROUBLE	
P10	CODED INPUT ACTIVE	UTILITY	
P11	UNACKNOWLEDGED FIRE ALARM EXISTS	UTILITY	
P12	UNACKNOWLEDGED SUPERVISORY EXISTS	UTILITY	
P13	UNACKNOWLEDGED TROUBLE EXISTS	UTILITY	
P14	SYSTEM DISABLED - PROGRAMMER DOWNLOAD	TROUBLE	
P15	CFG RAM WRITE PROTECT MISSING (SW1-1)	TROUBLE	
P16	SMPL PROGRAM 0 - SYSTEM DEFAULT	UTILITY	

URI CCE points list 11-2013 (002)

P17	SMPL PROGRAM 1 - DEFAULT AUDIO	UTILITY
P18	SMPL PROGRAM 2 - SYSTEM OPTIONS (CODING)	UTILITY
P19	SYSTEM EMERGENCY DOOR LOCK OPERATION	UTILITY
P20	ELEVATOR DAMPER CONTROL OPERATION	UTILITY
P21	BYPASSES AND REMOTE MICROPHONE CONTROL	UTILITY
P22	DRILL SW DAYCARE/MET SCHOOL OPERATION	UTILITY
P23	SMPL PROGRAM 7 - USER CUSTOM CONTROL	UTILITY
P24	CODING GROUP 0 ACTIVE	UTILITY
P25	CODING GROUP 1 ACTIVE	UTILITY
P26	CODING GROUP 2 ACTIVE	UTILITY
P27	CODING GROUP 3 ACTIVE	UTILITY
P28	CODING GROUP 4 ACTIVE	UTILITY
P29	CODING GROUP 5 ACTIVE	UTILITY
P30	CODING GROUP 6 ACTIVE	UTILITY
P31	CODING GROUP 7 ACTIVE	UTILITY
P32	COLD START	TROUBLE
P33	WARM START	TROUBLE
P34	CITY DISCONNECT	TROUBLE
P35	MANUAL EVACUATION SWITCH INPUT	UTILITY
P36	ELEVATOR BYPASS	TROUBLE
P37	DOORHOLDER BYPASS	TROUBLE
P38	CONTROL POINT BYPASS	TROUBLE
P39	SYSTEM EXECUTING FROM RAM	TROUBLE
P40	AUTOMATIC DETECTOR RESET	UTILITY
P41	MASTER FIRE ALARM ACK KEY	UTILITY
P42	MASTER SUPERVISORY ACK KEY	UTILITY
P43	MASTER TROUBLE ACK KEY	UTILITY
P44	CODING BUS DISABLE SWITCH	UTILITY
P45	DRILL SWITCH INPUT	UTILITY

♀

SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 16  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 128 DIGITAL SUMMARY  
 256 Point Digital Pseudo P46 - P91  
 continued

Point	Custom Label	Type	PNIS Codes
P46	DOOR HOLDER TRIGGER	UTILITY	
P47	SIGNALS/VISUALS ACTIVE	UTILITY	
P48	MANUAL EVACUATION	FIRE	
P49	SYSTEM AT ACCESS LEVEL 1 OR GREATER	UTILITY	
P50	SYSTEM AT ACCESS LEVEL 2 OR GREATER	UTILITY	
P51	SYSTEM AT ACCESS LEVEL 3 OR GREATER	UTILITY	
P52	SYSTEM AT ACCESS LEVEL 4	UTILITY	
P53	SYSTEM LIST OVERFLOW - WARM START NEEDED	TROUBLE	
P54	NETWORK MIKE KEYED	UTILITY	
P55	CRT KEYPAD INACTIVITY TIMER DISABLE	UTILITY	
P56	CITY CIRCUIT STD TROUBLE RELAY OPERATION	UTILITY	
P57	KEYPAD INACTIVITY TIMER DISABLE	UTILITY	
P58	SYSTEM TIME/DATE INVALID OR NOT SET	TROUBLE	
P59	ALARM VERIFICATION TALLY LIMIT EXCEEDED	TROUBLE	
P60	ALARM VERIFICATION GROUP 0 ACTIVE	UTILITY	
P61	ALARM VERIFICATION GROUP 1 ACTIVE	UTILITY	
P62	ALARM VERIFICATION GROUP 2 ACTIVE	UTILITY	
P63	ALARM VERIFICATION GROUP 3 ACTIVE	UTILITY	
P64	ALARM VERIFICATION GROUP 4 ACTIVE	UTILITY	
P65	ALARM VERIFICATION GROUP 5 ACTIVE	UTILITY	
P66	ALARM VERIFICATION GROUP 6 ACTIVE	UTILITY	
P67	ALARM VERIFICATION GROUP 7 ACTIVE	UTILITY	
P68	FIRST STAGE TIMER EXPIRED	UTILITY	

URI CCE points list 11-2013 (002)

P69	THE EVAC MESSAGE HAS PLAYED	UTILITY
P70	WALK TEST GROUP 0 ENABLED	TROUBLE
P71	WALK TEST GROUP 1 ENABLED	TROUBLE
P72	WALK TEST GROUP 2 ENABLED	TROUBLE
P73	WALK TEST GROUP 3 ENABLED	TROUBLE
P74	WALK TEST GROUP 4 ENABLED	TROUBLE
P75	WALK TEST GROUP 5 ENABLED	TROUBLE
P76	WALK TEST GROUP 6 ENABLED	TROUBLE
P77	WALK TEST GROUP 7 ENABLED	TROUBLE
P78	ALARM SILENCE/ALARM CUTOUT PSEUDO	UTILITY
P79	RESET SPKRS WHEN AUDIO CODING COMPLETE	UTILITY
P80	MASTER MICROPHONE KEYED	UTILITY
P81	REMOTE MICROPHONE 1 KEYED	UTILITY
P82	REMOTE MICROPHONE 2 KEYED	UTILITY
P83	REMOTE MICROPHONE 1 READY TO TALK	UTILITY
P84	REMOTE MICROPHONE 2 READY TO TALK	UTILITY
P85	VTG 1 - ACTIVE	UTILITY
P86	VTG 2 - ACTIVE	UTILITY
P87	EVACUATION MESSAGE ON	UTILITY
P88	EVACUATION MESSAGE OFF	UTILITY
P89	EVACUATION MESSAGE LED	UTILITY
P90	ALERT MESSAGE ON	UTILITY
P91	ALERT MESSAGE OFF	UTILITY

‡

SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 17  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 128 DIGITAL SUMMARY  
 256 Point Digital Pseudo P92 - P137  
 continued

Point	Custom Label	Type	PNIS Codes
P92	ALERT MESSAGE LED	UTILITY	
P93	DRILL MESSAGE ON	UTILITY	
P94	DRILL MESSAGE OFF	UTILITY	
P95	DRILL MESSAGE LED	UTILITY	
P96	ALL CLEAR MESSAGE ON	UTILITY	
P97	ALL CLEAR MESSAGE OFF	UTILITY	
P98	ALL CLEAR MESSAGE LED	UTILITY	
P99	AUX MSG 1 ON	UTILITY	
P100	AUX MSG 1 OFF	UTILITY	
P101	AUX MSG 1 LED	UTILITY	
P102	AUX MSG 2 ON	UTILITY	
P103	AUX MSG 2 OFF	UTILITY	
P104	AUX MSG 2 LED	UTILITY	
P105	PHONE PAGING ON	UTILITY	
P106	PHONE PAGING OFF	UTILITY	
P107	PHONE PAGING LED	UTILITY	
P108	AUDIO OVERRIDE ON	UTILITY	
P109	AUDIO OVERRIDE OFF	UTILITY	
P110	AUDIO OVERRIDE TROUBLE	TROUBLE	
P111	ALL SPEAKERS MINUS ON	UTILITY	
P112	ALL SPEAKERS MINUS OFF	UTILITY	
P113	ALL SPEAKERS MINUS LED	UTILITY	
P114	ALL SPEAKERS CHANNEL 1 ON	UTILITY	
P115	ALL SPEAKERS CHANNEL 1 OFF	UTILITY	
P116	ALL SPEAKERS CHANNEL 1 LED	UTILITY	
P117	ALL SPEAKERS CHANNEL 2 ON	UTILITY	
P118	ALL SPEAKERS CHANNEL 2 OFF	UTILITY	
P119	ALL SPEAKERS CHANNEL 2 LED	UTILITY	
P120	ALL SPEAKERS CHANNEL 3 ON	UTILITY	

URI CCE points list 11-2013 (002)

P121	ALL SPEAKERS CHANNEL 3 OFF	UTILITY
P122	ALL SPEAKERS CHANNEL 3 LED	UTILITY
P123	LOCAL SPEAKER EVAC ON	UTILITY
P124	LOCAL SPEAKER EVAC OFF	UTILITY
P125	LOCAL SPEAKER EVAC LED	UTILITY
P126	LOCAL SPEAKER ALERT ON	UTILITY
P127	LOCAL SPEAKER ALERT OFF	UTILITY
P128	LOCAL SPEAKER ALERT LED	UTILITY
P129	ALL SPEAKERS TALK ON	UTILITY
P130	ALL SPEAKERS TALK OFF	UTILITY
P131	ALL SPEAKERS TALK LED	UTILITY
P132	ANALOG SENSOR ALMOST DIRTY LOG ENABLE	TROUBLE
P133	LOG ANALOG SENSOR PEAK VALUE ENABLE	UTILITY
P134	CLEAR ANALOG SENSOR PEAK VALUE	TROUBLE
P135	ALL ALERT	UTILITY
P136	ALL EVAC	UTILITY
P137	ALL ALERT LED	UTILITY

♀

-----  
 SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 18  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 128 DIGITAL SUMMARY  
 256 Point Digital Pseudo P138 - P183  
 continued

Point	Custom Label	Type	PNIS Codes
-----			
P138	MASTER MIKE PRETONE PLAYING ON VTG2	UTILITY	
P139	REMOTE MIKE 1 PRETONE PLAYING ON VTG2	UTILITY	
P140	REMOTE MIKE 2 PRETONE PLAYING ON VTG2	UTILITY	
P141	MANUAL AUDIO EVAC ON	UTILITY	
P142	MANUAL AUDIO EVAC OFF	UTILITY	
P143	MANUAL AUDIO EVAC LED	UTILITY	
P144	DISABLE SUPERVISION ON VTG 1 (2120 APPL)	UTILITY	
P145	DISABLE SUPERVISION ON VTG 2 (2120 APPL)	UTILITY	
P146	EMPTY AUDIO SERVICE QUEUE	UTILITY	
P147	EVAC MSG PLAYING WHEN MICROPHONE KEYED	UTILITY	
P148	SYSTEM OUT OF AQB'S	TROUBLE	
P149	SPEAKER SWITCH OFF AUTO	TROUBLE	
P150	AUDIO CODING GROUP 1 ACTIVE	UTILITY	
P151	AUDIO CODING GROUP 2 ACTIVE	UTILITY	
P152	VTG 1 - AUDIO SUPERVISION ACTIVE	UTILITY	
P153	VTG 2 - AUDIO SUPERVISION ACTIVE	UTILITY	
P154	PHONE TALK LINE RELAY FEEDBACK	UTILITY	
P155	PHONE NETWORK RELAY FEEDBACK	UTILITY	
P156	LOCAL MASTER PHONE HANDSET OFF HOOK	UTILITY	
P157	PHONE TALK LINE RELAY CONTROL INPUT	UTILITY	
P158	PHONE NETWORK RELAY CONTROL INPUT	UTILITY	
P159	PHONE TALK LINE RELAY CONTROL	UTILITY	
P160	PHONE NETWORK RELAY CONTROL	UTILITY	
P161	MASTER PHONE OFFHOOK SUPERVISION	TROUBLE	
P162	MASTER MIKE PRETONE PLAYING ON VTG1	UTILITY	
P163	REMOTE MIKE 1 PRETONE PLAYING ON VTG1	UTILITY	
P164	REMOTE MIKE 2 PRETONE PLAYING ON VTG1	UTILITY	
P165	AMPS SWITCHED TO BATTERY	UTILITY	
P166	ENABLE RM PHONE TO RM PHONE CONVERSATION	UTILITY	
P167	ALERT MSG PLAYING WHEN MICROPHONE KEYED	UTILITY	
P168	MICROPHONE TO EVAC IN EFFECT	UTILITY	
P169	MICROPHONE TO ALERT IN EFFECT	UTILITY	
P170	MICROPHONE TO TALK (CHANNEL 3) IN EFFECT	UTILITY	
P171	BACKGROUND MUSIC RELAY CHANNEL 1	UTILITY	
P172	BACKGROUND MUSIC RELAY CHANNEL 2	UTILITY	

URI CCE points list 11-2013 (002)

P173	BACKGROUND MUSIC RELAY CHANNEL 3	UTILITY
P174	VTG 1 CODE'S PRECODE PLAYING	UTILITY
P175	VTG 1 CODE'S AFTER CODE PLAYING	UTILITY
P176	AFTER CODE START - VTG 1	UTILITY
P177	VTG 1 'QUIET' MESSAGE PLAYING	UTILITY
P178	VTG 2 CODE'S PRECODE PLAYING	UTILITY
P179	VTG 2 CODE'S AFTER CODE PLAYING	UTILITY
P180	AFTER CODE START - VTG 2	UTILITY
P181	VTG 2 'QUIET' MESSAGE PLAYING	UTILITY
P182	(2120 APPL) VTG1 CODE START	UTILITY
P183	(2120 APPL) STOP VTG1 QUEUE	UTILITY

‡

SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 19  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 128 DIGITAL SUMMARY  
 256 Point Digital Pseudo P184 - P229  
 continued

Point	Custom Label	Type	PNIS Codes
P184	(2120 APPL) VTG2 CODE START	UTILITY	
P185	(2120 APPL) STOP VTG2 QUEUE	UTILITY	
P186	MIKE DISABLE	UTILITY	
P187	VTG & AMPLIFIER TROUBLE DISABLE	UTILITY	
P188	VTG SUPERVISION TONE NOT ACTIVE	TROUBLE	
P189	SATELLITE PHONE TIMEOUT DISABLE	UTILITY	
P190	NETWORK MIKE PRETONE PLAYING	UTILITY	
P191	MASTER MIKE KEYED	UTILITY	
P192	REMOTE MIKE 1 KEYED	UTILITY	
P193	REMOTE MIKE 2 KEYED	UTILITY	
P194	MIKES ARE READY TO PAGE	UTILITY	
P195	S21 SWITCH ACTIVATED	UTILITY	
P196	RAM BATTERY MISSING/FAILED	TROUBLE	
P197	2120 1 COMM LOSS	UTILITY	
P198	INHIBIT SONALERT	UTILITY	
P199	INHIBIT ALARM DEFAULT	UTILITY	
P200	FORCE COLD START	UTILITY	
P201	AC VOLTAGE FAILURE/BROWNOUT	UTILITY	
P202	DETECTOR RESET	UTILITY	
P203	LCD ANNUNCIATORS OVERRIDE KEYSWITCH	UTILITY	
P204	SIGNALS SILENCED	UTILITY	
P205	TRUEALARM SENSITIVITY MODIFIED	TROUBLE	
P206	PRINT QUEUE OVERFLOW	UTILITY	
P207	NETWORK DIAGNOSTIC MODE	TROUBLE	
P208	OUT OF NQB'S	TROUBLE	
P209	COMMUNICATIONS SHORT CIRCUIT TROUBLE	TROUBLE	
P210	NETWORK DETECTOR RESET	UTILITY	
P211	NETWORK SYSTEM RESET	UTILITY	
P212	DETECTOR/SYSTEM RESET	UTILITY	
P213	4120 NETWORK CARD CONFIGURED	UTILITY	
P214	CLEAR VERIFICATION TALLIES	TROUBLE	
P215	PRIORITY 2 ALARM DETECT	UTILITY	
P216	PRIORITY 2 ALARM RESET REQUEST	UTILITY	
P217	NETWORK SIGNAL SILENCE	UTILITY	
P218	UNACKNOWLEDGED PRIORITY 2 ALARM EXISTS	UTILITY	
P219	MASTER PRIORITY 2 ALARM ACK KEY	UTILITY	
P220	NETWORK PRIORITY 2 RESET	UTILITY	
P221	SIGNALS ACTIVE - OFF ON SILENCE	UTILITY	
P222	REMOTE DOWNLOAD ENABLED	TROUBLE	
P223	MASTER MICROPHONE READY TO TALK	UTILITY	
P224	NETWORK INITIALIZATION INCOMPLETE	TROUBLE	

URI CCE points list 11-2013 (002)

P225	NETWORK OPERATING IN DEGRADED STYLE-7	TROUBLE
P226	NETWORK INITIALIZATION IN PROGRESS	TROUBLE
P227	SDACT DATABASE VERSION MISMATCH	TROUBLE
P228	PREVENT TIME/DATE LOGGING	UTILITY
P229	TRUEALERT SILENT TEST ACTIVE	TROUBLE

♀

-----  
 SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 20  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 128 DIGITAL SUMMARY  
 256 Point Digital Pseudo P230 - P250  
 continued

Point	Custom Label	Type	PNIS Codes
-----	-----	-----	-----
P230	TRUEALERT DEVICE TEST MODE ACTIVE	TROUBLE	
P231	EXTRA NODE ON NETWORK	TROUBLE	
P232	NETWORK POINT LABEL UPDATING INHIBITED	TROUBLE	
P235	JUNIPER: LOW TRUEALARM VALUE	UTILITY	
P250	ENABLE END PAIR AND MONITOR LOGGING	UTILITY	

♀

-----  
 SHEPARD'S BUILDING DIGITAL PSEUDO POINT SUMMARY Page 21  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 129 DIGITAL SUMMARY  
 256 Point Digital Pseudo P256 - P257

Point	Custom Label	Type	PNIS Codes
-----	-----	-----	-----
P256	FAN/DAMPER CONTROL BYPASS	TROUBLE	
P257	SIGNAL CIRCUITS BYPASS	TROUBLE	

♀

-----  
 SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY Page 22  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 144 ANALOG SUMMARY  
 256 Point Analog Pseudo A0 - A45

Point	Custom Label	Type
-----	-----	-----
A0	NUMBER OF SYSTEM FIRE ALARMS	ANALOG
A1	NUMBER OF SYSTEM SUPERVISORIES	ANALOG
A2	NUMBER OF SYSTEM TROUBLES	ANALOG
A3	NUMBER OF OLD (UNCLEARED) FIRE ALARMS	ANALOG
A4	NUMBER OF OLD (UNCLEARED) SUPERVISORIES	ANALOG
A5	NUMBER OF OLD (UNCLEARED) TROUBLES	ANALOG
A6	CURRENT HOUR	ANALOG
A7	CURRENT MINUTE	ANALOG
A8	CURRENT SECOND	ANALOG
A9	CURRENT DAY	ANALOG
A10	CURRENT MONTH	ANALOG
A11	CURRENT YEAR	ANALOG
A12	CURRENT ACCESS LEVEL	ANALOG
A13	ACCESS LEVEL TIMEOUT	TIMER
A14	SYSTEM RESET WINDOW TIMER	TIMER
A15	SYSTEM RESET WINDOW TIMER SETPOINT	ANALOG
A16	DETECTOR RESET PULSE TIMER	TIMER
A17	4-WIRE RESET RELAY PULSE TIMER	TIMER

URI CCE points list 11-2013 (002)

A18	FIRE ALARM CLEAR DELAY TIMER	TIMER
A19	FIRE ALARM CLEAR DELAY TIMER SETPOINT	ANALOG
A20	FIRE ALARM CLEAR PULSE TIMER	TIMER
A21	SYSTEM RESET PULSE TIMER	TIMER
A22	ALARM SILENCE INHIBIT TIMER	TIMER
A23	ALARM SILENCE INHIBIT TIMER SETPOINT	ANALOG
A24	FIRE ALARM CUTOFF TIMER	TIMER
A25	FIRE ALARM CUTOFF TIMER SETPOINT	ANALOG
A26	FIRE ALARM CUTOFF SILENCE PULSE TIMER	TIMER
A27	TROUBLE REMINDER CYCLE TIMER	TIMER
A28	TROUBLE REMINDER OFF-TIME SETPOINT	ANALOG
A29	TROUBLE REMINDER ON-TIME SETPOINT	ANALOG
A30	DOOR HOLDER ALARM DROP TIMER	TIMER
A31	DOOR HOLDER ALARM DROP TIMER SETPOINT	ANALOG
A32	DOOR HOLDER BROWNOUT DROP TIMER	TIMER
A33	DOOR HOLDER BROWNOUT DROP TIMER SETPOINT	ANALOG
A34	SYSTEM STARTUP PULSE TIMER	TIMER
A35	FIRE ALARM AUDIBLE SIGNAL OPERATION	ANALOG
A36	FIRE ALARM VISUAL SIGNAL OPERATION	ANALOG
A37	ALARM VERIFICATION - RETARD TIME	ANALOG
A38	ALARM VERIFICATION - RESET TIME	ANALOG
A39	ALARM VERIFICATION - CONFIRMATION TIME	ANALOG
A40	ALARM VERIFICATION - TALLY LIMIT	ANALOG
A41	WALK TEST ABORT TIMEOUT SETPOINT	ANALOG
A42	WALK TEST REACTIVATE DELAY SETPOINT	ANALOG
A43	MONITOR ZONE ENABLE DELAY SETPOINT	ANALOG
A44	CODED INPUT TIMEOUT SETPOINT	ANALOG
A45	OFF TIME AFTER PNIS (NON-CONT.) CODES	ANALOG

‡

SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY Page 23  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 144 ANALOG SUMMARY  
 256 Point Analog Pseudo A46 - A91  
 continued

Point	Custom Label	Type
A46	CITY CIRCUIT CONFIGURATION	ANALOG
A47	ALERT TONE/MSG AFTER MICROPHONE UNKEYED	ANALOG
A48	TOTAL AUDIO CHANNELS	ANALOG
A49	CHANNEL 1 ROUTING	ANALOG
A50	CHANNEL 2 ROUTING	ANALOG
A51	CHANNEL 3 ROUTING	ANALOG
A52	LOCAL ROUTING	ANALOG
A53	EVAC TONE/MSG AFTER MICROPHONE UNKEYED	ANALOG
A54	SUPERVISION MSG#	ANALOG
A55	EVACUATION MSG#	ANALOG
A56	ALERT MSG#	ANALOG
A57	DRILL MSG#	ANALOG
A58	ALL CLEAR MSG#	ANALOG
A59	AUX 1 MSG#	ANALOG
A60	AUX 2 MSG#	ANALOG
A61	MICROPHONE PRETONE MSG#	ANALOG
A62	PHONE OFFHOOK TIMER	TIMER
A63	PHONE CALLBACK TIMER	TIMER
A64	PHONE TIMEOUT TIMER	TIMER
A65	REMOTE MASTER PHONE TIMEOUT TIMER	TIMER
A66	SPEAKER SWITCH OFF AUTO COUNT	ANALOG
A67	AUDIO RESET PULSE TIMER	TIMER
A68	VTG 1 PRIORITY	ANALOG
A69	VTG 2 PRIORITY	ANALOG

URI CCE points list 11-2013 (002)

A70	CHANNEL 1 ROUTING PRIORITY	ANALOG
A71	CHANNEL 2 ROUTING PRIORITY	ANALOG
A72	CHANNEL 3 ROUTING PRIORITY	ANALOG
A73	LOCAL SPEAKER ROUTING PRIORITY	ANALOG
A74	AUDIO SUPERVISION PULSE TIMER VTG1	TIMER
A75	AUDIO SUPERVISION PULSE TIMER VTG2	TIMER
A76	ENABLE/DISABLE STATISTIC GROUP	ANALOG
A77	ENABLE/DISABLE STATISTIC OUTPUT PORT	ANALOG
A78	5 SEC TIMER FOR REMOTE MASTER PHONES	TIMER
A79	CLEAR PEAK PULSE	ANALOG
A80	PRECODE MESSAGE NUMBER - VTG 1	ANALOG
A81	AFTER CODE MESSAGE NUMBER - VTG 1	ANALOG
A82	PRECODE MESSAGE NUMBER - VTG 2	ANALOG
A83	AFTER CODE MESSAGE NUMBER - VTG 2	ANALOG
A84	'QUIET' MESSAGE NUMBER	ANALOG
A85	2 SECOND TIMER - VTG 1	TIMER
A86	2 SECOND TIMER - VTG 2	TIMER
A87	MIKE INHIBIT TIMER	TIMER
A88	MIKE INHIBIT TIMER SETPOINT	ANALOG
A89	PHONE CALLBACK TIMER SETPOINT	ANALOG
A90	PHONE TIMEOUT TIMER SETPOINT	ANALOG
A91	VTG & AMPLIFIER TROUBLE DISABLE TIMER	TIMER

♀

SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY Page 24  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 144 ANALOG SUMMARY  
 256 Point Analog Pseudo A92 - A137  
 continued

Point	Custom Label	Type
A92	SUPERVISION NOT ACTIVE - TBL DELAY	TIMER
A93	4 WIRE DETECTOR RESET EXTEND	TIMER
A94	ACTIVE MESSAGE NUMBER - VTG 1	ANALOG
A95	ACTIVE MESSAGE NUMBER - VTG 2	ANALOG
A96	ACTUAL CHIPSET PLUGGED INTO VTG 1	ANALOG
A97	ACTUAL CHIPSET PLUGGED INTO VTG 2	ANALOG
A98	BATTERY TROUBLE COUNTER	COUNTER
A99	AC POWER FAIL COUNTER	COUNTER
A100	SYSTEM TYPE	ANALOG
A101	FIRST STAGE TIMER	ANALOG
A102	FIRST STAGE TIMER SETPOINT	ANALOG
A103	MASTER MIKE 5 SECOND UNKEY DELAY	ANALOG
A104	REMOTE MIKE 1 5 SECOND UNKEY DELAY	ANALOG
A105	REMOTE MIKE 2 5 SECOND UNKEY DELAY	ANALOG
A106	MASTER MIKE'S PRETONE TIMER	ANALOG
A107	MASTER MIKE'S PRETONE SETPOINT	ANALOG
A108	REMOTE MIKE 1'S PRETONE TIMER	ANALOG
A109	REMOTE MIKE 1'S PRETONE SETPOINT	ANALOG
A110	REMOTE MIKE 2'S PRETONE TIMER	ANALOG
A111	REMOTE MIKE 2'S PRETONE SETPOINT	ANALOG
A112	GROUND TROUBLE COUNTER	COUNTER
A113	PAGING CHANNEL	ANALOG
A114	TRUEALARM MODIFICATION COUNTER	COUNTER
A115	EXCESSIVELY DIRTY (OUT OF RANGE)	ANALOG
A116	DIRTY SENSOR COUNTER	COUNTER
A117	ALMOST DIRTY COUNTER	COUNTER
A118	ALARMS SILENCED DELAY TIMER	TIMER
A119	NUMBER OF LOCAL SYSTEM POINTS' TROUBLES	COUNTER
A120	SYSTEM PAGING STATUS	ANALOG
A121	KEYPAD INACTIVITY TIMEOUT SETPOINT	ANALOG

URI CCE points list 11-2013 (002)

A122	NUMBER OF SYSTEM PRIORITY 2 ALARMS	ANALOG
A123	NUMBER OF OLD (UNCLEARED) PRI2 ALARMS	ANALOG
A124	PRI2 RESET WINDOW TIMER	TIMER
A125	PRI2 RESET WINDOW TIMER SETPOINT	ANALOG
A126	PRI2 ALARM CLEAR DELAY TIMER	TIMER
A127	PRI2 ALARM CLEAR DELAY TIMER SETPOINT	ANALOG
A128	PRI2 ALARM CLEAR PULSE TIMER	TIMER
A129	PRIORITY 2 RESET PULSE TIMER	TIMER
A130	PRIORITY 2 RESET START TIMER	TIMER
A131	SUPERVISION DELAY SETPOINT CHL1	ANALOG
A132	SUPERVISION DELAY SETPOINT CHL2	ANALOG
A133	SUPERVISION NOT ACTIVE DELAY SETPOINT	ANALOG
A134	LEFT END NETWORK NODE	ANALOG
A135	RIGHT END NETWORK NODE	ANALOG
A136	TRUEALERT DIAGNOSTICS TIMER	TIMER
A137	TRUEALARM CONSTANT VALUE	ANALOG

♀

SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY Page 25  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 144 ANALOG SUMMARY  
 256 Point Analog Pseudo A138 - A138  
 continued

Point	Custom Label	Type
A138	TRUEALARM LOW VALUE FILTER DELAY	ANALOG

♀

SHEPARD'S BUILDING ANALOG PSEUDO POINT SUMMARY Page 26  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 145 ANALOG SUMMARY  
 256 Point Analog Pseudo

no labels assigned - presumed unused

♀

SHEPARD'S BUILDING POINT LIST SUMMARY Page 27  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 POINT LIST  
 256 Point List Pseudo L0 - L42

List Name	Description	Points
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)	36
L1	CODING GROUP 1 SIGNALS/RELAYS	EMPTY
L2	CODING GROUP 2 SIGNALS/RELAYS	EMPTY
L3	CODING GROUP 3 SIGNALS/RELAYS	EMPTY
L4	CODING GROUP 4 SIGNALS/RELAYS	EMPTY
L5	CODING GROUP 5 SIGNALS/RELAYS	EMPTY
L6	CODING GROUP 6 SIGNALS/RELAYS	EMPTY
L7	CODING GROUP 7 SIGNALS/RELAYS	EMPTY
L8	FIRE ALARM SIGNALS OFF ON SILENCE	35
L9	FIRE ALARM SIGNALS OFF ON RESET	EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE	EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET	11
L12	FIRE ALARM VISUALS OFF ON SILENCE	1

URI CCE points list 11-2013 (002)

L13	FIRE ALARM VISUALS OFF ON RESET	EMPTY
L14	TROUBLE RELAYS OFF ON CLEAR	EMPTY
L15	TROUBLE RELAYS OFF ON ACKNOWLEDGE	EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET	EMPTY
L17	DOOR HOLDER CONTROL RELAYS	14
L18	GENERAL FIRE ALARM MONITOR ZONES	277
L19	PRIMARY ELEVATOR RECALL MONITOR ZONES	201
L20	ALTERNATE ELEVATOR RECALL MONITOR ZONES	75
L21	PRIMARY ELEVATOR CAPTURE RELAYS	2
L22	ALTERNATE ELEVATOR CAPTURE RELAYS	2
L23	WATERFLOW ALARM MONITOR ZONES	14
L24	WATERFLOW SIGNALS OFF ON SILENCE	EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET	EMPTY
L26	SPRINKLER SUPERVISORY MONITOR ZONES	8
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS	EMPTY
L28	USER SYSTEM LISTS	23
L29	EDITABLE GENERAL ALARM SYSTEM LISTS	24
L30	ALARM VERIFICATION GROUP 0	EMPTY
L31	ALARM VERIFICATION GROUP 1	EMPTY
L32	ALARM VERIFICATION GROUP 2	EMPTY
L33	ALARM VERIFICATION GROUP 3	EMPTY
L34	ALARM VERIFICATION GROUP 4	EMPTY
L35	ALARM VERIFICATION GROUP 5	EMPTY
L36	ALARM VERIFICATION GROUP 6	EMPTY
L37	ALARM VERIFICATION GROUP 7	EMPTY
L38	4 WIRE MONITOR ZONES	EMPTY
L39	NOT USED	EMPTY
L40	WALK TEST GROUP 0	296
L41	WALK TEST GROUP 1	EMPTY
L42	WALK TEST GROUP 2	EMPTY

NOTE: \* Indicates Auto List Generation disabled for system list.

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST SUMMARY

Page 28  
10:27:30, TUE, 19-NOV-13

CARD No: 160  
256 Point List Pseudo

POINT LIST  
L43 - L85

continued

List Name	Description	Points
L43	WALK TEST GROUP 3	EMPTY
L44	WALK TEST GROUP 4	EMPTY
L45	WALK TEST GROUP 5	EMPTY
L46	WALK TEST GROUP 6	EMPTY
L47	WALK TEST GROUP 7	EMPTY
L48	VNACS OFF ON SILENCE	EMPTY
L49	VNACS OFF ON RESET	EMPTY
L50	WALK TEST GROUP 0 - SIGNALS/RELAYS	56
L51	WALK TEST GROUP 1 - SIGNALS/RELAYS	EMPTY
L52	WALK TEST GROUP 2 - SIGNALS/RELAYS	EMPTY
L53	WALK TEST GROUP 3 - SIGNALS/RELAYS	EMPTY
L54	WALK TEST GROUP 4 - SIGNALS/RELAYS	EMPTY
L55	WALK TEST GROUP 5 - SIGNALS/RELAYS	EMPTY
L56	WALK TEST GROUP 6 - SIGNALS/RELAYS	EMPTY
L57	WALK TEST GROUP 7 - SIGNALS/RELAYS	EMPTY
L58	NOT USED	EMPTY
L59	NOT USED	EMPTY
L60	CODING GROUP 0 - NOT USED (NON-PNIS)	EMPTY
L61	CODING GROUP 1 - MONITOR ZONES	EMPTY

URI CCE points list 11-2013 (002)

L62	CODING GROUP 2 - MONITOR ZONES	EMPTY
L63	CODING GROUP 3 - MONITOR ZONES	EMPTY
L64	CODING GROUP 4 - MONITOR ZONES	EMPTY
L65	CODING GROUP 5 - MONITOR ZONES	EMPTY
L66	CODING GROUP 6 - MONITOR ZONES	EMPTY
L67	CODING GROUP 7 - MONITOR ZONES	EMPTY
L68	NOT USED	EMPTY
L69	NOT USED	EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM	EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM	EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET	5
L73	CONTROL POINTS OFF - ON SYSTEM RESET	2
L74	CONTROL POINTS OFF - ON SILENCE	1
L75	LPHONE MODE LEDS TRACKING DIGITAL PSEUDO	EMPTY
L76	VARIABLE SENSITIVITY PHOTO ANALOG SENSOR	204
L77	VARIABLE SENSITIVITY ION ANALOG SENSOR	EMPTY
L78	ANALOG SENSORS WITH PIEZO	EMPTY
L79	ANALOG SENSORS WITH RELAY	EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS	20
L81	AUDIO CODING GROUP 1 - MONITOR ZONES	EMPTY
L82	AUDIO CODING GROUP 2 - MONITOR ZONES	EMPTY
L83	AUX1 MESSAGE SPEAKERS	EMPTY
L84	AUX2 MESSAGE SPEAKERS	EMPTY
L85	RESTART MESSAGE AFTER MIKE - VTG 1	EMPTY

NOTE: \* Indicates Auto List Generation disabled for system list.

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST SUMMARY

Page 29  
10:27:30, TUE, 19-NOV-13

CARD No: 160  
256 Point List Pseudo

POINT LIST  
L86 - L136

continued

List Name	Description	Points
L86	RESTART MESSAGE AFTER MIKE - VTG 2	EMPTY
L87	AHU RELAYS ON - ON FIRE ALARM	2
L88	AHU RELAYS OFF - ON FIRE ALARM	EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET	2
L90	ALL SPEAKERS - NON EDITABLE	20
L91	AUDIO CODING GROUP 1 - SIGNAL CIRCUITS	EMPTY
L92	AUDIO CODING GROUP 2 - SIGNAL CIRCUITS	EMPTY
L93	PHONE CIRCUITS	EMPTY
L94	REMOTE MASTER PHONE CIRCUITS	EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF	EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT	EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH	EMPTY
L98	SWITCH POWER SUPPLY AMPS TO BATTERY	6
L99	SWITCH POWER SUPPLY AMPS TO BKGRND MUSIC	6
L100	POINTS TO EXCLUDE FROM AUTOMAP	EMPTY
L101	RESET POWER SUPPLY AMPS	6
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS	22
L103	EXTERNAL DETECTOR RESET PSEUDO	EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO	EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO	EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO	EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE	EMPTY
L108	EXTERNAL SPEAKERS AND SPEAKER LISTS	EMPTY
L109	ALARM SILENCED LED CONTROL	2
L110	INHIBIT NETWORK LABEL UPDATE	EMPTY

URI CCE points list 11-2013 (002)

L112	EXTERNAL PRIORITY 2 RESET PSEUDOS	EMPTY
L128	ALL EMERGENCY EXIT DOOR LOCKS	5
L129	GROUND FLOOR SPEAKER CIRCUITS	2
L130	SECOND FLOOR SPEAKER CIRCUITS	2
L131	THIRD FLOOR SPEAKER CIRCUITS	1
L132	FOURTH FLOOR SPEAKER CIRCUITS	1
L133	DAYCARE SPEAKER CIRCUITS	1
L134	MET SCHOOL SPEAKER CIRCUITS	1
L135	ALL STROBE CIRCUITS FOR BLDG DRILL	36
L136	ALL SPEAKER CIRCUITS FOR ALL BLDG DRILL	20

NOTE: \* Indicates Auto List Generation disabled for system list.

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 30  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L0 POINT LIST  
 256 Point List Pseudo  
 LIST No: 0 L0  
 continued

Description: CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

URI CCE points list 11-2013 (002)

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 31  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L8 POINT LIST  
 256 Point List Pseudo  
 LIST No: 8 L8

continued

Description: FIRE ALARM SIGNALS OFF ON SILENCE

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 32  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L11 POINT LIST  
 256 Point List Pseudo  
 LIST No: 11 L11

continued

Description: FIRE ALARM RELAYS OFF ON RESET

URI CCE points list 11-2013 (002)

Point	Custom Point Label	Type	Type
AUX4	AUX RELAY POINT AUX4		RRELAY
AUX9	SPARE		RRELAY
AUX10	SPARE		RRELAY
AUX13	SPARE		RRELAY
AUX14	SPARE		RRELAY
AUX17	SPARE		RRELAY
AUX18	SPARE		RRELAY
AUX21	GAS VALVE SHUTDOWN	AUX21	RRELAY
AUX22	SPARE		RRELAY
AUX25	SPARE		RRELAY
AUX26	SPARE		RRELAY

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 33  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L12 POINT LIST  
 256 Point List Pseudo  
 LIST No: 12 L12 continued

Description: FIRE ALARM VISUALS OFF ON SILENCE

Point	Custom Point Label	Device Type	Point Type
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 34  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L17 POINT LIST  
 256 Point List Pseudo  
 LIST No: 17 L17 continued

Description: DOOR HOLDER CONTROL RELAYS

Point	Custom Point Label	Device Type	Point Type
AUX3	LOWER LEVEL DOOR HOLDER CIRCUIT	AUX3	DHOLDER
AUX5	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX5	DHOLDER
AUX6	TURNSTILE RELSE SECURITY DESK 1 ENT.	AUX6	DHOLDER
M1-46	TURNSTILE RELSE SECURITY DESK2 ENT.	M1-46 RZAM	DHOLDER
AUX7	GROUND FLOOR NORTH DOOR HOLDER CIR	AUX7	DHOLDER
AUX8	SECOND FLOOR NORTH DOOR HOLDER CIR	AUX8	DHOLDER
AUX11	GROUND FLOOR SOUTH DOOR HOLDER CIR	AUX11	DHOLDER
AUX12	SECOND FLOOR SOUTH DOOR HOLDER CIR	AUX12	DHOLDER
AUX15	THIRD FLOOR DOOR HOLDER CIRCUIT	AUX15	DHOLDER
AUX16	FOURTH FLOOR DOOR HOLDER CIRCUIT	AUX16	DHOLDER
AUX19	THIRD FLOOR SOUTH DOOR HOLDER CIR	AUX19	DHOLDER
AUX20	FOURTH FLOOR SOUTH DOOR HOLDER CIR	AUX20	DHOLDER
AUX23	FIFTH FLOOR NORTH DOOR HOLDER CIR	AUX23	DHOLDER
AUX24	SIXTH FLOOR NORTH DOOR HOLDER CIR	AUX24	DHOLDER

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 35  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

URI CCE points list 11-2013 (002)

CARD No: 160 L18  
 256 Point List Pseudo  
 LIST No: 18

POINT LIST

L18  
 continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16 ADRPUL	PULL
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23 ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25 ADRPUL	PULL
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27 ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36 ADRPUL	PULL
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40 ADRPUL	PULL
M1-48	ZN 4 GROUND FLOOR SECURITY OFFICE	M1-48 PHOTO	SMOKE
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	ZN4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL

SHEPARD'S BUILDING  
 9520019D node:1 rev:16

POINT LIST DETAIL

Page 36  
 10:27:30, TUE, 19-NOV-13

CARD No: 160 L18  
 256 Point List Pseudo  
 LIST No: 18

POINT LIST

L18  
 continued

Description: GENERAL FIRE ALARM MONITOR ZONES

URI CCE points list 11-2013 (002)

Point	Custom Point Label	Device Type	Point Type
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL	PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL	PULL
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 37  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L18  
256 Point List Pseudo  
LIST No: 18

POINT LIST

L18  
continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M2-112	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-112	PHOTO	SMOKE
M2-113	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-113	PHOTO	SMOKE
M2-115	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-115	ADRPUL	PULL
M2-116	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-116	PHOTO	SMOKE
M2-117	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-117	PHOTO	SMOKE
M2-118	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-118	PHOTO	SMOKE
M2-119	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-119	PHOTO	SMOKE
M2-120	ZN6	SECOND	FLOOR	NORTH-STAIR F	M2-120	PHOTO	SMOKE
M2-121	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-121	PHOTO	SMOKE
M2-122	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-122	PHOTO	SMOKE
M2-123	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-123	PHOTO	SMOKE
M2-124	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-124	ADRPUL	PULL
M2-126	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-126	PHOTO	SMOKE
M2-127	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-127	PHOTO	SMOKE
M3-1	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-1	ADRPUL	PULL
M3-4	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-4	PHOTO	SMOKE
M3-5	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-5	PHOTO	SMOKE
M3-6	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-6	PHOTO	SMOKE
M3-7	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-7	PHOTO	SMOKE
M3-8	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-8	PHOTO	SMOKE
M3-9	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-9	PHOTO	SMOKE
M3-10	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-10	ADRPUL	PULL
M3-11	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-11	PHOTO	SMOKE
M3-12	ZN5	GROUND	FLOOR	SOUTH-SPKLR FLOW	M3-12	MAZAM	WATER
M3-13	ZN5	GROUND	FLOOR	SOUTH-STAIR D	M3-13	PHOTO	SMOKE
M3-14	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-14	PHOTO	SMOKE
M3-15	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-15	PHOTO	SMOKE
M3-16	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-16	PHOTO	SMOKE
M3-17	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-17	PHOTO	SMOKE
M3-18	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-18	PHOTO	SMOKE
M3-19	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-19	PHOTO	SMOKE
M3-20	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-20	ADRPUL	PULL
M3-21	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-21	ADRPUL	PULL
M3-22	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-22	PHOTO	SMOKE
M3-23	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-23	PHOTO	SMOKE
M3-24	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-24	PHOTO	SMOKE
M3-25	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-25	ADRPUL	PULL
M3-26	ZN5	GROUND	FLOOR	SOUTH-STUDNT CNTR	M3-26	ADRPUL	PULL
M3-27	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-27	PHOTO	SMOKE
M3-28	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-28	PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 38  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L18  
256 Point List Pseudo  
LIST No: 18

POINT LIST  
L18  
continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M3-56	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-56	PHOTO	SMOKE
M3-57	ZN5	GROUND	FLOOR	DAY CARE ROOM 139	M3-57	PHOTO	SMOKE
M3-110	ZN7	SECOND	FLOOR	SOUTH-ELECTRC RM	M3-110	PHOTO	SMOKE
M3-111	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-111	PHOTO	SMOKE
M3-112	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-112	PHOTO	SMOKE
M3-113	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-113	PHOTO	SMOKE
M3-114	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-114	ADRPUL	PULL
M3-115	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-115	PHOTO	SMOKE
M3-116	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-116	PHOTO	SMOKE
M3-117	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-117	PHOTO	SMOKE
M3-118	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-118	PHOTO	SMOKE
M3-119	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-119	PHOTO	SMOKE
M3-120	ZN7	SECOND	FLOOR	SOUTH-SPKLR FLOW	M3-120	MAZAM	WATER
M3-121	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-121	ADRPUL	PULL
M3-122	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-122	PHOTO	SMOKE
M3-123	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-123	PHOTO	SMOKE
M3-124	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-124	PHOTO	SMOKE
M3-125	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-125	PHOTO	SMOKE
M3-126	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-126	PHOTO	SMOKE
M3-127	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-127	PHOTO	SMOKE
M4-1	ZN8	THIRD	FLOOR	NORTH-STAIR A	M4-1	PHOTO	SMOKE
M4-2	ZN8	THIRD	FLR	NORTH-PASS ELEV LOBBY	M4-2	ADRPUL	PULL
M4-3	ZN8	THIRD	FLR	NORTH-PASS ELEV LOBBY	M4-3	PHOTO	SMOKE
M4-4	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-4	PHOTO	SMOKE
M4-5	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-5	PHOTO	SMOKE
M4-6	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-6	PHOTO	SMOKE
M4-7	ZN8	THIRD	FLR	NORTH-ELECTRIC RM 305	M4-7	PHOTO	SMOKE
M4-8	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-8	PHOTO	SMOKE
M4-9	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-9	PHOTO	SMOKE
M4-10	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-10	PHOTO	SMOKE
M4-11	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-11	ADRPUL	PULL
M4-12	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-12	PHOTO	SMOKE
M4-13	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-13	PHOTO	SMOKE
M4-14	ZN8	THIRD	FLOOR	NORTH-CORRIDOR	M4-14	PHOTO	SMOKE

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 39  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L18  
256 Point List Pseudo  
LIST No: 18

POINT LIST

L18  
continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL

URI CCE points list 11-2013 (002)

M4-116	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-116	PHOTO	SMOKE
M4-117	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-117	PHOTO	SMOKE
M4-118	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-118	PHOTO	SMOKE
M4-119	ZN10	FOURTH FLR NO-FR ELEV LOBBY	M4-119	ADRPUL	PULL
M4-120	ZN10	FOURTH FLR NO-FR ELEV LOBBY	M4-120	PHOTO	SMOKE
M4-121	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-121	PHOTO	SMOKE
M4-122	ZN10	FOURTH FLR NO-ELECT RM 414	M4-122	PHOTO	SMOKE
M4-123	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-123	PHOTO	SMOKE
M4-124	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-124	PHOTO	SMOKE
M4-125	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-125	PHOTO	SMOKE
M4-126	ZN10	FOURTH FL NO-PASS ELEV LOBBY	M4-126	PHOTO	SMOKE
M4-127	ZN10	FOURTH FL NO-PASS ELEV LOBBY	M4-127	ADRPUL	PULL
M5-1	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-1	PHOTO	SMOKE
M5-2	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-2	PHOTO	SMOKE
M5-3	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-3	PHOTO	SMOKE
M5-4	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-4	PHOTO	SMOKE
M5-6	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-6	PHOTO	SMOKE
M5-7	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-7	ADRPUL	PULL
M5-8	ZN9	THIRD FLOOR SOUTH-SPKLR FLOW	M5-8	MAZAM	WATER
M5-9	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-9	PHOTO	SMOKE
M5-10	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-10	PHOTO	SMOKE
M5-11	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-11	PHOTO	SMOKE
M5-12	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-12	PHOTO	SMOKE
M5-13	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-13	ADRPUL	PULL
M5-14	ZN9	THIRD FLOOR SOUTH-ELECT RM 320	M5-14	PHOTO	SMOKE
M5-15	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-15	PHOTO	SMOKE
M5-16	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-16	PHOTO	SMOKE
M5-17	ZN9	THIRD FLOOR SOUTH-CORRIDOR	M5-17	PHOTO	SMOKE

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 40  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L18 POINT LIST  
 256 Point List Pseudo  
 LIST No: 18 L18  
 continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113 ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115 PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116 PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117 PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122 ADRPUL	PULL
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124 PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125 PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M5-127	ZN11	FOURTH FLOOR SOUTH-CORRIDOR	M5-127	PHOTO	SMOKE
M6-1	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-1	PHOTO	SMOKE
M6-2	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-2	PHOTO	SMOKE
M6-3	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-3	ADRPUL	PULL
M6-5	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-5	ADRPUL	PULL
M6-6	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-6	PHOTO	SMOKE
M6-7	ZN12	FIFTH FLR NO-PASS ELEV LOBBY	M6-7	PHOTO	SMOKE
M6-8	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-8	PHOTO	SMOKE
M6-9	ZN12	FIFTH FLR NORTH-ELECT RM 519	M6-9	PHOTO	SMOKE
M6-10	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-10	PHOTO	SMOKE
M6-11	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-11	PHOTO	SMOKE
M6-12	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-12	ADRPUL	PULL
M6-13	ZN12	FIFTH FLR NORTH-FR ELEV LOBBY	M6-13	PHOTO	SMOKE
M6-14	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-14	PHOTO	SMOKE
M6-15	ZN12	FIFTH FLR NORTH-ELECT RM 516	M6-15	PHOTO	SMOKE
M6-16	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-16	PHOTO	SMOKE
M6-17	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-17	ADRPUL	PULL
M6-18	ZN12	FIFTH FLOOR NORTH-SPKLR FLOW	M6-18	MAZAM	WATER
M6-19	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-19	PHOTO	SMOKE
M6-20	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-20	ADRPUL	PULL
M6-21	ZN12	FIFTH FLOOR NORTH-CORRIDOR	M6-21	PHOTO	SMOKE
M6-97	ZN13	SIXTH FLR NORTH-ELECT RM 630	M6-97	PHOTO	SMOKE

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 41  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L18 POINT LIST  
 256 Point List Pseudo  
 LIST No: 18 L18

continued

Description: GENERAL FIRE ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100 ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102 MAZAM	HEAT
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106 HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE
M6-108	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-108 ADRPUL	PULL
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109 PHOTO	SMOKE
M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110 MAZAM	WATER
M6-111	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-111 ADRPUL	PULL
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112 PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113 PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114 PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115 PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116 PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117 PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118 PHOTO	SMOKE
M6-119	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119 HEAT	HEAT
M6-120	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120 HEAT	HEAT
M6-121	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121 HEAT	HEAT
M6-122	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-122 ADRPUL	PULL
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE
M6-124	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124 MAZAM	FIRE

♀

URI CCE points list 11-2013 (002)

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 42  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L19  
256 Point List Pseudo  
LIST No: 19

POINT LIST

L19  
continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-16	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-16 ADRPUL	PULL
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-23	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-23 ADRPUL	PULL
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-25	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-25 ADRPUL	PULL
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-27	ZN2 LOWER LEVEL NO-MECH RM 011	M1-27 ADRPUL	PULL
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE
M1-36	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-36 ADRPUL	PULL
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M1-39	ZN3 LOWER LEVEL SOUTH-STAIR D	M1-39 PHOTO	SMOKE
M1-40	ZN3 LOWER LEVEL SOUTH-CORRIDOR	M1-40 ADRPUL	PULL
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 43  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L19  
256 Point List Pseudo

POINT LIST

URI CCE points list 11-2013 (002)

LIST No: 19

L19  
continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE
M2-124	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-124 ADRPUL	PULL
M2-126	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-126 PHOTO	SMOKE
M2-127	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-127 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-114	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-114 ADRPUL	PULL
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M3-121	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-121 ADRPUL	PULL
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 44  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L19  
256 Point List Pseudo  
LIST No: 19

POINT LIST

L19  
continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Device Point

URI CCE points list 11-2013 (002)

Point	Custom Point Label	Type	Type
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11 ADRPUL	PULL
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-119	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-119 ADRPUL	PULL
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE
M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126 PHOTO	SMOKE
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-127 ADRPUL	PULL
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-7 ADRPUL	PULL
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 45  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L19  
256 Point List Pseudo  
LIST No: 19

POINT LIST

L19  
continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10 PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11 PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12 PHOTO	SMOKE
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-13 ADRPUL	PULL

URI CCE points list 11-2013 (002)

M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14 PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15 PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16 PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17 PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113 ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115 PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116 PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117 PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122 ADRPUL	PULL
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124 PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125 PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126 PHOTO	SMOKE
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127 PHOTO	SMOKE
M6-1	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-1 PHOTO	SMOKE
M6-2	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-2 PHOTO	SMOKE
M6-3	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-3 ADRPUL	PULL
M6-5	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-5 ADRPUL	PULL
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6 PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7 PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8 PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9 PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10 PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11 PHOTO	SMOKE
M6-12	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-12 ADRPUL	PULL
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13 PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14 PHOTO	SMOKE

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 46  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L19  
256 Point List Pseudo  
LIST No: 19

POINT LIST

L19  
continued

Description: PRIMARY ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE
M6-17	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-17 ADRPUL	PULL
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE
M6-20	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-20 ADRPUL	PULL
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21 PHOTO	SMOKE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97 PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL

URI CCE points list 11-2013 (002)

M6-100	ZN15	FREIGHT ELEVATOR PENTHOUSE	M6-100	ADRPUL	PULL
M6-101	ZN15	FREIGHT ELEVATOR PENTHOUSE	M6-101	PHOTO	SMOKE
M6-102	ZN15	FREIGHT ELEV PENTHOUSE REAR	M6-102	MAZAM	HEAT
M6-105	ZN13	SIXTH FL NORTH-FR ELEV LOBBY	M6-105	PHOTO	SMOKE
M6-106	ZN15	TOP OF FREIGHT ELEV SHAFT	M6-106	HEAT	HEAT
M6-107	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-107	PHOTO	SMOKE
M6-108	ZN13	SIXTH FL NORTH-FR ELEV LOBBY	M6-108	ADRPUL	PULL
M6-109	ZN13	SIXTH FLOOR NORTH-STAIR B	M6-109	PHOTO	SMOKE
M6-110	ZN13	SIXTH FLOOR NORTH-SPKLR FLOW	M6-110	MAZAM	WATER
M6-111	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-111	ADRPUL	PULL
M6-112	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-112	PHOTO	SMOKE
M6-113	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-113	PHOTO	SMOKE
M6-114	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-114	PHOTO	SMOKE
M6-115	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-115	PHOTO	SMOKE
M6-116	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-116	PHOTO	SMOKE
M6-117	ZN13	SIXTH FLOOR NORTH-CORRIDOR	M6-117	PHOTO	SMOKE
M6-118	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-118	PHOTO	SMOKE
M6-119	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-119	HEAT	HEAT
M6-120	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-120	HEAT	HEAT
M6-121	ZN14	TOP OF PASSENGER ELEV SHAFT	M6-121	HEAT	HEAT
M6-122	ZN13	SIXTH FLR NO-PASS ELEV LOBBY	M6-122	ADRPUL	PULL
M6-123	ZN13	SIXTH FLOOR NORTH-STAIR A	M6-123	PHOTO	SMOKE
M6-124	ZN13	6TH FLOOR COMPUTER RM FM200	M6-124	MAZAM	FIRE

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 47  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L20 POINT LIST  
 256 Point List Pseudo  
 LIST No: 20 L20 continued

Description: ALTERNATE ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-1 ADRPUL	PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE	M2-2 PHOTO	SMOKE
M2-3	ZN4 GROUND FLOOR NORTH-FOYER	M2-3 PHOTO	SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-4 PHOTO	SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-5 PHOTO	SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F	M2-6 PHOTO	SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-7 PHOTO	SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A	M2-8 PHOTO	SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-9 ADRPUL	PULL
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY	M2-10 PHOTO	SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-11 ADRPUL	PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-12 PHOTO	SMOKE
M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M2-26	ZN4	GROUND	FLOOR	NO-MAIN ELECT RM	M2-26	PHOTO	SMOKE
M2-27	ZN4	GROUND	FLOOR	NO-MAIN ELECT RM	M2-27	PHOTO	SMOKE
M2-28	ZN4	GROUND	FLOOR	NORTH-CORRIDOR	M2-28	PHOTO	SMOKE
M2-29	ZN4	GROUND	FLOOR	NORTH-CORRIDOR	M2-29	ADRPUL	PULL
M2-30	ZN4	GROUND	FLOOR	NORTH-STAIR B	M2-30	PHOTO	SMOKE
M2-31	ZN4	GROUND	FLOOR	NORTH-STAIR B	M2-31	ADRPUL	PULL
M2-33	ZN4	GROUND	FLOOR	NORTH-SPKLR FLOW	M2-33	MAZAM	WATER
M2-34	ZN4	GROUND	FL	NO-EMERGENCY POWR RM	M2-34	PHOTO	SMOKE
M2-35	ZN4	GROUND	FL	NO-MAIN ELECT RM 151	M2-35	ADRPUL	PULL
M2-36	ZN4	GROUND	FLOOR	NORTH-STAIR A	M2-36	ADRPUL	PULL
M2-37	ZN4	GROUND	FLOOR	NORTH-CORRIDOR	M2-37	PHOTO	SMOKE
M2-38	ZN4	GROUND	FLOOR	NORTH-LIBRARY 101	M2-38	ADRPUL	PULL
M2-48		KITCHEN	GROUND	FL N SUPPRESS SYS	M2-48	MAZAM	SUPDET
M3-1	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-1	ADRPUL	PULL
M3-4	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-4	PHOTO	SMOKE
M3-5	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-5	PHOTO	SMOKE
M3-6	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-6	PHOTO	SMOKE

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 48  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L20  
256 Point List Pseudo  
LIST No: 20

POINT LIST

L20  
continued

Description: ALTERNATE ELEVATOR RECALL MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M3-7	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-7 PHOTO	SMOKE
M3-8	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-8 PHOTO	SMOKE
M3-9	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-9 PHOTO	SMOKE
M3-10	ZN5 GROUND FLOOR SOUTH-VESTIBULE	M3-10 ADRPUL	PULL
M3-11	ZN5 GROUND FLOOR SOUTH-FOYER	M3-11 PHOTO	SMOKE
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25 ADRPUL	PULL
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26 ADRPUL	PULL
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M3-57 ZN5 GROUND FLOOR DAY CARE ROOM 139 M3-57 PHOTO SMOKE  
 M2-32 GROUND FL RECEIVING ROOM M2-32 ADRPUL PULL  
 ‡

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 49  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L21 POINT LIST  
 256 Point List Pseudo  
 LIST No: 21 L21  
 continued

Description: PRIMARY ELEVATOR CAPTURE RELAYS

Point	Custom Point Label	Device Type	Point Type
M6-104	FREIGHT ELEVATOR PRIMARY RECALL	M6-104 RZAM	PRIMARY
M6-127	PASSENGER ELEV PRIMARY RECALL	M6-127 RZAM	PRIMARY

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 50  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L22 POINT LIST  
 256 Point List Pseudo  
 LIST No: 22 L22  
 continued

Description: ALTERNATE ELEVATOR CAPTURE RELAYS

Point	Custom Point Label	Device Type	Point Type
M6-103	FREIGHT ELEV ALTERNATE RECALL	M6-103 RZAM	ALTERN
M6-126	PASSENGER ELEV ALTERNATE RECALL	M6-126 RZAM	ALTERN

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 51  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L23 POINT LIST  
 256 Point List Pseudo  
 LIST No: 23 L23  
 continued

Description: WATERFLOW ALARM MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-10	ZN2 LOWER LEVEL NORTH-SPKLR FLOW	M1-10 MAZAM	WATER
M1-31	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-31 MAZAM	WATER
M1-33	ZN1 LOWER LEVEL SOUTH-SPKLR MAIN	M1-33 MAZAM	WATER
M1-38	ZN3 LOWER LEVEL SOUTH-SPKLR FLOW	M1-38 MAZAM	WATER
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M3-12	ZN5 GROUND FLOOR SOUTH-SPKLR FLOW	M3-12 MAZAM	WATER
M3-120	ZN7 SECOND FLOOR SOUTH-SPKLR FLOW	M3-120 MAZAM	WATER
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER

URI CCE points list 11-2013 (002)

M6-18 ZN12 FIFTH FLOOR NORTH-SPKLR FLOW M6-18 MAZAM WATER  
 M6-110 ZN13 SIXTH FLOOR NORTH-SPKLR FLOW M6-110 MAZAM WATER  
 ♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 52  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L26 POINT LIST  
 256 Point List Pseudo L26  
 LIST No: 26 continued

Description: SPRINKLER SUPERVISORY MONITOR ZONES

Point	Custom Point Label	Device Type	Point Type
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4 MAZAM	SO
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9 MAZAM	SO
M1-17	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-17 MAZAM	SO
M1-19	ZN2 LOWER LEVEL NORTH-TAMPER SW	M1-19 MAZAM	SO
M1-32	ZN1 LOWER LEVEL SOUTH-TAMPER SW	M1-32 MAZAM	SO
M1-34	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-34 MAZAM	SO
M1-37	ZN3 LOWER LEVEL SOUTH-TAMPER SW	M1-37 MAZAM	SO
M1-41	ZN3 LOWER LEVEL SO-SPKLR PRESS SW	M1-41 MAZAM	SO

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 53  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L28 POINT LIST  
 256 Point List Pseudo L28  
 LIST No: 28 continued

Description: USER SYSTEM LISTS

Point	Custom Point Label	Device Type	Point Type
L38	4 WIRE MONITOR ZONES		EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM		EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM		EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET		CONTROL
L73	CONTROL POINTS OFF - ON SYSTEM RESET		CONTROL
L74	CONTROL POINTS OFF - ON SILENCE		CONTROL
L83	AUX1 MESSAGE SPEAKERS		EMPTY
L84	AUX2 MESSAGE SPEAKERS		EMPTY
L85	RESTART MESSAGE AFTER MIKE - VTG 1		EMPTY
L86	RESTART MESSAGE AFTER MIKE - VTG 2		EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF		EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT		EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH		EMPTY
L100	POINTS TO EXCLUDE FROM AUTOMAP		EMPTY
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS		MIXED
L103	EXTERNAL DETECTOR RESET PSEUDO		EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO		EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO		EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO		EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE		EMPTY
L109	ALARM SILENCED LED CONTROL		DPSEUDO
L112	EXTERNAL PRIORITY 2 RESET PSEUDOS		EMPTY
L110	INHIBIT NETWORK LABEL UPDATE		EMPTY

URI CCE points list 11-2013 (002)

‡

SHEPARD'S BUILDING POINT LIST DETAIL Page 54  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L29 POINT LIST  
 256 Point List Pseudo  
 LIST No: 29 L29  
 continued

Description: EDITABLE GENERAL ALARM SYSTEM LISTS

Point	Custom Point Label	Device Type	Point Type
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)		CONTROL
L8	FIRE ALARM SIGNALS OFF ON SILENCE		CONTROL
L9	FIRE ALARM SIGNALS OFF ON RESET		EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE		EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET		CONTROL
L12	FIRE ALARM VISUALS OFF ON SILENCE		CONTROL
L13	FIRE ALARM VISUALS OFF ON RESET		EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET		EMPTY
L17	DOOR HOLDER CONTROL RELAYS		CONTROL
L18	GENERAL FIRE ALARM MONITOR ZONES		MIXED
L21	PRIMARY ELEVATOR CAPTURE RELAYS		CONTROL
L22	ALTERNATE ELEVATOR CAPTURE RELAYS		CONTROL
L24	WATERFLOW SIGNALS OFF ON SILENCE		EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET		EMPTY
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS		EMPTY
L48	VNACS OFF ON SILENCE		EMPTY
L49	VNACS OFF ON RESET		EMPTY
L78	ANALOG SENSORS WITH PIEZO		EMPTY
L79	ANALOG SENSORS WITH RELAY		EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS		CONTROL
L87	AHU RELAYS ON - ON FIRE ALARM		CONTROL
L88	AHU RELAYS OFF - ON FIRE ALARM		EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET		CONTROL
L108	EXTERNAL SPEAKERS AND SPEAKER LISTS		EMPTY

‡

SHEPARD'S BUILDING POINT LIST DETAIL Page 55  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L40 POINT LIST  
 256 Point List Pseudo  
 LIST No: 40 L40  
 continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-4	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-4 MAZAM	SO
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-9	ZN2 LOWER LEVEL NORTH-TAMPER SWITCH	M1-9 MAZAM	SO

URI CCE points list 11-2013 (002)

M1-10	ZN2	LOWER	LEVEL	NORTH-SPKLR FLOW	M1-10	MAZAM	WATER
M1-12	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-12	PHOTO	SMOKE
M1-13	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-13	PHOTO	SMOKE
M1-14	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-14	PHOTO	SMOKE
M1-15	ZN2	LOWER	LEVEL	NORTH-STAIR A	M1-15	PHOTO	SMOKE
M1-16	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-16	ADRPUL	PULL
M1-17	ZN2	LOWER	LEVEL	NORTH-TAMPER SW	M1-17	MAZAM	SO
M1-18	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-18	PHOTO	SMOKE
M1-19	ZN2	LOWER	LEVEL	NORTH-TAMPER SW	M1-19	MAZAM	SO
M1-20	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-20	PHOTO	SMOKE
M1-21	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-21	PHOTO	SMOKE
M1-22	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-22	PHOTO	SMOKE
M1-23	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-23	ADRPUL	PULL
M1-24	ZN2	LOWER	LEVEL	NO-FR ELEV LOBBY	M1-24	PHOTO	SMOKE
M1-25	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-25	ADRPUL	PULL
M1-26	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-26	PHOTO	SMOKE
M1-27	ZN2	LOWER	LEVEL	NO-MECH RM 011	M1-27	ADRPUL	PULL
M1-28	ZN2	LOWER	LEVEL	NORTH-STAIR B	M1-28	PHOTO	SMOKE
M1-29	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-29	PHOTO	SMOKE
M1-30	ZN2	LOWER	LEVEL	NORTH-CORRIDOR	M1-30	PHOTO	SMOKE
M1-31	ZN1	LOWER	LEVEL	SOUTH-SPKLR MAIN	M1-31	MAZAM	WATER
M1-32	ZN1	LOWER	LEVEL	SOUTH-TAMPER SW	M1-32	MAZAM	SO
M1-33	ZN1	LOWER	LEVEL	SOUTH-SPKLR MAIN	M1-33	MAZAM	WATER
M1-34	ZN3	LOWER	LEVEL	SOUTH-TAMPER SW	M1-34	MAZAM	SO
M1-35	ZN3	LOWER	LEVEL	SOUTH-STAIR C	M1-35	PHOTO	SMOKE
M1-36	ZN3	LOWER	LEVEL	SOUTH-CORRIDOR	M1-36	ADRPUL	PULL
M1-37	ZN3	LOWER	LEVEL	SOUTH-TAMPER SW	M1-37	MAZAM	SO
M1-38	ZN3	LOWER	LEVEL	SOUTH-SPKLR FLOW	M1-38	MAZAM	WATER
M1-39	ZN3	LOWER	LEVEL	SOUTH-STAIR D	M1-39	PHOTO	SMOKE
M1-40	ZN3	LOWER	LEVEL	SOUTH-CORRIDOR	M1-40	ADRPUL	PULL
M1-41	ZN3	LOWER	LEVEL	SO-SPKLR PRESS SW	M1-41	MAZAM	SO
M1-42		DRILL SWITCH	DAYCARE CENTER	GND FL	M1-42	GENIAM	UTILITY
M1-43		DRILL SWITCH	MET SCHOOL	4TH FL SO.	M1-43	GENIAM	UTILITY

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 56  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
256 Point List Pseudo  
LIST No: 40

POINT LIST

L40  
continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M1-44	REMOTE MICROPHONE	ASTALK ON/OFF SW	M1-44 GENIAM UTILITY
M1-45	ALL EMERGENCY EXIT DOORS UNLOCK		M1-45 GENIAM UTILITY
M1-48	ZN 4 GROUND FLOOR SECURITY OFFFICE		M1-48 PHOTO SMOKE
M2-1	ZN4 GROUND FLOOR NORTH-VESTIBULE		M2-1 ADRPUL PULL
M2-2	ZN4 GROUND FLOOR NORTH-VESTIBULE		M2-2 PHOTO SMOKE
M2-3	ZN4 GROUND FLOOR NORTH-FOYER		M2-3 PHOTO SMOKE
M2-4	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-4 PHOTO SMOKE
M2-5	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-5 PHOTO SMOKE
M2-6	ZN4 GROUND FLOOR NORTH-STAIR F		M2-6 PHOTO SMOKE
M2-7	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-7 PHOTO SMOKE
M2-8	ZN4 GROUND FLOOR NORTH-STAIR A		M2-8 PHOTO SMOKE
M2-9	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-9 ADRPUL PULL
M2-10	ZN4 GROUND FLR NO-PASS ELEV LOBBY		M2-10 PHOTO SMOKE
M2-11	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-11 ADRPUL PULL
M2-12	ZN4 GROUND FLOOR NORTH-CORRIDOR		M2-12 PHOTO SMOKE

URI CCE points list 11-2013 (002)

M2-13	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-13 PHOTO	SMOKE
M2-14	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-14 PHOTO	SMOKE
M2-15	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-15 PHOTO	SMOKE
M2-16	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-16 PHOTO	SMOKE
M2-17	ZN4 GROUND FLOOR NORTH-LOUNGE 120	M2-17 PHOTO	SMOKE
M2-18	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-18 PHOTO	SMOKE
M2-19	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-19 ADRPUL	PULL
M2-20	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-20 PHOTO	SMOKE
M2-21	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-21 PHOTO	SMOKE
M2-22	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-22 PHOTO	SMOKE
M2-23	ZN4 GROUND FLR NORTH-FR ELEV LOBBY	M2-23 ADRPUL	PULL
M2-24	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-24 PHOTO	SMOKE
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-29	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-29 ADRPUL	PULL
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-31	ZN4 GROUND FLOOR NORTH-STAIR B	M2-31 ADRPUL	PULL
M2-32	GROUND FL RECEIVING ROOM	M2-32 ADRPUL	PULL
M2-33	ZN4 GROUND FLOOR NORTH-SPKLR FLOW	M2-33 MAZAM	WATER
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-35	ZN4 GROUND FL NO-MAIN ELECT RM 151	M2-35 ADRPUL	PULL
M2-36	ZN4 GROUND FLOOR NORTH-STAIR A	M2-36 ADRPUL	PULL
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-38	ZN4 GROUND FLOOR NORTH-LIBRARY 101	M2-38 ADRPUL	PULL
M2-41	GROUND FLR NORTH DOOR MON DR 104	M2-41 GENIAM	UTILITY

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 57  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
256 Point List Pseudo  
LIST No: 40

POINT LIST

L40  
continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M2-43	DOOR MONITOR STR B GRD FL N DR 113	M2-43 GENIAM	UTILITY
M2-45	DOOR MON NEAR REST RM GRD FL DR122	M2-45 GENIAM	UTILITY
M2-47	DOOR MON NEAR ELECTRIC ROOM DR 128	M2-47 GENIAM	UTILITY
M2-48	KITCHEN GROUND FL N SUPPRESS SYS	M2-48 MAZAM	SUPDET
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-100	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-100 ADRPUL	PULL
M2-101	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-101 ADRPUL	PULL
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-105	ZN6 SECOND FLOOR NORTH-SPKLR FLOW	M2-105 MAZAM	WATER
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-107	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-107 ADRPUL	PULL
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-115	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-115 ADRPUL	PULL

URI CCE points list 11-2013 (002)

M2-116	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-116	PHOTO	SMOKE
M2-117	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-117	PHOTO	SMOKE
M2-118	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-118	PHOTO	SMOKE
M2-119	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-119	PHOTO	SMOKE
M2-120	ZN6	SECOND	FLOOR	NORTH-STAIR F	M2-120	PHOTO	SMOKE
M2-121	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-121	PHOTO	SMOKE
M2-122	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-122	PHOTO	SMOKE
M2-123	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-123	PHOTO	SMOKE
M2-124	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-124	ADRPUL	PULL
M2-126	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-126	PHOTO	SMOKE
M2-127	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-127	PHOTO	SMOKE
M3-1	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-1	ADRPUL	PULL
M3-4	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-4	PHOTO	SMOKE
M3-5	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-5	PHOTO	SMOKE
M3-6	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-6	PHOTO	SMOKE
M3-7	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-7	PHOTO	SMOKE
M3-8	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-8	PHOTO	SMOKE
M3-9	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-9	PHOTO	SMOKE
M3-10	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-10	ADRPUL	PULL
M3-11	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-11	PHOTO	SMOKE
M3-12	ZN5	GROUND	FLOOR	SOUTH-SPKLR FLOW	M3-12	MAZAM	WATER

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 58  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
256 Point List Pseudo  
LIST No: 40

POINT LIST

L40  
continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M3-13	ZN5 GROUND FLOOR SOUTH-STAIR D	M3-13 PHOTO	SMOKE
M3-14	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-14 PHOTO	SMOKE
M3-15	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-15 PHOTO	SMOKE
M3-16	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-16 PHOTO	SMOKE
M3-17	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-17 PHOTO	SMOKE
M3-18	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-18 PHOTO	SMOKE
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-20	ZN5 GROUND FLOOR SOUTH-FOYER	M3-20 ADRPUL	PULL
M3-21	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-21 ADRPUL	PULL
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-25	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-25 ADRPUL	PULL
M3-26	ZN5 GROUND FLOOR SOUTH-STUDNT CNTR	M3-26 ADRPUL	PULL
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-31	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-31 ADRPUL	PULL
M3-35	GROUND FLOOR DOOR MON DR 110	M3-35 GENIAM	UTILITY
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M3-110	ZN7	SECOND	FLOOR	SOUTH-ELECTRC RM	M3-110	PHOTO	SMOKE
M3-111	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-111	PHOTO	SMOKE
M3-112	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-112	PHOTO	SMOKE
M3-113	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-113	PHOTO	SMOKE
M3-114	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-114	ADRPUL	PULL
M3-115	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-115	PHOTO	SMOKE
M3-116	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-116	PHOTO	SMOKE
M3-117	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-117	PHOTO	SMOKE
M3-118	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-118	PHOTO	SMOKE
M3-119	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-119	PHOTO	SMOKE
M3-120	ZN7	SECOND	FLOOR	SOUTH-SPKLR FLOW	M3-120	MAZAM	WATER
M3-121	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-121	ADRPUL	PULL
M3-122	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-122	PHOTO	SMOKE
M3-123	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-123	PHOTO	SMOKE
M3-124	ZN7	SECOND	FLOOR	SOUTH-CORRIDOR	M3-124	PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 59  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
256 Point List Pseudo  
LIST No: 40

POINT LIST

L40  
continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-2	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-2 ADRPUL	PULL
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE
M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE
M4-11	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-11 ADRPUL	PULL
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-16	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-16 ADRPUL	PULL
M4-17	ZN8 THIRD FLOOR NORTH-SPKLR FLOW	M4-17 MAZAM	WATER
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-23	ZN8 THIRD FLR NORTH-FR ELEV LOBBY	M4-23 ADRPUL	PULL
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-114	ZN10 FOURTH FLR NORTH-SPKLR FLOW	M4-114 MAZAM	WATER
M4-115	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-115 ADRPUL	PULL
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M4-118	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-118	PHOTO	SMOKE
M4-119	ZN10	FOURTH FLR NO-FR ELEV LOBBY	M4-119	ADRPUL	PULL
M4-120	ZN10	FOURTH FLR NO-FR ELEV LOBBY	M4-120	PHOTO	SMOKE
M4-121	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-121	PHOTO	SMOKE
M4-122	ZN10	FOURTH FLR NO-ELECT RM 414	M4-122	PHOTO	SMOKE
M4-123	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-123	PHOTO	SMOKE
M4-124	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-124	PHOTO	SMOKE
M4-125	ZN10	FOURTH FLOOR NORTH-CORRIDOR	M4-125	PHOTO	SMOKE
M4-126	ZN10	FOURTH FL NO-PASS ELEV LOBBY	M4-126	PHOTO	SMOKE

‡

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 60  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
256 Point List Pseudo  
LIST No: 40

POINT LIST

L40  
continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M4-127	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-127 ADRPUL	PULL
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE
M5-7	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-7 ADRPUL	PULL
M5-8	ZN9 THIRD FLOOR SOUTH-SPKLR FLOW	M5-8 MAZAM	WATER
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10 PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11 PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12 PHOTO	SMOKE
M5-13	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-13 ADRPUL	PULL
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14 PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15 PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16 PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17 PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE
M5-108	GENERATOR RUNNING	M5-108 MAZAM	SUPERV
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE
M5-113	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-113 ADRPUL	PULL
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE
M5-115	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-115 PHOTO	SMOKE
M5-116	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-116 PHOTO	SMOKE
M5-117	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-117 PHOTO	SMOKE
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE
M5-121	ZN11 FOURTH FLR SOUTH-SPKLR FLOW	M5-121 MAZAM	WATER
M5-122	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-122 ADRPUL	PULL
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124 PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125 PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126 PHOTO	SMOKE
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M6-1 ZN12 FIFTH FLOOR NORTH-CORRIDOR M6-1 PHOTO SMOKE  
 M6-2 ZN12 FIFTH FLOOR NORTH-CORRIDOR M6-2 PHOTO SMOKE  
 M6-3 ZN12 FIFTH FLOOR NORTH-CORRIDOR M6-3 ADRPUL PULL  
 ‡

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 61  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L40 POINT LIST  
 256 Point List Pseudo  
 LIST No: 40 L40  
 continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M6-5	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-5 ADRPUL	PULL
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6 PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7 PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8 PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9 PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10 PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11 PHOTO	SMOKE
M6-12	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-12 ADRPUL	PULL
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13 PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14 PHOTO	SMOKE
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE
M6-17	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-17 ADRPUL	PULL
M6-18	ZN12 FIFTH FLOOR NORTH-SPKLR FLOW	M6-18 MAZAM	WATER
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE
M6-20	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-20 ADRPUL	PULL
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21 PHOTO	SMOKE
M6-96	ZN13 COMPUTER ROOM FM 200 TROUBLE	M6-96 MAZAM	TROUBLE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97 PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-99	ZN15 PASSENGER ELEV PENTHOUSE	M6-99 ADRPUL	PULL
M6-100	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100 ADRPUL	PULL
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-102	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102 MAZAM	HEAT
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-106	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106 HEAT	HEAT
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE
M6-108	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-108 ADRPUL	PULL
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109 PHOTO	SMOKE
M6-110	ZN13 SIXTH FLOOR NORTH-SPKLR FLOW	M6-110 MAZAM	WATER
M6-111	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-111 ADRPUL	PULL
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112 PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113 PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114 PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115 PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116 PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117 PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118 PHOTO	SMOKE
M6-119	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119 HEAT	HEAT
M6-120	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120 HEAT	HEAT
M6-121	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121 HEAT	HEAT
M6-122	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-122 ADRPUL	PULL

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 62  
 Page 46

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CARD No: 160 L40  
 256 Point List Pseudo  
 LIST No: 40

POINT LIST

L40  
 continued

Description: WALK TEST GROUP 0

Point	Custom Point Label	Device Type	Point Type
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE
M6-124 ♀	ZN13 6TH FLOOR COMPUTER RM FM200	M6-124 MAZAM	FIRE

SHEPARD'S BUILDING  
 9520019D node:1 rev:16

POINT LIST DETAIL

Page 63  
 10:27:30, TUE, 19-NOV-13

CARD No: 160 L50  
 256 Point List Pseudo  
 LIST No: 50

POINT LIST

L50  
 continued

Description: WALK TEST GROUP 0 - SIGNALS/RELAYS

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL

URI CCE points list 11-2013 (002)

SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL
SIG56	SPARE	SIG56	SSIGNAL

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 64  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L50 POINT LIST  
 256 Point List Pseudo  
 LIST No: 50 L50

continued

Description: WALK TEST GROUP 0 - SIGNALS/RELAYS

Point	Custom Point Label	Device Type	Point Type
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 65  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L72 POINT LIST  
 256 Point List Pseudo  
 LIST No: 72 L72

continued

Description: CONTROL POINTS ON - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RZAM	RELAY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RZAM	RELAY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RZAM	RELAY
M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY
M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RZAM	RELAY

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 66  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L73 POINT LIST

URI CCE points list 11-2013 (002)

256 Point List Pseudo  
LIST No: 73

L73  
continued

Description: CONTROL POINTS OFF - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS	M6-93 RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS	M6-94 RZAM	CDAMPER

SHEPARD'S BUILDING POINT LIST DETAIL Page 67  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L74 POINT LIST  
256 Point List Pseudo  
LIST No: 74 L74  
continued

Description: CONTROL POINTS OFF - ON SILENCE

Point	Custom Point Label	Device Type	Point Type
0-7-3	Master Output - City Alarm relay		OUTPUT

SHEPARD'S BUILDING POINT LIST DETAIL Page 68  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L76 POINT LIST  
256 Point List Pseudo  
LIST No: 76 L76  
continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M1-1	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-1 PHOTO	SMOKE
M1-2	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-2 PHOTO	SMOKE
M1-3	ZN2 LOWER LEVEL NORTH CORRIDOR	M1-3 PHOTO	SMOKE
M1-5	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-5 PHOTO	SMOKE
M1-6	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-6 PHOTO	SMOKE
M1-7	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-7 PHOTO	SMOKE
M1-8	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-8 PHOTO	SMOKE
M1-12	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-12 PHOTO	SMOKE
M1-13	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-13 PHOTO	SMOKE
M1-14	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-14 PHOTO	SMOKE
M1-15	ZN2 LOWER LEVEL NORTH-STAIR A	M1-15 PHOTO	SMOKE
M1-18	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-18 PHOTO	SMOKE
M1-20	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-20 PHOTO	SMOKE
M1-21	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-21 PHOTO	SMOKE
M1-22	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-22 PHOTO	SMOKE
M1-24	ZN2 LOWER LEVEL NO-FR ELEV LOBBY	M1-24 PHOTO	SMOKE
M1-26	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-26 PHOTO	SMOKE
M1-28	ZN2 LOWER LEVEL NORTH-STAIR B	M1-28 PHOTO	SMOKE
M1-29	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-29 PHOTO	SMOKE
M1-30	ZN2 LOWER LEVEL NORTH-CORRIDOR	M1-30 PHOTO	SMOKE
M1-35	ZN3 LOWER LEVEL SOUTH-STAIR C	M1-35 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M1-39	ZN3	LOWER LEVEL SOUTH-STAIR D	M1-39	PHOTO	SMOKE
M1-48	ZN 4	GROUND FLOOR SECURITY OFFICE	M1-48	PHOTO	SMOKE
M2-2	ZN4	GROUND FLOOR NORTH-VESTIBULE	M2-2	PHOTO	SMOKE
M2-3	ZN4	GROUND FLOOR NORTH-FOYER	M2-3	PHOTO	SMOKE
M2-4	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-4	PHOTO	SMOKE
M2-5	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-5	PHOTO	SMOKE
M2-6	ZN4	GROUND FLOOR NORTH-STAIR F	M2-6	PHOTO	SMOKE
M2-7	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-7	PHOTO	SMOKE
M2-8	ZN4	GROUND FLOOR NORTH-STAIR A	M2-8	PHOTO	SMOKE
M2-10	ZN4	GROUND FLR NO-PASS ELEV LOBBY	M2-10	PHOTO	SMOKE
M2-12	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-12	PHOTO	SMOKE
M2-13	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-13	PHOTO	SMOKE
M2-14	ZN4	GROUND FLOOR NORTH-LOUNGE 120	M2-14	PHOTO	SMOKE
M2-15	ZN4	GROUND FLOOR NORTH-LOUNGE 120	M2-15	PHOTO	SMOKE
M2-16	ZN4	GROUND FLOOR NORTH-LOUNGE 120	M2-16	PHOTO	SMOKE
M2-17	ZN4	GROUND FLOOR NORTH-LOUNGE 120	M2-17	PHOTO	SMOKE
M2-18	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-18	PHOTO	SMOKE
M2-20	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-20	PHOTO	SMOKE
M2-21	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-21	PHOTO	SMOKE
M2-22	ZN4	GROUND FLR NORTH-FR ELEV LOBBY	M2-22	PHOTO	SMOKE
M2-24	ZN4	GROUND FLOOR NORTH-CORRIDOR	M2-24	PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 69  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L76  
256 Point List Pseudo  
LIST No: 76

POINT LIST

L76  
continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M2-25	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-25 PHOTO	SMOKE
M2-26	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-26 PHOTO	SMOKE
M2-27	ZN4 GROUND FLOOR NO-MAIN ELECT RM	M2-27 PHOTO	SMOKE
M2-28	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-28 PHOTO	SMOKE
M2-30	ZN4 GROUND FLOOR NORTH-STAIR B	M2-30 PHOTO	SMOKE
M2-34	ZN4 GROUND FL NO-EMERGENCY POWR RM	M2-34 PHOTO	SMOKE
M2-37	ZN4 GROUND FLOOR NORTH-CORRIDOR	M2-37 PHOTO	SMOKE
M2-98	ZN6 SECOND FLOOR ELECTRICAL RM 275	M2-98 PHOTO	SMOKE
M2-99	ZN6 SECOND FLOOR ELECTRICAL RM 274	M2-99 PHOTO	SMOKE
M2-102	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-102 PHOTO	SMOKE
M2-103	ZN6 SECOND FL NORTH-FR ELEV LOBBY	M2-103 PHOTO	SMOKE
M2-104	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-104 PHOTO	SMOKE
M2-106	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-106 PHOTO	SMOKE
M2-108	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-108 PHOTO	SMOKE
M2-109	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-109 PHOTO	SMOKE
M2-110	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-110 PHOTO	SMOKE
M2-111	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-111 PHOTO	SMOKE
M2-112	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-112 PHOTO	SMOKE
M2-113	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-113 PHOTO	SMOKE
M2-116	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-116 PHOTO	SMOKE
M2-117	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-117 PHOTO	SMOKE
M2-118	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-118 PHOTO	SMOKE
M2-119	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-119 PHOTO	SMOKE
M2-120	ZN6 SECOND FLOOR NORTH-STAIR F	M2-120 PHOTO	SMOKE
M2-121	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-121 PHOTO	SMOKE
M2-122	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-122 PHOTO	SMOKE
M2-123	ZN6 SECOND FLOOR NORTH-CORRIDOR	M2-123 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M2-126	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-126	PHOTO	SMOKE
M2-127	ZN6	SECOND	FLOOR	NORTH-CORRIDOR	M2-127	PHOTO	SMOKE
M3-4	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-4	PHOTO	SMOKE
M3-5	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-5	PHOTO	SMOKE
M3-6	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-6	PHOTO	SMOKE
M3-7	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-7	PHOTO	SMOKE
M3-8	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-8	PHOTO	SMOKE
M3-9	ZN5	GROUND	FLOOR	SOUTH-VESTIBULE	M3-9	PHOTO	SMOKE
M3-11	ZN5	GROUND	FLOOR	SOUTH-FOYER	M3-11	PHOTO	SMOKE
M3-13	ZN5	GROUND	FLOOR	SOUTH-STAIR D	M3-13	PHOTO	SMOKE
M3-14	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-14	PHOTO	SMOKE
M3-15	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-15	PHOTO	SMOKE
M3-16	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-16	PHOTO	SMOKE
M3-17	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-17	PHOTO	SMOKE
M3-18	ZN5	GROUND	FLOOR	SOUTH-CORRIDOR	M3-18	PHOTO	SMOKE

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 70  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L76 POINT LIST  
 256 Point List Pseudo  
 LIST No: 76 L76  
 continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M3-19	ZN5 GROUND FLOOR SOUTH-FOYER	M3-19 PHOTO	SMOKE
M3-22	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-22 PHOTO	SMOKE
M3-23	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-23 PHOTO	SMOKE
M3-24	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-24 PHOTO	SMOKE
M3-27	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-27 PHOTO	SMOKE
M3-28	ZN5 GROUND FLOOR SOUTH-CORRIDOR	M3-28 PHOTO	SMOKE
M3-30	ZN5 GROUND FLOOR SOUTH-STAIR C	M3-30 PHOTO	SMOKE
M3-50	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-50 PHOTO	SMOKE
M3-51	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-51 PHOTO	SMOKE
M3-52	ZN5 GROUND FLOOR DAY CARE ROOM 137	M3-52 PHOTO	SMOKE
M3-53	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-53 PHOTO	SMOKE
M3-54	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-54 PHOTO	SMOKE
M3-55	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-55 PHOTO	SMOKE
M3-56	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-56 PHOTO	SMOKE
M3-57	ZN5 GROUND FLOOR DAY CARE ROOM 139	M3-57 PHOTO	SMOKE
M3-110	ZN7 SECOND FLOOR SOUTH-ELECTRC RM	M3-110 PHOTO	SMOKE
M3-111	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-111 PHOTO	SMOKE
M3-112	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-112 PHOTO	SMOKE
M3-113	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-113 PHOTO	SMOKE
M3-115	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-115 PHOTO	SMOKE
M3-116	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-116 PHOTO	SMOKE
M3-117	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-117 PHOTO	SMOKE
M3-118	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-118 PHOTO	SMOKE
M3-119	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-119 PHOTO	SMOKE
M3-122	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-122 PHOTO	SMOKE
M3-123	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-123 PHOTO	SMOKE
M3-124	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-124 PHOTO	SMOKE
M3-125	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-125 PHOTO	SMOKE
M3-126	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-126 PHOTO	SMOKE
M3-127	ZN7 SECOND FLOOR SOUTH-CORRIDOR	M3-127 PHOTO	SMOKE
M4-1	ZN8 THIRD FLOOR NORTH-STAIR A	M4-1 PHOTO	SMOKE
M4-3	ZN8 THIRD FLR NORTH-PASS ELEV LOBBY	M4-3 PHOTO	SMOKE
M4-4	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-4 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M4-5	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-5 PHOTO	SMOKE
M4-6	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-6 PHOTO	SMOKE
M4-7	ZN8 THIRD FLR NORTH-ELECTRIC RM 305	M4-7 PHOTO	SMOKE
M4-8	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-8 PHOTO	SMOKE
M4-9	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-9 PHOTO	SMOKE
M4-10	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-10 PHOTO	SMOKE
M4-12	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-12 PHOTO	SMOKE
M4-13	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-13 PHOTO	SMOKE
M4-14	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-14 PHOTO	SMOKE

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

POINT LIST DETAIL

Page 71  
10:27:30, TUE, 19-NOV-13

CARD No: 160 L76  
256 Point List Pseudo  
LIST No: 76

POINT LIST

L76  
continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M4-15	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-15 PHOTO	SMOKE
M4-18	ZN8 THIRD FLR NORTH-ELECT RM 304A	M4-18 PHOTO	SMOKE
M4-19	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-19 PHOTO	SMOKE
M4-20	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-20 PHOTO	SMOKE
M4-21	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-21 PHOTO	SMOKE
M4-22	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-22 PHOTO	SMOKE
M4-24	ZN8 THIRD FLOOR NORTH-CORRIDOR	M4-24 PHOTO	SMOKE
M4-25	ZN8 THIRD FLOOR NORTH-STAIR B	M4-25 PHOTO	SMOKE
M4-113	ZN10 FOURTH FLR NO-ELECT RM 412A	M4-113 PHOTO	SMOKE
M4-116	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-116 PHOTO	SMOKE
M4-117	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-117 PHOTO	SMOKE
M4-118	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-118 PHOTO	SMOKE
M4-120	ZN10 FOURTH FLR NO-FR ELEV LOBBY	M4-120 PHOTO	SMOKE
M4-121	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-121 PHOTO	SMOKE
M4-122	ZN10 FOURTH FLR NO-ELECT RM 414	M4-122 PHOTO	SMOKE
M4-123	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-123 PHOTO	SMOKE
M4-124	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-124 PHOTO	SMOKE
M4-125	ZN10 FOURTH FLOOR NORTH-CORRIDOR	M4-125 PHOTO	SMOKE
M4-126	ZN10 FOURTH FL NO-PASS ELEV LOBBY	M4-126 PHOTO	SMOKE
M5-1	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-1 PHOTO	SMOKE
M5-2	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-2 PHOTO	SMOKE
M5-3	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-3 PHOTO	SMOKE
M5-4	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-4 PHOTO	SMOKE
M5-6	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-6 PHOTO	SMOKE
M5-9	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-9 PHOTO	SMOKE
M5-10	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-10 PHOTO	SMOKE
M5-11	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-11 PHOTO	SMOKE
M5-12	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-12 PHOTO	SMOKE
M5-14	ZN9 THIRD FLOOR SOUTH-ELECT RM 320	M5-14 PHOTO	SMOKE
M5-15	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-15 PHOTO	SMOKE
M5-16	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-16 PHOTO	SMOKE
M5-17	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-17 PHOTO	SMOKE
M5-18	ZN9 THIRD FLOOR SOUTH-CORRIDOR	M5-18 PHOTO	SMOKE
M5-107	ZN11 FOURTH FL SOUTH-ELECT RM 428	M5-107 PHOTO	SMOKE
M5-109	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-109 PHOTO	SMOKE
M5-110	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-110 PHOTO	SMOKE
M5-111	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-111 PHOTO	SMOKE
M5-112	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-112 PHOTO	SMOKE
M5-114	ZN11 FOURTH FLOOR SOUTH-STAIR C	M5-114 PHOTO	SMOKE

URI CCE points list 11-2013 (002)

M5-115 ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-115 PHOTO SMOKE  
 M5-116 ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-116 PHOTO SMOKE  
 M5-117 ZN11 FOURTH FLOOR SOUTH-CORRIDOR M5-117 PHOTO SMOKE

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 72  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L76 POINT LIST  
 256 Point List Pseudo  
 LIST No: 76 L76

continued

Description: VARIABLE SENSITIVITY PHOTO ANALOG SENSOR

Point	Custom Point Label	Device Type	Point Type
M5-118	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-118 PHOTO	SMOKE
M5-119	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-119 PHOTO	SMOKE
M5-120	ZN11 FOURTH FLOOR SOUTH-STAIR D	M5-120 PHOTO	SMOKE
M5-123	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-123 PHOTO	SMOKE
M5-124	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-124 PHOTO	SMOKE
M5-125	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-125 PHOTO	SMOKE
M5-126	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-126 PHOTO	SMOKE
M5-127	ZN11 FOURTH FLOOR SOUTH-CORRIDOR	M5-127 PHOTO	SMOKE
M6-1	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-1 PHOTO	SMOKE
M6-2	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-2 PHOTO	SMOKE
M6-6	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-6 PHOTO	SMOKE
M6-7	ZN12 FIFTH FLR NO-PASS ELEV LOBBY	M6-7 PHOTO	SMOKE
M6-8	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-8 PHOTO	SMOKE
M6-9	ZN12 FIFTH FLR NORTH-ELECT RM 519	M6-9 PHOTO	SMOKE
M6-10	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-10 PHOTO	SMOKE
M6-11	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-11 PHOTO	SMOKE
M6-13	ZN12 FIFTH FLR NORTH-FR ELEV LOBBY	M6-13 PHOTO	SMOKE
M6-14	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-14 PHOTO	SMOKE
M6-15	ZN12 FIFTH FLR NORTH-ELECT RM 516	M6-15 PHOTO	SMOKE
M6-16	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-16 PHOTO	SMOKE
M6-19	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-19 PHOTO	SMOKE
M6-21	ZN12 FIFTH FLOOR NORTH-CORRIDOR	M6-21 PHOTO	SMOKE
M6-97	ZN13 SIXTH FLR NORTH-ELECT RM 630	M6-97 PHOTO	SMOKE
M6-98	ZN15 PASSENGER ELEV PENTHOUSE	M6-98 PHOTO	SMOKE
M6-101	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101 PHOTO	SMOKE
M6-105	ZN13 SIXTH FL NORTH-FR ELEV LOBBY	M6-105 PHOTO	SMOKE
M6-107	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-107 PHOTO	SMOKE
M6-109	ZN13 SIXTH FLOOR NORTH-STAIR B	M6-109 PHOTO	SMOKE
M6-112	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-112 PHOTO	SMOKE
M6-113	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-113 PHOTO	SMOKE
M6-114	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-114 PHOTO	SMOKE
M6-115	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-115 PHOTO	SMOKE
M6-116	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-116 PHOTO	SMOKE
M6-117	ZN13 SIXTH FLOOR NORTH-CORRIDOR	M6-117 PHOTO	SMOKE
M6-118	ZN13 SIXTH FLR NO-PASS ELEV LOBBY	M6-118 PHOTO	SMOKE
M6-123	ZN13 SIXTH FLOOR NORTH-STAIR A	M6-123 PHOTO	SMOKE

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 73  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

-----  
 CARD No: 160 L80 POINT LIST  
 256 Point List Pseudo  
 LIST No: 80 L80

continued

URI CCE points list 11-2013 (002)

Description: GENERAL FIRE ALARM SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 74  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L87 POINT LIST  
 256 Point List Pseudo  
 LIST No: 87 L87  
 continued

Description: AHU RELAYS ON - ON FIRE ALARM

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS	M6-93 RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS	M6-94 RZAM	CDAMPER

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 75  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L89 POINT LIST  
 256 Point List Pseudo  
 LIST No: 89 L89  
 continued

Description: AHU RELAYS OFF - ON SYSTEM RESET

Point	Custom Point Label	Device Type	Point Type
M6-93	PASSNGR ELEV DAMPER CONTROL STATUS	M6-93 RZAM	CDAMPER
M6-94	FREIGHT ELEV DAMPER CONTROL STATUS	M6-94 RZAM	CDAMPER

♀

SHEPARD'S BUILDING POINT LIST DETAIL Page 76  
 Page 54

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CARD No: 160 L90  
 256 Point List Pseudo  
 LIST No: 90

POINT LIST

L90  
 continued

Description: ALL SPEAKERS - NON EDITABLE

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER

♀

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 77

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CARD No: 160 L98  
 256 Point List Pseudo  
 LIST No: 98

POINT LIST

L98  
 continued

Description: SWITCH POWER SUPPLY AMPS TO BATTERY

Point	Custom Point Label	Device Type	Point Type
2-0-18	Amplifier Batteries		TROUBLE
10-0-18	Amplifier Batteries		TROUBLE
16-0-18	Amplifier Batteries		TROUBLE
21-0-18	Amplifier Batteries		TROUBLE
26-0-18	Amplifier Batteries		TROUBLE
31-0-18	Amplifier Batteries		TROUBLE

♀

SHEPARD'S BUILDING

POINT LIST DETAIL

Page 78

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CARD No: 160 L99  
 256 Point List Pseudo  
 LIST No: 99

POINT LIST

L99  
 continued

Description: SWITCH POWER SUPPLY AMPS TO BKGRND MUSIC

URI CCE points list 11-2013 (002)

Point	Custom Point Label	Device Type	Point Type
2-0-19	Amplifier Background Music		TROUBLE
10-0-19	Amplifier Background Music		TROUBLE
16-0-19	Amplifier Background Music		TROUBLE
21-0-19	Amplifier Background Music		TROUBLE
26-0-19	Amplifier Background Music		TROUBLE
31-0-19	Amplifier Background Music		TROUBLE

‡

SHEPARD'S BUILDING POINT LIST DETAIL Page 79  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L101 POINT LIST  
 256 Point List Pseudo  
 LIST No: 101 L101 continued

Description: RESET POWER SUPPLY AMPS

Point	Custom Point Label	Device Type	Point Type
2-0-20	Amplifier Reset		TROUBLE
10-0-20	Amplifier Reset		TROUBLE
16-0-20	Amplifier Reset		TROUBLE
21-0-20	Amplifier Reset		TROUBLE
26-0-20	Amplifier Reset		TROUBLE
31-0-20	Amplifier Reset		TROUBLE

‡

SHEPARD'S BUILDING POINT LIST DETAIL Page 80  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L102 POINT LIST  
 256 Point List Pseudo  
 LIST No: 102 L102 continued

Description: LISTS TO AUTO-GENERATE EXTERNAL POINTS

Point	Custom Point Label	Device Type	Point Type
L0	CODING GROUP 0 SIGNALS/RELAYS (NON-PNIS)		CONTROL
L8	FIRE ALARM SIGNALS OFF ON SILENCE		CONTROL
L9	FIRE ALARM SIGNALS OFF ON RESET		EMPTY
L10	FIRE ALARM RELAYS OFF ON SILENCE		EMPTY
L11	FIRE ALARM RELAYS OFF ON RESET		CONTROL
L12	FIRE ALARM VISUALS OFF ON SILENCE		CONTROL
L13	FIRE ALARM VISUALS OFF ON RESET		EMPTY
L16	RELAYS PULSED ON SYSTEM (DETECTOR) RESET		EMPTY
L17	DOOR HOLDER CONTROL RELAYS		CONTROL
L18	GENERAL FIRE ALARM MONITOR ZONES		MIXED
L21	PRIMARY ELEVATOR CAPTURE RELAYS		CONTROL
L22	ALTERNATE ELEVATOR CAPTURE RELAYS		CONTROL
L24	WATERFLOW SIGNALS OFF ON SILENCE		EMPTY
L25	WATERFLOW SIGNALS OFF ON RESET		EMPTY
L27	SPRINKLER SUPERVISORY SIGNALS/RELAYS		EMPTY
L78	ANALOG SENSORS WITH PIEZO		EMPTY

URI CCE points list 11-2013 (002)

L79	ANALOG SENSORS WITH RELAY	EMPTY
L80	GENERAL FIRE ALARM SPEAKER CIRCUITS	CONTROL
L87	AHU RELAYS ON - ON FIRE ALARM	CONTROL
L88	AHU RELAYS OFF - ON FIRE ALARM	EMPTY
L89	AHU RELAYS OFF - ON SYSTEM RESET	CONTROL
L93	PHONE CIRCUITS	EMPTY

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 81  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L109 POINT LIST  
 256 Point List Pseudo  
 LIST No: 109 L109

continued

Description: ALARM SILENCED LED CONTROL

Point	Custom Point Label	Device Type	Point Type
P85	VTG 1 - ACTIVE		UTILITY
P221	SIGNALS ACTIVE - OFF ON SILENCE		UTILITY

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 82  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L128 POINT LIST  
 256 Point List Pseudo  
 LIST No: 128 L128

continued

Description: ALL EMERGENCY EXIT DOOR LOCKS

Point	Custom Point Label	Device Type	Point Type
M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RZAM	RELAY
M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RZAM	RELAY
M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RZAM	RELAY
M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RZAM	RELAY
M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RZAM	RELAY

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 83  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CARD No: 160 L129 POINT LIST  
 256 Point List Pseudo  
 LIST No: 129 L129

continued

Description: GROUND FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT SIG15		SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT SIG33		SPEAKER

♀

-----  
 SHEPARD'S BUILDING POINT LIST DETAIL Page 84  
 Page 57

URI CCE points list 11-2013 (002)

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CARD No: 160 L130  
 256 Point List Pseudo  
 LIST No: 130

POINT LIST

L130  
 continued

Description: SECOND FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER

SHEPARD'S BUILDING  
 9520019D node:1 rev:16

POINT LIST DETAIL

Page 85  
 10:27:30, TUE, 19-NOV-13

CARD No: 160 L131  
 256 Point List Pseudo  
 LIST No: 131

POINT LIST

L131  
 continued

Description: THIRD FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER

SHEPARD'S BUILDING  
 9520019D node:1 rev:16

POINT LIST DETAIL

Page 86  
 10:27:30, TUE, 19-NOV-13

CARD No: 160 L132  
 256 Point List Pseudo  
 LIST No: 132

POINT LIST

L132  
 continued

Description: FOURTH FLOOR SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER

SHEPARD'S BUILDING  
 9520019D node:1 rev:16

POINT LIST DETAIL

Page 87  
 10:27:30, TUE, 19-NOV-13

CARD No: 160 L133  
 256 Point List Pseudo  
 LIST No: 133

POINT LIST

L133  
 continued

Description: DAYCARE SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER

URI CCE points list 11-2013 (002)

SHEPARD'S BUILDING POINT LIST DETAIL Page 88  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L134 POINT LIST  
 256 Point List Pseudo  
 LIST No: 134 L134  
 continued

Description: MET SCHOOL SPEAKER CIRCUITS

Point	Custom Point Label	Device Type	Point Type
SIG58 ♀	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER

SHEPARD'S BUILDING POINT LIST DETAIL Page 89  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L135 POINT LIST  
 256 Point List Pseudo  
 LIST No: 135 L135  
 continued

Description: ALL STROBE CIRCUITS FOR BLDG DRILL

Point	Custom Point Label	Device Type	Point Type
SIG3	LOWER LEVEL STROBE CIRCUIT	SIG3	SSIGNAL
SIG4	LOWER LEVEL STROBE CIRCUIT	SIG4	SSIGNAL
SIG21	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21	SSIGNAL
SIG22	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22	SSIGNAL
SIG23	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23	SSIGNAL
SIG24	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24	SSIGNAL
SIG27	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27	SSIGNAL
SIG28	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28	SSIGNAL
SIG29	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29	SSIGNAL
SIG30	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30	SSIGNAL
SIG31	GND FLR DAYCARE STROBE CIRCUIT	SIG31	SVISUAL
SIG39	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39	SSIGNAL
SIG40	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40	SSIGNAL
SIG41	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41	SSIGNAL
SIG42	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42	SSIGNAL
SIG51	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG51	SSIGNAL
SIG52	THIRD FLOOR SOUTH STROBE CIRCUIT	SIG52	SSIGNAL
SIG53	FOURTH FLOOR MET SCHOOL STROBES	SIG53	SSIGNAL
SIG54	FOURTH FLOOR SOUTH STROBE CIRCUIT	SIG54	SSIGNAL
SIG63	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG63	SSIGNAL
SIG64	FIFTH FLOOR NORTH STROBE CIRCUIT	SIG64	SSIGNAL
SIG65	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG65	SSIGNAL
SIG66	SIXTH FLOOR NORTH STROBE CIRCUIT	SIG66	SSIGNAL
SIG5	SPARE	SIG5	SSIGNAL
SIG6	SPARE	SIG6	SSIGNAL
SIG7	SPARE	SIG7	SSIGNAL
SIG8	SPARE	SIG8	SSIGNAL
SIG25	SPARE	SIG25	SSIGNAL
SIG26	SPARE	SIG26	SSIGNAL
SIG32	SIGNAL CIRCUIT	SIG32	SSIGNAL
SIG43	SPARE	SIG43	SSIGNAL
SIG44	SPARE	SIG44	SSIGNAL
SIG55	SPARE	SIG55	SSIGNAL

URI CCE points list 11-2013 (002)

SIG56	SPARE	SIG56	SSIGNAL
SIG67	SPARE	SIG67	SSIGNAL
SIG68	SPARE	SIG68	SSIGNAL

‡

SHEPARD'S BUILDING POINT LIST DETAIL Page 90  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 160 L136 POINT LIST  
 256 Point List Pseudo  
 LIST No: 136 L136  
 continued

Description: ALL SPEAKER CIRCUITS FOR ALL BLDG DRILL

Point	Custom Point Label	Device Type	Point Type
SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9	SPEAKER
SIG15	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15	SPEAKER
SIG18	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18	SPEAKER
SIG33	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33	SPEAKER
SIG34	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34	SPEAKER
SIG36	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36	SPEAKER
SIG45	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45	SPEAKER
SIG48	FOURTH FLOOR NORTH SPEAKER CIRCUIT	SIG48	SPEAKER
SIG57	THIRD FLOOR SOUTH SPEAKER CIRCUIT	SIG57	SPEAKER
SIG58	FOURTH FLOOR MET SCHOOL SPEAKERS	SIG58	SPEAKER
SIG60	FOURTH FLOOR SOUTH SPEAKER CIRCUIT	SIG60	SPEAKER
SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69	SPEAKER
SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72	SPEAKER
SIG12	SPARE	SIG12	SPEAKER
SIG35	SIGNAL CARD 19 CIRCUIT	SIG35	SPEAKER
SIG37	SIGNAL CARD 19 CIRCUIT	SIG37	SPEAKER
SIG38	SIGNAL CARD 19 CIRCUIT	SIG38	SPEAKER
SIG59	SIGNAL CARD 29 CIRCUIT	SIG59	SPEAKER
SIG61	SIGNAL CARD 29 CIRCUIT	SIG61	SPEAKER
SIG62	SIGNAL CARD 29 CIRCUIT	SIG62	SPEAKER

‡

SHEPARD'S BUILDING PANEL KEYS AND LEDS REPORT Page 91  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 0 SLOT No: 5 LED/KEY  
 (7003) 4100+ Master Controller MASTER SLOT  
 Display Panel Control Keys/LEDs 0-5

Pt	KEY Mode	Ref Addr	Ref Custom Label	Ref Type
1	TOF	P34	CITY DISCONNECT	TROUBLE
2	TOF	P36	ELEVATOR BYPASS	TROUBLE
3	TOF	P37	DOORHOLDER BYPASS	TROUBLE
4	TOF	P256	FAN/DAMPER CONTROL BYPASS	TROUBLE
5	TOF	P257	SIGNAL CIRCUITS BYPASS	TROUBLE

Pt	LED Mode	Ref Addr	Ref Custom Label	Ref Type
6	ON	P34	CITY DISCONNECT	TROUBLE
7	ON	P36	ELEVATOR BYPASS	TROUBLE
8	ON	P37	DOORHOLDER BYPASS	TROUBLE
9	ON	P256	FAN/DAMPER CONTROL BYPASS	TROUBLE
10	ON	P257	SIGNAL CIRCUITS BYPASS	TROUBLE

‡

URI CCE points list 11-2013 (002)

SHEPARD'S BUILDING REMOTE UNIT INTERFACE (RUI) REPORT Page 92  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 8 RUI  
 (0304) Remote Unit Interface (RUI) CARD  
 RUI Channel: 1 8

Input Communication Rate : 9600 BAUD  
 Output Communication Rate : 9600 BAUD

Card No	Card Type	Unit
11	(0110) MAPNET Interface	Unit 1
12	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 1
13	(4011) 2 Ckt Class A Signal (IAC)	Unit 1
14	(4331) 3 Input Class A Signal	Unit 1
15	(4331) 3 Input Class A Signal	Unit 2
17	(0110) MAPNET Interface	Unit 2
18	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 2
20	(4331) 3 Input Class A Signal	Unit 3
22	(0110) MAPNET Interface	Unit 3
23	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 3
24	(4011) 2 Ckt Class A Signal (IAC)	Unit 3
25	(4331) 3 Input Class A Signal	Unit 4
27	(0110) MAPNET Interface	Unit 4
28	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 4
30	(4331) 3 Input Class A Signal	Unit 5
32	(0110) MAPNET Interface	Unit 5
33	(3002) 4 Pt, 10 Amp Relay w/ Feedback	Unit 5
34	(4011) 2 Ckt Class A Signal (IAC)	Unit 5
10	(6005) Power Supply/Charger (Audio)	Unit 1
16	(6005) Power Supply/Charger (Audio)	Unit 2
21	(6005) Power Supply/Charger (Audio)	Unit 3
26	(6005) Power Supply/Charger (Audio)	Unit 4
31	(6005) Power Supply/Charger (Audio)	Unit 5
19	(4031) 6 Ckt Class A Signal (IAC)	Unit 2
29	(4031) 6 Ckt Class A Signal (IAC)	Unit 4
36	(0304) Remote Unit Interface (RUI)	Unit 4
37	(4603-9101) LCD Annunciator	Unit 6

♀

SHEPARD'S BUILDING REMOTE UNIT INTERFACE (RUI) REPORT Page 93  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CARD No: 36 RUI  
 (0304) Remote Unit Interface (RUI) CARD  
 RUI Channel: 2 36

Input Communication Rate : 9600 BAUD  
 Output Communication Rate : 9600 BAUD

Card No	Card Type	Unit
	no remote annunciators	

♀

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 94  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0

CARD No: 0 (base)  
64 LED / 64 Sw Controller

0-4

CONTROL PANEL LED/SWITCH ANNUNCIATOR 0

UNIT COMPOSITION:

Card No	Card Type	Display Card Point Usage
0	64 LED / 64 Sw Controller	0 LEDs / 0 SWS
5	(0301) 64 LED / 64 Sw Controller	40 LEDs / 32 SWS
1	(0113) 2120/RS232 Interface	N/A
2	(6005) Power Supply/Charger	N/A
3	(4331) 3 Input Class A Signal	N/A
4	(3002) 4 Pt, 10 Amp Relay w/ Feedback	N/A
7	(0110) MAPNET Interface	N/A
8	(0304) Remote Unit Interface (RUI)	N/A
9	(4011) 2 Ckt Class A Signal (IAC)	N/A
35	(3003) 8 Pt, 3 Amp Relay w/ Feedback	N/A

NOTE: Card 0, Annun 0 = Master Controller slot 4

CONTROLLER CARD CONFIGURATION DETAIL:

Controller Card No	Display Card	Display Card Type
0		no display cards assigned
5	1	0403 - 8 Momen Sw/8 Red LED
	2	L404 - 8 Maint Sw/16 Red-Grn LED
	3	0204 - Microphone Enclosure
	4	0204 - Microphone Enclosure
	5	0412 - 1 Channel Audio Control Module
	6	0409 - Blank Display Card
	7	0409 - Blank Display Card
	8	L403 - 8 Momen Sw/8 Red LED

♀

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 95  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0  
CARD No: 0 (base) DISPLAY 9  
64 LED / 64 Sw Controller 0-4

DISPLAY CARD DETAIL:

NO DISPLAY CARDS ASSIGNED

♀

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 96  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0  
CARD No: 5 DISPLAY 1  
(0301) 64 LED / 64 Sw Controller 5

URI CCE points list 11-2013 (002)

DISPLAY CARD DETAIL:

DISPLAY CARD: 1 0403 - 8 Momen Sw/8 Red LED

LED Range 1 - 8 Switch Range 65 - 72.

Pt	Mode	Ref Addr	Ref Custom Label	Ref Type
1	SP1	SIG72	SIXTH FLOOR NORTH SPEAKER CIRCUIT	SIG72 SPEAKER
2	SP1	SIG69	FIFTH FLOOR NORTH SPEAKER CIRCUIT	SIG69 SPEAKER
3	SP1	L132	FOURTH FLOOR SPEAKER CIRCUITS	CONTROL
4	SP1	L131	THIRD FLOOR SPEAKER CIRCUITS	CONTROL
5	SP1	L130	SECOND FLOOR SPEAKER CIRCUITS	CONTROL
6	SP1	L129	GROUND FLOOR SPEAKER CIRCUITS	CONTROL
7	SP1	SIG9	LOWER LEVEL SPEAKER CIRCUIT	SIG9 SPEAKER
8	ASTALK			

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 97  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0  
 CARD No: 5 DISPLAY 2  
 (0301) 64 LED / 64 Sw Controller 5

DISPLAY CARD DETAIL:

DISPLAY CARD: 2 L404 - 8 Maint Sw/16 Red-Grn LED

Pt	SW Mode	Ref Addr	Ref Custom Label	Ref Type
73	SMPL			
74	SMPL			
75	SMPL			
76	SMPL			
77	SMPL			
78	SMPL			
79	SMPL			
80	SMPL			

Pt	LED Mode	Ref Addr	Ref Custom Label	Ref Type
9	SMPL			
10	SMPL			
11	SMPL			
12	SMPL			
13	SMPL			
14	SMPL			
15	SMPL			
16	SMPL			

Pt	LED Mode	Ref Addr	Ref Custom Label	Ref Type
17	SMPL			
18	SMPL			
19	SMPL			
20	SMPL			
21	SMPL			

URI CCE points list 11-2013 (002)

22 SMPL  
23 SMPL  
24 SMPL

‡

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 98  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0  
CARD No: 5 DISPLAY 5  
(0301) 64 LED / 64 Sw Controller

DISPLAY CARD DETAIL:

DISPLAY CARD: 5 0412 - 1 Channel Audio Control Module

LED Range 25 - 32 Switch Range 81 - 88.

Pt	Mode	Ref Addr	Ref Custom Label	Ref Type
1	ASEVAC			
2	AEVAC			
3	ASTALK			
4				
5				
6				
7				
8	A1LOCAL			

SHEPARD'S BUILDING UNIT DETAIL REPORT Page 99  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

UNIT No: 0 UNIT 0  
CARD No: 5 DISPLAY 8  
(0301) 64 LED / 64 Sw Controller

DISPLAY CARD DETAIL:

DISPLAY CARD: 8 L403 - 8 Momen Sw/8 Red LED

Pt	SW Mode	Ref Addr	Ref Custom Label	Ref Type
89	ONOFF	M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RELAY
90	ONOFF	M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RELAY
91	ONOFF	M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RELAY
92	ONOFF	M2-44	GROUND FLR NORTH DOOR LOCK DR 122	M2-44 RELAY
93	ONOFF	M2-46	GROUND FLR NORTH DOOR LOCK DR 128	M2-46 RELAY
94	SMPL			
95	SMPL			
96	SMPL			

Pt	LED Mode	Ref Addr	Ref Custom Label	Ref Type
33	ON	M2-40	GROUND FLR NORTH DOOR LOCK DR 104	M2-40 RELAY
34	ON	M3-34	GROUND FLOOR DOOR LOCK DR 110	M3-34 RELAY
35	ON	M2-42	GROUND FLR NORTH DOOR LOCK DR 113	M2-42 RELAY

URI CCE points list 11-2013 (002)

36 ON M2-44 GROUND FLR NORTH DOOR LOCK DR 122 M2-44 RELAY  
 37 ON M2-46 GROUND FLR NORTH DOOR LOCK DR 128 M2-46 RELAY  
 38 SMPL  
 39 SMPL  
 40 SMPL

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 100  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 1 UNIT 1

I/O Unit 1

UNIT COMPOSITION:

Card No	Card Type
10	(6005) Power Supply/Charger (Audio)
11	(0110) MAPNET Interface
12	(3002) 4 Pt, 10 Amp Relay w/ Feedback
13	(4011) 2 Ckt Class A Signal (IAC)
14	(4331) 3 Input Class A Signal

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 101  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 2 UNIT 2

I/O Unit 2

UNIT COMPOSITION:

Card No	Card Type
15	(4331) 3 Input Class A Signal
16	(6005) Power Supply/Charger (Audio)
17	(0110) MAPNET Interface
18	(3002) 4 Pt, 10 Amp Relay w/ Feedback
19	(4031) 6 Ckt Class A Signal (IAC)

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 102  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 3 UNIT 3

I/O Unit 3

UNIT COMPOSITION:

Card No	Card Type
20	(4331) 3 Input Class A Signal
21	(6005) Power Supply/Charger (Audio)
22	(0110) MAPNET Interface
23	(3002) 4 Pt, 10 Amp Relay w/ Feedback
24	(4011) 2 Ckt Class A Signal (IAC)

♀

URI CCE points list 11-2013 (002)

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 103  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 4 UNIT 4

I/O Unit 4

UNIT COMPOSITION:

Card No	Card Type
25	(4331) 3 Input Class A Signal
26	(6005) Power Supply/Charger (Audio)
27	(0110) MAPNET Interface
28	(3002) 4 Pt, 10 Amp Relay w/ Feedback
29	(4031) 6 ckt Class A Signal (IAC)
36	(0304) Remote Unit Interface (RUI)

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 104  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 5 UNIT 5

I/O Unit 5

UNIT COMPOSITION:

Card No	Card Type
30	(4331) 3 Input Class A Signal
31	(6005) Power Supply/Charger (Audio)
32	(0110) MAPNET Interface
33	(3002) 4 Pt, 10 Amp Relay w/ Feedback
34	(4011) 2 ckt Class A Signal (IAC)

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 105  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 6 UNIT 6  
 CARD No: 37 (base) 37  
 (4603-9101) LCD Annunciator

REMOTE LCD ANNUNCIATOR 6

UNIT COMPOSITION:

Card No	Card Type
37	(4603-9101) LCD Annunciator

♀

-----  
 SHEPARD'S BUILDING UNIT DETAIL REPORT Page 106  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

UNIT No: 6 UNIT 6  
 CARD No: 37 (base) 37  
 (4603-9101) LCD Annunciator

URI CCE points list 11-2013 (002)

CARD DETAIL:

UNIT No: 6      CARD No: 37      (4603-9101) LCD Annunciator

POINT Address	Default Label
1	LCD - Programmable Control KEY 1
2	LCD - Programmable Control KEY 2
3	LCD - Programmable Control KEY 3
4	LCD - Programmable Control KEY 4
5	LCD - Programmable Control LED 1
6	LCD - Programmable Control LED 2
7	LCD - Programmable Control LED 3
8	LCD - Programmable Control LED 4
9	LCD - FIRE ALARM Acknowledge Key
10	LCD - SUPERVISORY Acknowledge Key
11	LCD - TROUBLE Acknowledge Key
12	LCD - KEY SWITCH
13	LCD - ALARM SILENCE Key
14	LCD - SYSTEM RESET Key
15	LCD - DISPLAY TIME Key
16	LCD - FIRE ALARM LED
17	LCD - SUPERVISORY SERVICE LED
18	LCD - TROUBLE LED
19	LCD - ALARM SILENCED LED
20	LCD - PIEZO

♀

SHEPARD'S BUILDING      UNIT DETAIL REPORT      Page 107  
 9520019D node:1 rev:16      10:27:30, TUE, 19-NOV-13

UNIT No: 6      UNIT 6  
 CARD No: 37 (base)      37  
 (4603-9101) LCD Annunciator

Display Panel CONTROL KEYS/LEDs

Pt	KEY Mode	Ref Addr	Ref Custom Label	Ref Type
1	SMPL			
2	SMPL			
3	SMPL			
4	SMPL			

Pt	LED Mode	Ref Addr	Ref Custom Label	Ref Type
5	SMPL			
6	SMPL			
7	SMPL			
8	SMPL			

♀

SHEPARD'S BUILDING      2120/RS232 INTERFACE REPORT      Page 108  
 9520019D node:1 rev:16      10:27:30, TUE, 19-NOV-13

CARD No: 1      2120/RS232 INTERFACE  
 (0113) 2120/RS232 Interface      CARD

1

URI CCE points list 11-2013 (002)

PORT	TYPE	BAUD	PARITY	DATA BITS	STOP BITS
A	UNUSED	----	----	0	0
B	UNUSED	----	----	0	0

♀

-----  
 SHEPARD'S BUILDING AUDIO CONFIGURATION REPORT Page 109  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

AUDIO

(0210) Audio Controller Card No.: 6  
 Number of channels - 1  
 Message Memory Board - YES  
 Chipset - 87 TONES, WALK TEST, & BOSTON EVAC

Card Inputs	Used
-----	-----
Master Microphone	YES
Remote Microphone 1	YES
Remote Microphone 2	NO
Fire Fighters Phone	NO
Network Input	NO
Backup VTG	NO

♀

-----  
 SHEPARD'S BUILDING OPTIONS DETAIL REPORT Page 110  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

OPTIONS  
STANDARD

Elevator Recall Operation:

List	Description	Point Total
-----	-----	-----
L19	PRIMARY ELEVATOR RECALL MONITOR ZONES	201
L20	ALTERNATE ELEVATOR RECALL MONITOR ZONES	75
L21	PRIMARY ELEVATOR CAPTURE RELAYS	2
L22	ALTERNATE ELEVATOR CAPTURE RELAYS	2

Door Holder Operation:

Drop On Alarm Delay after 0 seconds.  
 Drop on AC Power Loss after 0 minutes, 35 seconds.

List	Description	Point Total
-----	-----	-----
L17	DOOR HOLDER CONTROL RELAYS	14

♀

-----  
 SHEPARD'S BUILDING OPTIONS DETAIL REPORT Page 111  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

OPTIONS  
EXPANDED

Audio Operation:

VTG1 Chip Set S87 TONES, WALK TEST, & BOSTON EVAC

MSG	CHL	URI MSG#	CCE points list 11-2013 (002) Description
Evac.	1	1	SLOW WHOOP FOREVER
Alert	1	8	MARCH TIME - 60 BPM - CHIME - FOREVER
Drill	1	73	STANDARD DRILL MESSAGE
Clear	1	100	CUSTOM ALL CLEAR MESSAGE
Aux1	1	0	NO MESSAGE DEFINED
Aux2	1	0	NO MESSAGE DEFINED
Microphone Pretone		0	NO MESSAGE DEFINED
MSG After Mike VTG1		1	SLOW WHOOP FOREVER
MSG After Mike VTG2		8	MARCH TIME - 60 BPM - CHIME - FOREVER

Pre-Programmed User Lists: YES

List	List Description	Point Total
L38	4 WIRE MONITOR ZONES	EMPTY
L70	CONTROL POINTS ON - ON FIRE ALARM	EMPTY
L71	CONTROL POINTS OFF - ON FIRE ALARM	EMPTY
L72	CONTROL POINTS ON - ON SYSTEM RESET	5
L73	CONTROL POINTS OFF - ON SYSTEM RESET	2
L74	CONTROL POINTS OFF - ON SILENCE	1
L83	AUX1 MESSAGE SPEAKERS	EMPTY
L84	AUX2 MESSAGE SPEAKERS	EMPTY
L85	RESTART MESSAGE AFTER MIKE - VTG 1	EMPTY
L86	RESTART MESSAGE AFTER MIKE - VTG 2	EMPTY
L95	SATELLITE PHONES - SCC 4100 ON/OFF	EMPTY
L96	SATELLITE PHONES - SCC 4100 NORMAL/SHORT	EMPTY
L97	SATELLITE PHONES - SCC 4100 ON/OFF RMPH	EMPTY
L100	POINTS TO EXCLUDE FROM AUTOMAP	EMPTY
L102	LISTS TO AUTO-GENERATE EXTERNAL POINTS	22
L103	EXTERNAL DETECTOR RESET PSEUDO	EMPTY
L104	EXTERNAL SYSTEM RESET PSEUDO	EMPTY
L105	EXTERNAL DETECTOR/SYSTEM RESET PSEUDO	EMPTY
L106	EXTERNAL SIGNAL SILENCE PSEUDO	EMPTY
L107	ENTER LOCAL MODE ON DATA NOT AVAILABLE	EMPTY
L109	ALARM SILENCED LED CONTROL	2
L112	EXTERNAL PRIORITY 2 RESET PSEUDOS	EMPTY
L110	INHIBIT NETWORK LABEL UPDATE	EMPTY

♀

SHEPARD'S BUILDING  
9520019D node:1 rev:16

OPTIONS DETAIL REPORT

Page 112  
10:27:30, TUE, 19-NOV-13

OPTIONS  
PASSCODES

Display Function	Protection Level
Alarm Silence	1
System Reset	1
Change Time and Date	2
Panel Control Key 1	2
Panel Control Key 2	2
Panel Control Key 3	2
Panel Control Key 4	2
Panel Control Key 5	2
ON/OFF/AUTO Keys	2
ARM/DISARM Keys	2
Change TrueAlarm Sensitivities	3
DISABLE/ENABLE Keys	3



URI CCE points list 11-2013 (002)

♀

SHEPARD'S BUILDING CUSTOM CONTROL EQUATION SUMMARY Page 116  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CUSTOM CONTROL  
 EQU SUMMARY

Program: 3

Program: 3

Equation No.	Label
1	Hold Emergency Door Locks on-Sys Startup
2	Alarm at Door#104-Turn on Aux27 & Aux34
3	Alarm at Door#110-Turn on Aux28 & Aux34
4	Alarm at Door#113-Turn on Aux29 & Aux34
5	Alarm at Door#122-Turn on Aux30 & Aux34
6	Alarm at Door#128-Turn on Aux31 & Aux34
7	Trouble any Door lock-Turn on Aux33
8	General Alarm-Release all Emerg Door Lks
9	Relock Emergency Doors-Keyswitch Off
10	[END-OF-PROGRAM]

♀

SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 117  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CUSTOM CONTROL  
 EQU DETAIL

Program: 3

Program: 3

Label: Hold Emergency Door Locks on-Sys Startup

Equation 1

COMMENTS:

INPUTS:

The ON state of:

A34 TIMER SYSTEM STARTUP PULSE TIMER

OUTPUTS:

HOLD points ON pri=9,9

M2-40	RELAY	GROUND FLR NORTH DOOR LOCK DR 104	M2-40
M2-42	RELAY	GROUND FLR NORTH DOOR LOCK DR 113	M2-42
M2-44	RELAY	GROUND FLR NORTH DOOR LOCK DR 122	M2-44
M2-46	RELAY	GROUND FLR NORTH DOOR LOCK DR 128	M2-46
M3-34	RELAY	GROUND FLOOR DOOR LOCK DR 110	M3-34

END:

Label: Alarm at Door#104-Turn on Aux27 & Aux34

Equation 2

COMMENTS:

INPUTS:

The ON state of:

M2-41 UTILITY GROUND FLR NORTH DOOR MON DR 104 M2-41

OUTPUTS:

TRACK points ON pri=9,9

AUX27	RELAY	DOOR 104 MONITORS M2-41 IAM-ANN LT	AUX27
AUX34	RELAY	DOOR ALARM ANNUNCIATOR PIEZO	AUX34

END:

Label: Alarm at Door#110-Turn on Aux28 & Aux34

Equation 3

COMMENTS:

URI CCE points list 11-2013 (002)

INPUTS:

The ON state of:

M3-35 UTILITY GROUND FLOOR DOOR MON DR 110 M3-35

OUTPUTS:

TRACK points ON pri=9,9

AUX28 RELAY DOOR 110 MONITORS M3-35 IAM-ANN LT AUX28

AUX34 RELAY DOOR ALARM ANNUNCIATOR PIEZO AUX34

END:

Label: Alarm at Door#113-Turn on Aux29 & Aux34

Equation 4

COMMENTS:

INPUTS:

The ON state of:

M2-43 UTILITY DOOR MONITOR STR B GRD FL N DR 113 M2-43

OUTPUTS:

♀

SHEPARD'S BUILDING

CUSTOM CONTROL EQUATION LISTING

Page 118

9520019D node:1 rev:16

10:27:30, TUE, 19-NOV-13

CUSTOM CONTROL  
EQU DETAIL

Program: 3

Program: 3

TRACK points ON pri=9,9

AUX29 RELAY DOOR 113 MONITORS M2-43 IAM-ANN LT AUX29

AUX34 RELAY DOOR ALARM ANNUNCIATOR PIEZO AUX34

END:

Label: Alarm at Door#122-Turn on Aux30 & Aux34

Equation 5

COMMENTS:

INPUTS:

The ON state of:

M2-45 UTILITY DOOR MON NEAR REST RM GRD FL DR122 M2-45

OUTPUTS:

TRACK points ON pri=9,9

AUX30 RELAY DOOR 122 MONITORS M2-45 IAM-ANN LT AUX30

AUX34 RELAY DOOR ALARM ANNUNCIATOR PIEZO AUX34

END:

Label: Alarm at Door#128-Turn on Aux31 & Aux34

Equation 6

COMMENTS:

INPUTS:

The ON state of:

M2-47 UTILITY DOOR MON NEAR ELECTRIC ROOM DR 128 M2-47

OUTPUTS:

TRACK points ON pri=9,9

AUX31 RELAY DOOR 128 MONITORS M2-47 IAM-ANN LT AUX31

AUX34 RELAY DOOR ALARM ANNUNCIATOR PIEZO AUX34

END:

Label: Trouble any Door lock-Turn on Aux33

Equation 7

COMMENTS:

INPUTS:

The TROUBLE state of:

L128 CONTROL ALL EMERGENCY EXIT DOOR LOCKS

OUTPUTS:

TRACK points ON pri=9,9

URI CCE points list 11-2013 (002)

AUX33 RELAY DOOR ALARM TROUBLE-ANN LT & PIEZO AUX33  
END:

Label: General Alarm-Release all Emerg Door Lks Equation 8

COMMENTS:

INPUTS:

The DETECT state of:  
L18 MIXED GENERAL FIRE ALARM MONITOR ZONES  
OR the ON state of:

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 119  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU DETAIL

Program: 3 Program: 3

M1-45 UTILITY ALL EMERGENCY EXIT DOORS UNLOCK M1-45  
OUTPUTS:  
HOLD points OFF pri=9,9  
L128 CONTROL ALL EMERGENCY EXIT DOOR LOCKS  
END:

Label: Relock Emergency Doors-Keyswitch off Equation 9

COMMENTS:

INPUTS:

NOT the ON state of:  
M1-45 UTILITY ALL EMERGENCY EXIT DOORS UNLOCK M1-45  
OUTPUTS:

HOLD points ON pri=9,9  
L128 CONTROL ALL EMERGENCY EXIT DOOR LOCKS  
END:

Label: [END-OF-PROGRAM] Equation 10

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION SUMMARY Page 120  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU SUMMARY

Program: 4 Program: 4

Equation No.	Label
1	Alm Pass.Elev Shaft/Mach RM-Dmp M6-93 on
2	Alm Frgt.Elev.Shaft/Mach Rm-Dmp M6-94 on
3	[END-OF-PROGRAM]

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 121  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU DETAIL

Program: 4 Program: 4

URI CCE points list 11-2013 (002)

Label: Alm Pass.Elev Shaft/Mach RM-Dmp M6-93 on Equation 1

COMMENTS:

INPUTS:

OR DETect the points:

M6-98	SMOKE	ZN15 PASSENGER ELEV PENTHOUSE	M6-98
M6-99	PULL	ZN15 PASSENGER ELEV PENTHOUSE	M6-99
M6-119	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-119
M6-120	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-120
M6-121	HEAT	ZN14 TOP OF PASSENGER ELEV SHAFT	M6-121

OUTPUTS:

HOLD points ON pri=9,9  
M6-93 CDAMPER PASSNGR ELEV DAMPER CONTROL STATUS M6-93

END:

Label: Alm Frgt.Elev.Shaft/Mach Rm-Dmp M6-94 on Equation 2

COMMENTS:

INPUTS:

OR DETect the points:

M6-100	PULL	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-100
M6-101	SMOKE	ZN15 FREIGHT ELEVATOR PENTHOUSE	M6-101
M6-102	HEAT	ZN15 FREIGHT ELEV PENTHOUSE REAR	M6-102
M6-106	HEAT	ZN15 TOP OF FREIGHT ELEV SHAFT	M6-106

OUTPUTS:

HOLD points ON pri=9,9  
M6-94 CDAMPER FREIGHT ELEV DAMPER CONTROL STATUS M6-94

END:

Label: [END-OF-PROGRAM] Equation 3

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION SUMMARY Page 122  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU SUMMARY

Program: 5 Program: 5

Equation No.	Label
1	Speaker and Strobe Circuit Bypass on Alm
2	Fan/Damper/Gas Control Bypass on Alarm
3	Remote Microphone Operation-Switch On
4	Remote Microphone Operation-Switch Off
5	city trip
6	[END-OF-PROGRAM]

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 123  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU DETAIL

Program: 5 Program: 5

Label: Speaker and Strobe Circuit Bypass on Alm Equation 1  
Page 74

URI CCE points list 11-2013 (002)

COMMENTS:

INPUTS:

The DETECT state of:

L18 MIXED

AND the ON state of:

P257 TROUBLE

GENERAL FIRE ALARM MONITOR ZONES

SIGNAL CIRCUITS BYPASS

OUTPUTS:

HOLD points OFF pri=7,9

SIG3	SSIGNAL	LOWER LEVEL STROBE CIRCUIT	SIG3
SIG4	SSIGNAL	LOWER LEVEL STROBE CIRCUIT	SIG4
SIG5	SSIGNAL	SPARE	SIG5
SIG6	SSIGNAL	SPARE	SIG6
SIG7	SSIGNAL	SPARE	SIG7
SIG8	SSIGNAL	SPARE	SIG8
SIG9	SPEAKER	LOWER LEVEL SPEAKER CIRCUIT	SIG9
SIG10	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG11	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG12	SPEAKER	SPARE	SIG12
SIG13	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG14	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG15	SPEAKER	GROUND FLOOR NORTH SPEAKER CIRCUIT	SIG15
SIG16	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG17	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG18	SPEAKER	SECOND FLOOR NORTH SPEAKER CIRCUIT	SIG18
SIG19	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG20	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	
SIG21	SSIGNAL	GROUND FLOOR NORTH STROBE CIRCUIT	SIG21
SIG22	SSIGNAL	GROUND FLOOR NORTH STROBE CIRCUIT	SIG22
SIG23	SSIGNAL	SECOND FLOOR NORTH STROBE CIRCUIT	SIG23
SIG24	SSIGNAL	SECOND FLOOR NORTH STROBE CIRCUIT	SIG24
SIG25	SSIGNAL	SPARE	SIG25
SIG26	SSIGNAL	SPARE	SIG26
SIG27	SSIGNAL	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG27
SIG28	SSIGNAL	GROUND FLOOR SOUTH STROBE CIRCUIT	SIG28
SIG29	SSIGNAL	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG29
SIG30	SSIGNAL	SECOND FLOOR SOUTH STROBE CIRCUIT	SIG30
SIG31	SVISUAL	GND FLR DAYCARE STROBE CIRCUIT	SIG31
SIG32	SSIGNAL	SIGNAL CIRCUIT	SIG32
SIG33	SPEAKER	GROUND FLOOR SOUTH SPEAKER CIRCUIT	SIG33
SIG34	SPEAKER	GROUND FLR DAYCARE CENTER SPEAKERS	SIG34
SIG35	SPEAKER	SIGNAL CARD 19 CIRCUIT	SIG35
SIG36	SPEAKER	SECOND FLOOR SOUTH SPEAKER CIRCUIT	SIG36
SIG37	SPEAKER	SIGNAL CARD 19 CIRCUIT	SIG37
SIG38	SPEAKER	SIGNAL CARD 19 CIRCUIT	SIG38

♀

SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 124  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CUSTOM CONTROL  
 EQU DETAIL

Program: 5

Program: 5

SIG39	SSIGNAL	THIRD FLOOR NORTH STROBE CIRCUIT	SIG39
SIG40	SSIGNAL	THIRD FLOOR NORTH STROBE CIRCUIT	SIG40
SIG41	SSIGNAL	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG41
SIG42	SSIGNAL	FOURTH FLOOR NORTH STROBE CIRCUIT	SIG42
SIG43	SSIGNAL	SPARE	SIG43
SIG44	SSIGNAL	SPARE	SIG44
SIG45	SPEAKER	THIRD FLOOR NORTH SPEAKER CIRCUIT	SIG45
SIG46	SIGNAL	*** SIGNAL CIRCUIT NOT AVAILABLE ***	

```

                URI CCE points list 11-2013 (002)
SIG47          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG48          SPEAKER         FOURTH FLOOR NORTH SPEAKER CIRCUIT SIG48
SIG49          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG50          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG51          SSIGNAL         THIRD FLOOR SOUTH STROBE CIRCUIT   SIG51
SIG52          SSIGNAL         THIRD FLOOR SOUTH STROBE CIRCUIT   SIG52
SIG53          SSIGNAL         FOURTH FLOOR MET SCHOOL STROBES   SIG53
SIG54          SSIGNAL         FOURTH FLOOR SOUTH STROBE CIRCUIT   SIG54
SIG55          SSIGNAL         SPARE                               SIG55
SIG56          SSIGNAL         SPARE                               SIG56
SIG57          SPEAKER         THIRD FLOOR SOUTH SPEAKER CIRCUIT   SIG57
SIG58          SPEAKER         FOURTH FLOOR MET SCHOOL SPEAKERS   SIG58
SIG59          SPEAKER         SIGNAL CARD 29 CIRCUIT             SIG59
SIG60          SPEAKER         FOURTH FLOOR SOUTH SPEAKER CIRCUIT   SIG60
SIG61          SPEAKER         SIGNAL CARD 29 CIRCUIT             SIG61
SIG62          SPEAKER         SIGNAL CARD 29 CIRCUIT             SIG62
SIG63          SSIGNAL         FIFTH FLOOR NORTH STROBE CIRCUIT   SIG63
SIG64          SSIGNAL         FIFTH FLOOR NORTH STROBE CIRCUIT   SIG64
SIG65          SSIGNAL         SIXTH FLOOR NORTH STROBE CIRCUIT   SIG65
SIG66          SSIGNAL         SIXTH FLOOR NORTH STROBE CIRCUIT   SIG66
SIG67          SSIGNAL         SPARE                               SIG67
SIG68          SSIGNAL         SPARE                               SIG68
SIG69          SPEAKER         FIFTH FLOOR NORTH SPEAKER CIRCUIT   SIG69
SIG70          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG71          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG72          SPEAKER         SIXTH FLOOR NORTH SPEAKER CIRCUIT   SIG72
SIG73          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***
SIG74          SIGNAL          *** SIGNAL CIRCUIT NOT AVAILABLE ***

```

END:

Label: Fan/Damper/Gas Control Bypass on Alarm

Equation 2

COMMENTS:

INPUTS:

The ON state of:

P256 TROUBLE

FAN/DAMPER CONTROL BYPASS

OUTPUTS:

HOLD points OFF pri=7,9  
M6-93 CDAMPER

PASSNGR ELEV DAMPER CONTROL STATUS M6-93

♀

-----  
SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 125  
9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
-----

CUSTOM CONTROL  
EQU DETAIL

Program: 5

Program: 5

M6-94 CDAMPER  
AUX21 RRELAY

FREIGHT ELEV DAMPER CONTROL STATUS M6-94  
GAS VALVE SHUTDOWN AUX21

END:

Label: Remote Microphone Operation-Switch On

Equation 3

COMMENTS:

INPUTS:

The ON state of:

M1-44 UTILITY

REMOTE MICROPHONE ASTALK ON/OFF SW M1-44

OUTPUTS:

TRACK points ON pri=9,9  
P114 UTILITY

ALL SPEAKERS CHANNEL 1 ON

END:

URI CCE points list 11-2013 (002)

Label: Remote Microphone Operation-Switch Off Equation 4

COMMENTS:  
 INPUTS:  
     NOT the ON state of:  
         M1-44           UTILITY           REMOTE MICROPHONE ASTALK ON/OFF SW M1-44  
 OUTPUTS:  
     TRACK points ON pri=9,9  
         P115           UTILITY           ALL SPEAKERS CHANNEL 1 OFF  
 END:

Label: city trip Equation 5

COMMENTS:  
 INPUTS:  
     The ON state of:  
         P11           UTILITY           UNACKNOWLEDGED FIRE ALARM EXISTS  
     AND NOT the ON state of:  
         P34           TROUBLE           CITY DISCONNECT  
 OUTPUTS:  
     HOLD points ON pri=9,9  
         0-7-3         OUTPUT           Master Output - City Alarm relay  
 END:

Label: [END-OF-PROGRAM] Equation 6

♀

-----  
 SHEPARD'S BUILDING           CUSTOM CONTROL EQUATION SUMMARY Page 126  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CUSTOM CONTROL  
EQU SUMMARY

Program: 6 Program: 6

Equation No.	Label
1	Daycare Drill Switch On-Spkr/Strbes On
2	Daycare Drill Switch Off-Spkr/Strbes Off
3	All Bldg Drill Sw On-Spkr/Strbes On
4	All Bldg Drill Sw Off-Spkr/Strbes Off
5	[END-OF-PROGRAM]

♀

-----  
 SHEPARD'S BUILDING           CUSTOM CONTROL EQUATION LISTING Page 127  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

CUSTOM CONTROL  
EQU DETAIL

Program: 6 Program: 6

Label: Daycare Drill Switch On-Spkr/Strbes On Equation 1

COMMENTS:  
 INPUTS:  
     The ON state of:  
         M1-42           UTILITY           DRILL SWITCH DAYCARE CENTER GND FL M1-42  
     AND NOT the ON state of:  
         P257           TROUBLE           SIGNAL CIRCUITS BYPASS  
Page 77

URI CCE points list 11-2013 (002)

OUTPUTS:

MARCH TIME G0; L12; on=1/4; off=1/4; pri=9,9  
 SILENCE VTG1 pri=15,15  
 PLAY VTG1=A55 CHL1=VTG1 L133=CHL1 trk=P89 pri=9,9  
 SPEAKER CHL1 pri=9,9  
 L133 CONTROL DAYCARE SPEAKER CIRCUITS

END:

Label: Daycare Drill Switch Off-Spkr/Strbes Off

Equation 2

COMMENTS:

INPUTS:

NOT the ON state of:

M1-42 UTILITY DRILL SWITCH DAYCARE CENTER GND FL M1-42

OUTPUTS:

HOLD points OFF pri=9,9  
 L12 CONTROL FIRE ALARM VISUALS OFF ON SILENCE  
 SILENCE VTG1 pri=9,9  
 HOLD points OFF pri=9,9  
 L133 CONTROL DAYCARE SPEAKER CIRCUITS

END:

Label: All Bldg Drill Sw On-Spkr/Strbes On

Equation 3

COMMENTS:

INPUTS:

The ON state of:

M1-43 UTILITY DRILL SWITCH MET SCHOOL 4TH FL SO. M1-43

AND NOT the ON state of:

P257 TROUBLE SIGNAL CIRCUITS BYPASS

OUTPUTS:

HOLD points ON pri=9,9  
 L135 CONTROL ALL STROBE CIRCUITS FOR BLDG DRILL  
 MARCH TIME G0; L12; on=1/4; off=1/4; pri=9,9  
 SILENCE VTG1 pri=15,15  
 PLAY VTG1=A55 CHL1=VTG1 L136=CHL1 trk=P89 pri=9,9  
 SPEAKER CHL1 pri=9,9  
 L136 CONTROL ALL SPEAKER CIRCUITS FOR ALL BLDG DRILL

‡

SHEPARD'S BUILDING CUSTOM CONTROL EQUATION LISTING Page 128  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13

CUSTOM CONTROL  
 EQU DETAIL

Program: 6

Program: 6

END:

Label: All Bldg Drill sw Off-spkr/Strbes Off

Equation 4

COMMENTS:

INPUTS:

NOT the ON state of:

M1-43 UTILITY DRILL SWITCH MET SCHOOL 4TH FL SO. M1-43

OUTPUTS:

HOLD points OFF pri=9,9  
 L135 CONTROL ALL STROBE CIRCUITS FOR BLDG DRILL  
 SILENCE VTG1 pri=9,9  
 HOLD points OFF pri=9,9  
 L136 CONTROL ALL SPEAKER CIRCUITS FOR ALL BLDG DRILL

END:

URI CCE points list 11-2013 (002)

Label: [END-OF-PROGRAM]

Equation 5

♀

-----  
 SHEPARD'S BUILDING REPORT CATEGORY INDEX Page 129  
 9520019D node:1 rev:16 10:27:30, TUE, 19-NOV-13  
 -----

INDEX

Report Category	Page Number
-----	
GENERAL INFORMATION	1
SYSTEM OPERATION	2
CARD SUMMARY BY LOCATION	3
SYSTEM POINT SUMMARY	5
DIGITAL PSEUDO POINT SUMMARY	15
ANALOG PSEUDO POINT SUMMARY	22
POINT LIST SUMMARY	27
POINT LIST DETAIL	30
PANEL KEYS AND LEDS REPORT	91
REMOTE UNIT INTERFACE (RUI) REPORT	92
UNIT DETAIL REPORT	94
2120/RS232 INTERFACE REPORT	108
AUDIO CONFIGURATION REPORT	109
OPTIONS DETAIL REPORT	110
NETWORK INTERFACE REPORT	114
TRUEALERT CARD DETAIL	--
VIRTUAL NACS REPORT	115
CUSTOM CONTROL EQUATION LISTING	117

♀