



State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387

**ADDENDUM # 3**

3/1/2016

Solicitation #7550203

*Title: Henry Barnard School Generator Replacement Project*

**Submission Deadline: March 16, 2016 @ 10:00 AM (ET)**

Per the issuance of ADDENDUM #3 the following are noted:

Vendor Submitted Questions: (see attached)  
Pre-Bid Attendance Sheet

**NOTICE TO VENDORS:**

**Engineers/Architects Consultants**

Respondents to this solicitation are hereby advised that the respondent selected for award of a contract pursuant to this solicitation, and its affiliated or subsidiary companies (whether partially or wholly owned), shall be ineligible to bid upon any future consulting or construction solicitations which may arise from or relate to the services described in this solicitation. In addition, any sub-consultants or subcontractors engaged by the respondent selected for award of a contract who performs any services arising from this solicitation shall be ineligible to bid upon any future consulting or construction solicitations which may arise from or relate to the services described in this solicitation.

*Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.*

**Gary P. Mosca**  
**Senior Buyer**



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website:  
[www.purchasing.ri.gov](http://www.purchasing.ri.gov)

**Vendor Questions:**  
**Bid Solicitation Number: 7550203**  
**Titled: Henry Barnard School Generator Replacement**

**Addendum #3**

**Question:** Can you provide a sketch showing location of ATS and remote annunciator?

**Response:** In lieu of a sketch the following information is being provide: The location of the ATS and remote annunciator is located in the Second Floor Room; above the existing generator location. There are approximately 100 circuit feet between the existing generator location and the ATS/remote annunciator. Conduit and wiring may be installed exposed within the Server Room, similar to the existing wiring.

**Question:** Can existing generator pad be demo during school hours?

**Response:** Henry Barnard School hours are from 7am-3pm, last day of classes is 13 June. If concrete pad is to be demoed prior to 13 June work may be done between the hours of 3-5pm. If pad is to be demoed after 13 June work may be done at any time, however no earlier than 6am and no later than 5pm. If the contract is awarded prior to April 1, 2016 the concrete pad can be demoed the week of April 18 – 22, 2016, which is school vacation.

**Question:** Will the existing remote annunciator be compatible with the new generator control system?

**Response:** The existing remote annunciator will be removed and replaced. A new remote annunciator will be provided and it shall comply with NFPA 110. Annunciator shall be LED labeled with proper alarm conditions to identify each alarm event and a common audible signal shall sound for each alarm condition. New wiring shall be replace the existing and be installed in existing raceway. Wiring shall be provided as required by the generator manufacturer.

**Question:** Who is response for fueling the generator?

**Response:** The contractor shall provide fuel for testing and shall also fill the tank after testing is complete.

**Question:** Is a temporary generator required? What size temporary generator is required?

**Response:** A temporary generator is required. This generator feeds a data center that shall remain operational. Outages shall be schedule with the Facilities. Outage shall be kept to a minimum. Temporary generator shall be 100 kW.

**Question:** What is to be done with the existing generator?

**Response:** Existing generator shall be transported to a site on Campus as directed by the Facilities Engineering.



State of Rhode Island  
 Division of Purchases  
 One Capitol Hill  
 Providence, RI 02908

"NON-MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

**BID NUMBER:** 7550203  
**BID TITLE:** Henry Bernard School Generator Replacement Project  
**PRE-BID DATE AND TIME:** 2/26/16 @ 9:00 A.M.

**Purchasing Representative:** Gary P. Mosca  
**Pre-bid START TIME:** 9:00 AM  
**Pre-bid END TIME:** 3:25 AM

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT EMAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
1 State of Rhode Island	Gary P. Mosca	1 Capitol Hill, Providence, RI 02908	gary.mosca@purchasing.ri.gov	401-574-8124	401-574-8387	
2 Beth Shoret Generator	Michael Meynau	247 (Lansdown Hwy) Whitman	MMEYNAU@SIR.COM	774-205-3394	(508) 295-9682	
3 Charles Webster	-	317 NEW BRIDGE CORP	CHARLESWEBSTER@FALCO.COM	401-644-7937		
4 TRAM BUILDERS	Brian Ross	28 WILMOT ST FARMVILLE RI	ESTIMATING@TRAMBUILDERS.COM	401-943-3800	401-943-3822	
5 CARSON CORP	STEVE CAROZZO	34 ORTHOTE THE TOWN RI	STEVE@CARSONCORP.COM	401-372-1100	401-373-0035	
6 K ELECTRIC	DAVE KIRK	2640 WARWICK HWY WARWICK RI	DAVEK@KELCENRIC.COM	401-739-6000	401-739-7600	
7 NOLAN ELECTRIC	JEFF NOLAN	PO BOX 947 N. SUTHERLE RI	JEFF@NOLANELECTRIC.NET	401-647-5478	401-647-2780	
8 RF Andert	Raymond Andert	East Coastersh 169 Boy street Providence	RAndert@RFAndert.com	401-467-3510		
9 EW Andert	Matthew Labounty	81 Pine St WARRICK, RI 02888	mlabounty@ewandert.com	401-785-9850	401-785-2450	
10 JT O'ROURKE	Richard Tocco	166 DOYLE AV PROVIDENCE RI	ANDY@CKELECTRIC.COM	401-286-2659		
11 CK ELECTRIC	ANDY THERIEN	h	RIS@CKELECTRIC.COM	401-391-3901		
12 n	Robert Melman	600 Mt. Pleasant and Abenwards Ave	Abenwards@rci.edu	401-787-3089		
13 RSE	DAVID BENEVIDES					
14 PIC	Meghan Yeeffe	600 Mt. Pleasant Ave	MYEEFFE@RCI.EDU	401-495L-8204P		
15						