



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

March 10, 2016

ADDENDUM NUMBER ONE

RFQ #7550356

**TITLE: ACCESSIBLE RAMP INSTALLATION AT ROGER WHEELER STATE
BEACH, NARRAGANSETT, RI**

Closing Date and Time: 3/16/16 at 1:30PM

Per the issuance of this ADDENDUM #1 (4 pages) the following is noted:

Attached is the sign in sheet from the non-mandatory pre bid conference held 3/9/16 at 1pm.

Attached are the notes from the pre bid conference.

Attached is updated railing specification.

As noted by buyer:

This is a non-mandatory pre bid conference

There may be other bids received from vendors who do not attend this pre bid.

Questions are being accepted on line until 3/10/16 at 5pm. The email address and instructions how to submit questions is on the bid proposal. NONE RECEIVED.

Bid bond is required

Performance bond is required

Specifications and plans are posted on the website.

This is a public works project and as such requires a CD be submitted along with the paper copy of your bid. Instructions on how to do that are included in the bid package.

The contract times are listed on the bid form (item #4 on the bid form) .

There are liquidated damages of \$800 per day, also indicated on the bid form.


Please note the clauses that pertain to public works projects.

This is a prevailing wage project. Note the certification within the bid package that acknowledges you are aware of your obligations as they pertain to prevailing wage.

Included is a bid preparation check list to help you. It is not a substitute for a thorough review of the instructions to bidders.

We are also asking that you submit a new state w-9. The state form is different from the federal form.

This bid is scheduled to open on 3/16 at 1:30pm. The tentative schedule is to send out a tentative letter of award on 3/17. Vendor will be given 10 days to supply required information (bond, insurance, etc). Award will be made as soon as all required information is received. PO's are now being sent electronically. Hopefully po in place no later than 4/1.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

March 9, 2016

ADDENDUM NUMBER ONE

RFQ #7550356

**TITLE: ACCESSIBLE RAMP INSTALLATION AT ROGER WHEELER STATE
BEACH, NARRAGANSETT, RI**

Notes from pre bid conference:

The current site meets ADA requirements. The ramps being installed are convenience ramps that need to meet ADA requirements.

Ramps can be built in place, can be built in another part of parking lot and installed in location, or can be built off site and installed in location.

The plans provide for the ramps to be built in such a way that they can be moved if required.

DEM will be responsible for any sand removal/relocation on beach side of new ramp location.

The drawings are acceptable as is.

Accessible Ramp Installation
Roger Wheeler State Beach
Narragansett, RI

SOLICITATION NUMBER: 7550356

Addendum #1

Delete Specification Section 06010 2.2- A- 3 and replace with the following language:

3. The pipe handrail/guardrail shall be constructed with mechanically fastened, smooth and continuous A.D.A. Railing System of aluminum fittings as regularly manufactured by The Hollaender Manufacturing Company, 10285 Wayne Avenue, Box 156399, Cincinnati, Ohio 45215-6399, or approved equal. The design of the handrail bracket shall provide a 1 ½" clearance between the post and the rail, and allow for adjustment of the rail to match the angle of the ramp or stairs. Handrail brackets and pipe fittings shall provide a continuous, uninterrupted gripping surface with no sharp edges or projections. The bracket shall be externally connected to the post by means of an anodized aluminum, tubular rivet nut, and an austenitic 302 alloy stainless steel hexagon socket, button head, cap screw. The bracket shall be connected to the underside of the rail by means of two stainless steel, flat countersunk head, Type F self-tapping screws that conform to ANSI/ASME- B18.6.4 Pipe fittings shall be internally connected to the pipe by means of an internal double tang, expanded by an austenitic 302 alloy stainless steel, internal/external, reverse knurl, cup point, hexagon socket set screw. Pop rivets, sheet metal screws, and adhesives shall not be an acceptable fastening method. The brackets and fittings shall be of high tensile aluminum magnesium alloy 535 manufactured in compliance with ASTM B26, cast from high-purity ingot 535.2 conforming to ASTM B179.