



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

May 9, 2016

**ADDENDUM NUMBER TWO**

**RFQ # 7550560**

**TITLE: Electrical Switchboard Upgrade, DOA**

**Closing Date and Time: 5/25/16 at 11:30 AM**

**Per the issuance of this ADDENDUM # (2), 3 pages, including this cover sheet.**

**Specification Change /Addition / Clarifications**

Listed are additional questions we received for this Invitation to Bid. Please include this information when submitting your Bid Response.

1. Q. Are you requesting a feasibility or actual load study for switchboard No.2?  
A. Load Study
2. Q. Can you provide more information on the existing Trayer Switch? The manufacturer's representative claims the information provided is inadequate.  
A. See attached photo #7617T.E.C. Cat No G3800035 VDG5M3WY
3. Q. Are the new CT's for breaker #24 to be ring type or bus mounted?  
A. Ring
4. Q. Clarify the overtime workday shutdowns. Are they Monday through Friday?  
A. Monday thru Friday 3 pm to 8 pm Saturday and Sunday 7 am to 8 pm.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

5. Is circuit breaker #24 presently being utilized? If so, how long can the feeder be shut down?  
A. It is not in use.
6. Q. Can the switchboard be viewed? If so, who do we contact?  
A. No