



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

June 7, 2016

**ADDENDUM NUMBER THREE**

**RFQ # 7550595**

**TITLE: Improvements to the Emergency Power, Pastore Center, Regan Building, DOA**

**Closing Date and Time: 6/14/16 at 1:30 PM**

**Per the issuance of this ADDENDUM # (3) 1 page, including this cover sheet.**

**Specification Change /Addition / Clarifications**

Listed are (2) clarifications for this Invitation to Bid. Please include this information when submitting your Bid Response.

SECTION 16614 – DIESEL GENERATOR SETS ARCHITECTURAL FORMAT – 750 KW

Section 2.4 FUEL OIL STORAGE, paragraph B. item 1 revise “Capacity 24 Hour(s) continuous operation at 100 percent rated power output.” to read, “Capacity 96 Hour(s) continuous operation at 100 percent rated power output.”

Drawing E-3 note 5 revise note to read, “DISTANCE IS APPROXIMATELY 250’. DUCTBANK SHALL BE CONCRETE ENCASED, AND SHALL CROSS ASPHALT WALKWAY AND BE ROUTED IN GRASSED AREA TO SWITCH. RESTORE SURFACE TO AS WAS CONDITION AFTER INSTALLATION. PROVIDE 600 AMP ELBOW TERMINATIONS WITH TEST PORTS.”