



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 2, 2016
ADDENDUM NUMBER TWO
RFQ #7550607

**TITLE: FURNISH AND INSTALL GENERATOR AT THE FORAND BUILDING
(DMV)**

Closing Date and Time: 6/13/16 at 2:00 PM

Per the issuance of this ADDENDUM #2 (2 pages and PDF files) the following is noted:

This addendum posts clarifications to questions raised at the pre bid conference.

This addendum posts answers to questions sent in on line and accepted until 5pm on 6/1/16.

This addendum posts revised drawings and specifications (in PDF format).

PRE BID QUESTIONS/RESPONSES

Q1. Is the contractor to relocate the existing benches at the end of pad area to be extended?
A. The generator size has been reduced. Pad is no longer being extended.

Q2. What is to be done with the generators and the propane tank scheduled to be removed.

Response:

A. The existing generators shall be brought to a location at the Pastore Power Plant.
The propane tank shall be removed by "Ferrell Gas" who own and maintain tank, Contractor shall coordinate this removal.

Q3. Specification was requested for the existing fence.

A. Generator size has been reduced and fence relocation is not required see revised drawings.

Q4. What constitutes "after hours" When can contractor work.

A. After hours is anytime that the DMV is not in operation. After hours work will be weekends.

Q5. What is the size of the temporary generator?

A. Two temporary generators will be required one 150 kW for the life safety panel and fire pump and the other a 600 kW to operate during service change. Contractor is responsible for both

Q6. What type of electric manhole is required?

A. A split style manhole or one without a bottom. If later is provide pour floor with a sump after installation.

DRAWING CHANGES

Drawings E-3 and E-4 are being reissued.

SPECIFICATIONS

Replace Section 16613 in its entirety



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 2, 2016
ADDENDUM NUMBER TWO
RFQ #7550607
TITLE: FURNISH AND INSTALL GENERATOR AT THE FORAND
BUILDING (DMV)

Questions sent in on line:

1. Is the South wall of the Security Screen being moved 3' South and reinstalled and East and West wall extended
 - A. Generator size has changed and footprint allow for Security Screen to remain in place.
2. Bid Form has allowances and alternate's, unit prices not shown on plans
 - A. Bid form is a template used on many bids. There are no allowances, alternates, or unit pricing required.
3. Would Generac Industrial Power be considered an approved equal as long as its performance is shown to meet or exceed the specified requirements?
 - A. See revised specifications attached, Part 2, PRODUCTS, section 2.1 MANUFACTURERS.

END OF QUESTIONS